



Water and Wastewater Operations and Management
 375 Lake Meadows Drive, Montgomery, Texas 77356
 Ph:936-588-1166

CITY OF MONTGOMERY

MONTHLY OPERATIONS REPORT

DATE
 10/08/25

<u>METER COUNT</u>	
<i>Total</i>	1,440

<u>CONSUMPTION</u>		
07/30/25	to	08/31/25
Billed Consumption		19,729,213
Estimated Flushing		1,025,000
Total		20,754,213

Plant Pumpage 22,492,000

Accountability **92.27%**

	<u>Well #2</u>	<u>Well #3</u>	<u>Well #4</u>
Well Pumpage	N/A	12,214,000	10,278,000
Calculated Well GPM	N/A	526	1202
Avg Well Run Hours	N/A	13.3	4.7

CITY OF MONTGOMERY

DATE
10/08/25

MONTHLY OPERATIONS SUMMARY

WASTEWATER TREATMENT PLANT

August 2025

TPDES Permit # WQ0014737001

Expires: 06/01/2027

NPDES Permit # TX0128031

	Effluent Quality Data: Reported for			
	Reported	Permitted	August-25 Annual Average	Excursion
BOD 5 Average	2.43 mg/l	10.00 mg/l	2.52 mg/l	NO
TSS Average	7.01 mg/l	15.00 mg/l	4.86 mg/l	NO
NH3	0.05 mg/l	2.00 mg/l	0.05 mg/l	NO
CL2 Res Min	1.06 mg/l	1.00 mg/l	1.43 mg/l	NO
CL2 Res Max	3.31 mg/l	4.00 mg/l	3.53 mg/l	NO
Oxygen	7.09 mg/l	4.00 mg/l	7.48 mg/l	NO
Flow Average	0.224 mgd	0.400 mgd	0.237 mgd	NO

Effluent Quality Compliant with Discharge Permit ?

YES

The plant was operated within all parameters of our permit.

No violation notices were received from any other local agency.

CITY OF MONTGOMERY
MONTHLY OPERATIONS SUMMARY
GROUND WATER PERMIT PUMPAGE
August 2025

LONE STAR GROUNDWATER CONSERVATION DISTRICT
PERMIT #OP-04072101D/HUP040 & 13012801B AWS - 01/01/25 - 12/31/25

	"Gulf Coast Aquifer" - Jasper		Catahoula Aquifer	
Jan-25	6,094,300		6,240,000	
Feb-25	5,256,300		6,868,000	
Mar-25	7,347,100		8,224,000	
Apr-25	7,680,000		8,304,000	
May-25	9,852,600		8,637,000	
Jun-25	8,811,700		8,053,000	
Jul-25	9,068,100		9,493,000	
Aug-25	12,637,100		10,278,000	
Sep-25				
Oct-25				
Nov-25				
Dec-25				
Total Pumpage	66,747,200	34.93%	66,097,000	34.56%
<u>2025 Permitted Withdrawal:</u>	<u>191,081,000</u>		<u>191,250,000</u>	

Permit Summary Gulf Coast Aquifier

Historical Use Permit Amount:	92,930,000
2025 Permitted Withdrawal:	92,930,000

Alternative Water Summary

City of Montgomery - Alternate Water Source Permit:	90,000,000
Total 2025 GRP AWS Permitted Withdrawal:	90,000,000