

CITY OF MONTGOMERY

MONTHLY OPERATIONS REPORT

<u>DATE</u> 01/22/25

METER COU	NT
Total	1,272

CONS	UMPTION	
11/30/24	to	12/30/24
Billed Consumption		10,874,771
Estimated Flushing		450,000
Total		11,324,771

Plant Pumpage 12,689,400

Accountability 89.25%

	Well #2	Well #3	Well #4
Well Pumpage	N/A	5,875,400	6,814,000
Calculated Well GPM	N/A	538	1260
Avg Well Run Hours	N/A	6.3	3.1

CITY OF MONTGOMERY

<u>DATE</u> 01/22/25

MONTHLY OPERATIONS SUMMARY

WASTEWATER TREATMENT PLANT December 2024

TPDES Permit # WQ0014737001 Expires: 06/01/2027

NPDES Permit # TX0128031

	Effluent Quality Data: Reported for		December-24		
	Reported	Permitted	Annual Average	Excursion	
BOD 5 Average	2.60 mg/l	10.00 mg/l	2.90 mg/l	NO	
TSS Average	2.35 mg/l	15.00 mg/l	4.93 mg/l	NO	
NH3	0.05 mg/l	2.00 mg/l	0.07 mg/l	NO	
CL2 Res Min	1.35 mg/l	1.00 mg/l	1.15 mg/l	NO	
CL2 Res Max	3.69 mg/l	4.00 mg/l	3.63 mg/l	NO	
Oxygen	7.94 mg/l	4.00 mg/l	7.60 mg/l	NO	
Flow Average	0.257 mgd	0.400 mgd	0.227 mgd	NO	

Effluent Quality Compliant with Discharge Permit?

YES

The plant was operated within all parameters of our permit. No violation notices were received from any other local agency.

CITY OF MONTGOMERY MONTHLY OPERATIONS SUMMARY

GROUND WATER PERMIT PUMPAGE December 2024

LONE STAR GROUNDWATER CONSERVATION DISTRICT PERMIT #OP-04072101D/HUP040 & 13012801B AWS - 01/01/24 - 12/31/24

	"Gulf Coast Aquifer" - Jasp	er	Catahoula Aquifer	
Jan-24	2,623,000		7,890,000	
Feb-24	2,380,000		7,436,000	
Mar-24	3,244,100	8,714,000		
Apr-24	3,161,600	9,650,000		
May-24	3,134,600	8,942,000		
Jun-24	4,151,900		9,667,000	
Jul-24	6,942,400	7,839,000		
Aug-24	1,495,800	00 15,051,000		
Sep-24	8,279,300	8,348,000		
Oct-24	15,554,300		7,508,000	
Nov-24	9,006,900		6,807,000	
Dec-24	6,103,600		7,004,000	
Total Pumpage	66,077,500	34.58%	104,856,000	54.83%

Permit Summary Gulf Coast Aquifier

191,250,000

191,081,000

2024 Permitted Withdrawal:

Historical Use Permit Amount:	92,930,000
2024 Permitted Withdrawal:	92,930,000

Alternative Water Summary

City of Montgomery - Alternate Water Source Permit:	90,000,000
Total 2024 GRP AWS Permitted Withdrawal:	90,000,000