

Montgomery City Council  
**AGENDA REPORT**

<b>Meeting Date:</b> 06/24/2025	<b>Budgeted Amount:</b> None
<b>Department:</b> Administration	<b>Prepared By:</b> WGA

**Subject**

Consideration and Possible Action regarding the approval of Change Order No. 2 to upsize the well motor and pump at Water Plant No. 2.

**Recommendation**

WGA and Staff recommend that Council approve the Change Order No.2 to upsize the well motor and pump at Water Plant No. 2.

**Discussion**

The Change Order and supporting documents are attached.

Following the results of the pump testing, it is recommended to increase the size of the well motor to maximize the pumping capability of the well. The original motor size includes a 60 HP motor, which will be upgraded to a 75 HP motor to achieve the desired output. Approval of the change order will result in a \$28,500.00 increase in the final contract amount to \$2,563,450.00. The Change Order also includes 14 days added to the original contracted amount. As a result, the plant is now scheduled for substantial completion in August of this year.

**Approved By**

City Staff	Ruby Beaven	Date: 06/18/2025
------------	-------------	------------------