

### **CITY OF MONTGOMERY**

### MONTHLY OPERATIONS REPORT

<u>DATE</u> 05/22/24

METE	ER COUN	<u>IT</u>
	Total	1,262

CONS	<b>UMPTION</b>	
03/31/24	to	04/30/24
Billed Consumption		11,727,520
Estimated Flushing		450,000
		12 155 520
Total		12,177,520

Plant Pumpage 12,811,600

Accountability 95.05%

	Well #2	Well #3	Well #4
Well Pumpage	N/A	3,161,600	9,650,000
Calculated Well GPM	N/A	517	1240
Avg Well Run Hours	N/A	3.4	4.3

### **CITY OF MONTGOMERY**

<u>DATE</u> 05/22/24

#### **MONTHLY OPERATIONS SUMMARY**

## WASTEWATER TREATMENT PLANT April 2024

TPDES Permit # WQ0014737001 Expires: 06/01/2027

NPDES Permit # TX0128031

	Effluent Quality Data: Reported for		April-24		
	Reported	Permitted	Annual Average	Excursion	
BOD 5 Average	3.64 mg/l	10.00 mg/l	3.16 mg/l	NO	
TSS Average	8.92 mg/l	15.00 mg/l	7.10 mg/l	NO	
NH3	0.07 mg/l	2.00 mg/l	1.91 mg/l	NO	
CL2 Res Min	1.17 mg/l	1.00 mg/l	1.12 mg/l	NO	
CL2 Res Max	3.88 mg/l	4.00 mg/l	3.85 mg/l	NO	
Oxygen	7.50 mg/l	4.00 mg/l	7.30 mg/l	NO	
Flow Average	0.221 mgd	0.400 mgd	0.223 mgd	NO	

Effluent Quality Compliant with Discharge Permit?

YES

The plant was operated within all parameters of our permit. No violation notices were received from any other local agency.

# CITY OF MONTGOMERY MONTHLY OPERATIONS SUMMARY

GROUND WATER PERMIT PUMPAGE April 2024

## LONE STAR GROUNDWATER CONSERVATION DISTRICT PERMIT #OP-04072101D/HUP040 & 13012801B AWS - 01/01/24 - 12/31/24

2,623,000		7,890,000	
2,380,000		7,436,000	
3,244,100		8,714,000	
3,161,600		9,650,000	
11,408,700	12.28%	33,690,000	37.43%
	2,380,000 3,244,100 3,161,600	2,380,000 3,244,100 3,161,600	2,380,000     7,436,000       3,244,100     8,714,000       3,161,600     9,650,000

### **Permit Summary Gulf Coast Aquifier**

90,000,000

92,930,000

2024 Permitted Withdrawal:

Historical Use Permit Amount:	92,930,000
2024 Permitted Withdrawal:	92,930,000

#### **Alternative Water Summary**

City of Montgomery - Alternate Water Source Permit:	90,000,000
Total 2024 GRP AWS Permitted Withdrawal:	90,000,000