

CITY OF MONTGOMERY

MONTHLY OPERATIONS REPORT

<u>DATE</u> 06/19/24

METE	ER COUN	<u> T</u>
	•	
	Total	1,234

CONS	UMPTION	
04/30/24	to	05/31/24
Billed Consumption		10,858,834
Estimated Flushing		560,000
Total	-	11,418,834

Plant Pumpage 12,076,600

Accountability 94.55%

	Well #2	Well #3	Well #4
Well Pumpage	N/A	3,134,600	8,942,000
Calculated Well GPM	N/A	520	1261
Avg Well Run Hours	N/A	3.2	3.9

CITY OF MONTGOMERY

<u>DATE</u> 06/19/24

MONTHLY OPERATIONS SUMMARY

WASTEWATER TREATMENT PLANT May 2024

TPDES Permit # WQ0014737001 Expires: 06/01/2027

NPDES Permit # TX0128031

	Effluent Quality Data: Reported for		May-24		
	Reported	Permitted	Annual Average	Excursion	
BOD 5 Average	2.74 mg/l	10.00 mg/l	3.10 mg/l	NO	
TSS Average	4.52 mg/l	15.00 mg/l	6.73 mg/l	NO	
NH3	0.06 mg/l	2.00 mg/l	1.65 mg/l	NO	
CL2 Res Min	1.00 mg/l	1.00 mg/l	1.10 mg/l	NO	
CL2 Res Max	3.89 mg/l	4.00 mg/l	3.85 mg/l	NO	
Oxygen	7.65 mg/l	4.00 mg/l	7.35 mg/l	NO	
Flow Average	0.274 mgd	0.400 mgd	0.231 mgd	NO	

Effluent Quality Compliant with Discharge Permit?

YES

The plant was operated within all parameters of our permit. No violation notices were received from any other local agency.

CITY OF MONTGOMERY MONTHLY OPERATIONS SUMMARY

GROUND WATER PERMIT PUMPAGE May 2024

LONE STAR GROUNDWATER CONSERVATION DISTRICT PERMIT #OP-04072101D/HUP040 & 13012801B AWS - 01/01/24 - 12/31/24

	"Gulf Coast Aquifer" - Jasj	per	Catahoula Aquifer	
Jan-24	2,623,000		7,890,000	
Feb-24	2,380,000		7,436,000	
Mar-24	3,244,100		8,714,000	
Apr-24	3,161,600		9,650,000	
May-24	3,134,600		8,942,000	
Jun-24				
Jul-24				
Aug-24				
Sep-24				
Oct-24				
Nov-24				
Dec-24				
Total Pumpage	14,543,300	15.65%	42,632,000	47.37%

Permit Summary Gulf Coast Aquifier

90,000,000

92,930,000

2024 Permitted Withdrawal:

Historical Use Permit Amount:	92,930,000
2024 Permitted Withdrawal:	92,930,000

Alternative Water Summary

City of Montgomery - Alternate Water Source Permit:	90,000,000
Total 2024 GRP AWS Permitted Withdrawal:	90,000,000