

CITY OF MONTGOMERY

MONTHLY OPERATIONS REPORT

<u>DATE</u> 04/17/24

METI	ER COUN	<u>T</u>
	Total	1,257

CONSUMPTION		<u>v</u>
02/29/24	to	03/31/24
Billed Consumption		10,929,091
Estimated Flushing		450,000
Total		11,379,091

Plant Pumpage 11,958,100

Accountability 95.16%

	Well #2	Well #3	Well #4
Well Pumpage	N/A	3,244,100	8,714,000
Calculated Well GPM	N/A	515	1297
Avg Well Run Hours	N/A	3.4	3.7

CITY OF MONTGOMERY

<u>DATE</u> 04/17/24

MONTHLY OPERATIONS SUMMARY

WASTEWATER TREATMENT PLANT March 2024

TPDES Permit # WQ0014737001 Expires: 06/01/2027

NPDES Permit # TX0128031

	Effluent Quality Data: Reported for		March-24		
	Reported	Permitted	Annual Average	Excursion	
BOD 5 Average	2.81 mg/l	10.00 mg/l	3.07 mg/l	NO	
TSS Average	2.68 mg/l	15.00 mg/l	6.73 mg/l	NO	
NH3	0.07 mg/l	2.00 mg/l	2.28 mg/l	NO	
CL2 Res Min	1.26 mg/l	1.00 mg/l	1.11 mg/l	NO	
CL2 Res Max	3.95 mg/l	4.00 mg/l	3.84 mg/l	NO	
Oxygen	8.27 mg/l	4.00 mg/l	7.26 mg/l	NO	
Flow Average	0.212 mgd	0.400 mgd	0.224 mgd	NO	

Effluent Quality Compliant with Discharge Permit?

YES

The plant was operated within all parameters of our permit. No violation notices were received from any other local agency.

CITY OF MONTGOMERY MONTHLY OPERATIONS SUMMARY

GROUND WATER PERMIT PUMPAGE March 2024

LONE STAR GROUNDWATER CONSERVATION DISTRICT PERMIT #OP-04072101D/HUP040 & 13012801B AWS - 01/01/24 - 12/31/24

	"Gulf Coast Aquifer" - Jasp	per	Catahoula Aquifer	
Jan-24	2,623,000		7,890,000	
Feb-24	2,380,000		7,436,000	
Mar-24	3,244,100		8,714,000	
Apr-24				
May-24				
Jun-24				
Jul-24				
Aug-24				
Sep-24				
Oct-24				
Nov-24				
Dec-24				
Total Pumpage	8,247,100	8.87%	24,040,000	26.71%

Permit Summary Gulf Coast Aquifier

90,000,000

92,930,000

2024 Permitted Withdrawal:

Historical Use Permit Amount:	92,930,000
2024 Permitted Withdrawal:	92,930,000

Alternative Water Summary

City of Montgomery - Alternate Water Source Permit:	90,000,000
Total 2024 GRP AWS Permitted Withdrawal:	90,000,000