

Montgomery City Council
AGENDA REPORT

Meeting Date: August 9, 2022	Budgeted Amount: N/A
Department: Admin	Prepared By: Dave McCorquodale

Subject

Consideration and possible action on a proposal from the city engineer for design and construction administration of the Lift Station No. 8 Force Main Repair.

Recommendation

Approval of the proposal as presented.

Discussion

As you are aware, the sanitary sewer force main from Lift Station No. 8 was damaged from erosion in the Town Creek channel and a temporary reroute has been set up along Lone Star Parkway since early July. This proposal is for the permanent repair to reroute the force main to hang from the structure of the bridge adjacent to the original route of the line (see exhibit in the proposal). Mounting the line to bridge structure ensures that no future erosion will affect the integrity of the line. This solution is normal practice and is similar to the water line mounted on the Buffalo Springs bridge.

Approved By

		Date:
Interim City Administrator	Dave McCorquodale	Date: 08/04/2022