



Water and Wastewater Operations and Management
375 Lake Meadows Drive, Montgomery, Texas 77356
Ph:936-588-1166

CITY OF MONTGOMERY

MONTHLY OPERATIONS REPORT

DATE
07/23/25

<u>METER COUNT</u>	
<i>Total</i>	1,380

<u>CONSUMPTION</u>		
<u>05/31/25</u>	<u>to</u>	<u>06/30/25</u>
Billed Consumption		14,307,645
Estimated Flushing		1,225,000
Total		15,532,645

Plant Pumpage **16,864,700**

Accountability **92.10%**

	Well #2	Well #3	Well #4
Well Pumpage	N/A	8,811,700	8,053,000
Calculated Well GPM	N/A	526.8	1199.4
Avg Well Run Hours	N/A	9.3	3.7

CITY OF MONTGOMERY

DATE
07/23/25

MONTHLY OPERATIONS SUMMARY

WASTEWATER TREATMENT PLANT

June 2025

TPDES Permit # WQ0014737001

Expires: 06/01/2027

NPDES Permit # TX0128031

	Effluent Quality Data: Reported for		June-25	Annual
	Reported	Permitted	Average	Excursion
BOD 5 Average	2.32 mg/l	10.00 mg/l	2.56 mg/l	NO
TSS Average	3.39 mg/l	15.00 mg/l	3.88 mg/l	NO
NH3	0.04 mg/l	2.00 mg/l	0.05 mg/l	NO
CL2 Res Min	1.92 mg/l	1.00 mg/l	1.41 mg/l	NO
CL2 Res Max	3.61 mg/l	4.00 mg/l	3.57 mg/l	NO
Oxygen	7.09 mg/l	4.00 mg/l	7.49 mg/l	NO
Flow Average	0.262 mgd	0.400 mgd	0.236 mgd	NO

Effluent Quality Compliant with Discharge Permit ? YES

The plant was operated within all parameters of our permit.

No violation notices were received from any other local agency.

CITY OF MONTGOMERY
MONTHLY OPERATIONS SUMMARY
GROUND WATER PERMIT PUMPAGE
June 2025

LONE STAR GROUNDWATER CONSERVATION DISTRICT
PERMIT #OP-04072101D/HUP040 & 13012801B AWS - 01/01/25 - 12/31/25

"Gulf Coast Aquifer" - Jasper		Catahoula Aquifer	
Jan-25	6,094,300	6,240,000	
Feb-25	5,256,300	6,868,000	
Mar-25	7,347,100	8,224,000	
Apr-25	7,680,000	8,304,000	
May-25	9,852,600	8,637,000	
Jun-25	8,811,700	8,053,000	
Jul-25			
Aug-25			
Sep-25			
Oct-25			
Nov-25			
Dec-25			
Total Pumpage	45,042,000	23.57%	46,326,000
			24.22%

2025 Permitted Withdrawal: 191,081,000 191,250,000

Permit Summary Gulf Coast Aquifer

Historical Use Permit Amount:	92,930,000
2025 Permitted Withdrawal:	92,930,000

Alternative Water Summary

City of Montgomery - Alternate Water Source Permit:	90,000,000
Total 2025 GRP AWS Permitted Withdrawal:	90,000,000