## FINAL INSPECTION

Project: Redbird Meadows/Briarley Project Number: 00574-123-00 Engineer: LIA Engineering, Inc.

Inspection Date & Time: Tuesday, May 20, 2025 @ 1:00 PM

Punchlist Details section 2	Substantial Completion Inspection	One-Year Warranty
Driveway connections at Basset Hound Dr to be built per approved plans		
Seal cracks on pavement (typical throughout development)	Completed	
Rout & seal cracks (typ) Basset Hound Dr STA 17+60, STA 19+00, STA 24+50,	Completed	
Rout & seal cracks (typ) Catahoula Ct STA 1+40,	Completed	
Remove formwork @ Catahoula Ct STA 3+00	Completed	
Remove and replace curb @ Catahoula Ct cul de sac	Completed	
Grout and seal cracks on manhole @ Basset Hound Drive 15+00,		
Grout and seal cracks on manhole @ Catahoula Ct cul de sac		
Paint fire hydrants per City of Montgomery Detail	Completed	
Curb cut and paint @ all sanitary (green) and water (blue) leads	Completed	
Paint water valve box lids blue	Completed	
Engineer to provide As-builts drawings in both PDF and DWG formats per Sec.78-130 of City of Montgomery Code of Ordinances.	Completed	
Engineer to provide bond per Sec.78-131 of the city of Montgomery code of Ordinances	Completed	
Provide waterline hydrostatic test reports	Completed	
Flood streets to check for standing water/birdbaths. Check streets at 2 hrs, 24 hrs, 48 hrs. If birdbaths are	Completed	
Jumbo meter boxes to be installed at all double service locations to allow for city to install meters		
Lift station to be fully operational prior to acceptance into 1 year warranty period		
, , , , , , , , , , , , , , , , , , , ,		
	Regrade existing roadside ditch to original condition or better to ensure proper drainage along Old Plantersville Rd  Driveway connections at Basset Hound Dr to be built per approved plans  Seal cracks on pavement (typical throughout development)  Rout & seal cracks (typ) Basset Hound Dr STA 17+60, STA 19+00, STA 24+50,  Rout & seal cracks (typ) Catahoula Ct STA 1+40,  Remove formwork @ Catahoula Ct STA 3+00  Remove and replace curb @ Catahoula Ct cul de sac  Grout and seal cracks on manhole @ Basset Hound Drive 15+00,  Grout and seal cracks on manhole @ Catahoula Ct cul de sac  Paint fire hydrants per City of Montgomery Detail  Curb cut and paint @ all sanitary (green) and water (blue) leads  Paint water valve box lids blue  Engineer to provide As-builts drawings in both PDF and DWG formats per Sec.78-130 of City of Montgomery Code of Ordinances.  Engineer to provide bond per Sec.78-131 of the city of Montgomery code of Ordinances  Provide waterline hydrostatic test reports  Flood streets to check for standing water/birdbaths. Check streets at 2 hrs, 24 hrs, 48 hrs. If birdbaths are  Jumbo meter boxes to be installed at all double service locations to allow for city to install meters	Regrade existing roadside ditch to original condition or better to ensure proper drainage along Old Plantersville Rd Driveway connections at Basset Hound Dr to be built per approved plans  Seal cracks on pavement (typical throughout development)  Completed  Rout & seal cracks (typ) Basset Hound Dr STA 17+60, STA 19+00, STA 24+50,  Completed  Rout & seal cracks (typ) Catahoula Ct STA 1+40,  Remove formwork @ Catahoula Ct STA 3+00  Completed  Remove and replace curb @ Catahoula Ct cul de sac  Grout and seal cracks on manhole @ Basset Hound Drive 15+00,  Grout and seal cracks on manhole @ Catahoula Ct cul de sac  Paint fire hydrants per City of Montgomery Detail  Curb cut and paint @ all sanitary (green) and water (blue) leads  Completed  Engineer to provide As-builts drawings in both PDF and DWG formats per Sec. 78-130 of City of Montgomery Code of Ordinances.  Engineer to provide bond per Sec. 78-131 of the city of Montgomery code of Ordinances  Flood streets to check for standing water/birdbaths. Check streets at 2 hrs, 24 hrs, 48 hrs. If birdbaths are Jumbo meter boxes to be installed at all double service locations to allow for city to install meters  Lift station to be fully operational prior to acceptance into 1 year warranty period  Street lights to be installed and inspected by end of 1 yr warranty, prior to City acceptance of

23	Sidewalks shall be constructed by the developer prior to city acceptance of the infrastructure yr warranty period.	at end of 1			
24	Tree planting to be inspected at end of 1 year warranty, prior to city acceptance of infrastruct	ıre			
25	tablish vegetation within the city ROW, prior to acceptance into 1 year warranty period				
	Z:\00574 (City of Montgomery)\123 RedBird Meadows (Dev. No. 2006)\Inspection\Final Inspection\Substantial Completion Inspection.xlsx				
	4526 Research Forest Dr. Suite 360   The Woodlands, TX 77381   71	3.789.1900	wga-llc.co	om	