

## **Barge final comments**

For 739 S Main St., we had the following:

- On Drawing C-9, there is a note referencing the proposed doghouse manhole but it is not shown on the drawing.
- It is assumed the intent is for the property owner to own and maintain the line on the property upstream of the doghouse manhole; please confirm. Per the City's wastewater regulations, a cleanout will be needed at least every 100 feet along the line upstream of the doghouse manhole.
- On Drawing C-15, the information on the pipe profile is difficult to read due to overlapping text. Clean-up text with pipe and slope information.
- On Drawing C-15, profile of the ground surface is incomplete for the sewer line profile.