

**§ 18-207 Table A - User Discharge Restrictions Wastewater  
Treatment Plant - Industrial Local Limits**

Pollutant	Daily Average* Maximum Concentration (mg/l)	Instantaneous Maximum Concentration (mg/l)
Copper	<b>0.36004</b>	N/A
Chromium	<b>0.92139</b>	N/A
Nickel	<b>0.73235</b>	N/A
Cadmium	<b>0.03089</b>	N/A
Lead	<b>0.11062</b>	N/A
Mercury	<b>0.00091</b>	N/A
Silver	<b>0.07249</b>	N/A
Zinc	<b>0.37001</b>	N/A
Cyanide	N/A	<b>0.03347</b>
Toluene	N/A	<b>0.92430</b>
Benzene	N/A	<b>0.04621</b>
1,1,1 Trichloroethane	N/A	<b>0.61620</b>
Ethylbenzene	N/A	<b>0.09859</b>
Carbon tetrachloride	N/A	<b>0.01070</b>
Chloroform	N/A	<b>0.55133</b>
Tetrachloroethylene	N/A	<b>0.12926</b>
Trichloroethylene	N/A	<b>0.23268</b>
1,2Trans Dichloroethylene	N/A	<b>0.01849</b>
Methylene chloride	N/A	<b>0.23700</b>
Phenols (total)	N/A	<b>1.12036</b>
Naphthalene	N/A	<b>0.03081</b>
Phthalates (total)	N/A	<b>0.41837</b>
DEHP	N/A	<b>0.03892</b>
BOD	N/A	<b>471.00**</b>
Suspended solids	N/A	<b>2,295.00**</b>

\* Based on twenty-four (24) hour flow proportional composite samples.

\*\*Based on twenty-four (24) hour flow proportional composite samples. In cases where wastewater streams contain sanitary wastewater, a combined waste stream formula will be used to develop the local limit for BOD and suspended solids and limits on these parameters shall be sampled as a daily average maximum concentration.

**§ 18-207 Table B - Plant Protection Criteria**

Parameter	Maximum Concentration (mg/l)	Maximum
	(24 Hour Flow) Proportional Composite Sample	Instantaneous Concentration (mg/l) Grab Sample
Copper	<b>0.1671</b>	N/A
Chromium	<b>0.3750</b>	N/A
Nickel	<b>0.2996</b>	N/A
Cadmium	<b>0.0125</b>	N/A
Lead	<b>0.0469</b>	N/A
Mercury	<b>0.0004</b>	N/A
Silver	<b>0.0294</b>	N/A
Zinc	<b>0.2734</b>	N/A
Cyanide	N/A	<b>0.0146</b>
Toluene	N/A	<b>0.3750</b>
Benzene	N/A	<b>0.0188</b>
1,1,1 Trichloroethane	N/A	<b>0.2500</b>
Ethylbenzene	N/A	<b>0.0400</b>
Carbon tetrachloride	N/A	<b>0.0043</b>
Chloroform	N/A	<b>0.2237</b>
Tetrachloroethylene	N/A	<b>0.0524</b>
Trichloroethylene	N/A	<b>0.0944</b>
1,2Trans	N/A	<b>0.0075</b>
Methylene chloride	N/A	<b>0.0962</b>
Phenols (total)	N/A	<b>0.4545</b>
Naphthalene	N/A	<b>0.0125</b>
Phthalates (total)	N/A	<b>0.1697</b>
DEHP	N/A	<b>0.0158</b>
BOD	N/A	<b>190.97</b>
Suspended solids	N/A	<b>931.16</b>