



## **MORGAN'S POINT RESORT**

### **Utilities Department**

*Our Home, Our People, Our Service.*

February 2023

#### **Water**

- We began an extensive and detailed line and valve locating process on Driftwood to plan future improvements in the area.
- We repaired a leaking flush valve on Maya.
- We repaired a water main break on Ebbtide without shutting down service.
- We completed 5-occupant change, 2-disconnect, 4-connect, 11-meter information, 1-meter change, and 0-miscellaneous service orders.
- We completed meter reads, 33 re-reads, and 27 lock offs for non-payment.
- We flushed all dead-end mains.
- We sampled chlorine daily, free ammonia and monochloramines weekly and after any adjustment, submitted six coliform samples and six nitrite / nitrate samples for the month. All with good results.

#### **Wastewater**

- We clean, service, monitor, and adjusted our treatment system according to schedule.
- We treated a daily average of 4,259 gallons.
- Our weekly average sample results were biochemical oxygen demand <2.0 mg/L, total suspended solids 2.5 mg/L, and our lowest dissolved oxygen level was 9.7 mg/L for the month.
- We completed and submitted our monthly Discharge Monitoring Reports as required by the E.P.A. and the T.C.E.Q.

#### **Swimming Pool**

- We maintained the pump and filter system and chemical feed system.