

| Datecompleted | Equipment | Location | Notes | Task | Taskdesc |
|---------------|---------------------|--------------------------|---|------------|---|
| 5/2/2025 | HIGH SERVICE PUMP 1 | 30359 WT Maple Plain, MN | greased, everything ok | Inspection | CHECK OIL LEVEL, ADD IF NEEDED. INSPECT UNIT FOR ABNORMAL WEAR AND NOISES. |
| 5/2/2025 | HIGH SERVICE PUMP 2 | 30359 WT Maple Plain, MN | greased, everything ok | Inspection | CHECK OIL LEVEL, ADD IF NEEDED. INSPECT UNIT FOR ABNORMAL WEAR AND NOISES. |
| 5/2/2025 | DEHUMIDIFIERS | 30359 WT Maple Plain, MN | all dehumidifiers are working properly | Inspection | CHECK AIR FILTER AND REPLACE IF NEEDED, MAKE SURE DRAIN TUBE IS DRAINING PROPERLY. |
| 5/2/2025 | MIXER NO 1 | 30359 WT Maple Plain, MN | greased, everything ok | Inspection | CHECK OIL LEVEL AND TOP OFF IF NEEDED. INSPECT UNIT FOR ABNORMAL WEAR OR NOISES. ADD ONE OR TWO SQUIRTS OF GREASE TO GREASE ZERTS. |
| 5/2/2025 | WELL 3 | 30359 WT Maple Plain, MN | greased, everything ok | Inspection | CHECK OIL LEVEL AND TOP OFF IF NEEDED. INSPECT FOR ABNORMAL WEAR AND NOISES. |
| 5/2/2025 | FIRE EXTINGUISHERS | 30359 WT Maple Plain, MN | all fire extinguishers are in working order | Inspection | CONFIRM NO OBSTRUCTIONS TO EXTINGUISHER. CONFIRM PIN IS IN PLACE, GAUGE READS FULL OR IN THE GREEN. REMOVE FROM MOUNT AND TURN UPSIDE DOWN SEVERAL TIMES. |
| 5/9/2025 | CATERPILLAR TRACTOR | 30359 WT Maple Plain, MN | exercised, everything ok | Monthly PM | Start vehicle and drive to exercise equipment. Check Fluids |
| 5/9/2025 | MACK DUMP TRUCK | 30359 WT Maple Plain, MN | exercised, everything ok | Monthly PM | Start vehicle and drive to exercise equipment. check fluids |
| 5/9/2025 | FORD F350 1 TON | 30359 WT Maple Plain, MN | exercised, everything ok | Inspection | Detailed examination of equipment for defects or abnormalities. |
| 5/9/2025 | F150 Truck | 30359 WT Maple Plain, MN | exercised, replaced battery, everything ok | Inspection | Detailed examination of equipment for defects or abnormalities. |
| 5/9/2025 | Kubota B3030 | 30359 WT Maple Plain, MN | exercised, everything ok | Inspection | Detailed examination of equipment for defects or abnormalities. |

| | | | | | |
|-----------|-------------------------------|--------------------------|--|---------------|--|
| 5/9/2025 | Kubota ZD326 | 30359 WT Maple Plain, MN | exercised, everything ok | Inspection | Detailed examination of equipment for defects or abnormalities. |
| 5/9/2025 | ToolCat Bobcat UW56 | 30359 WT Maple Plain, MN | exercised, everything ok | Inspection | Detailed examination of equipment for defects or abnormalities. |
| 5/13/2025 | Parks | 30359 WT Maple Plain, MN | all parks are currently looking good with grass restoration, stump grindings and mulching projects in progress | Inspection | Detailed examination of equipment for defects or abnormalities. |
| 5/13/2025 | Trails | 30359 WT Maple Plain, MN | all asphalt trails are currently looking good, the gravel trails at rainbow park could use a fresh layer of gravel when things dry out | Inspection | Detailed examination of equipment for defects or abnormalities. |
| 5/16/2025 | MAIN LIFT STATION | 30359 WW Maple Plain, MN | cleaned floats, everything ok | LS Monthly PM | <ol style="list-style-type: none"> 1. Test power fail and high level alarm and verify communication equipment will reach emergency contact for your project. 2. Inspect and clean floats. 3. If level indicator verify operating properly. 4. Inspect overall condition of lift station. |
| 5/27/2025 | Public works air Compressor 1 | 30359 WT Maple Plain, MN | everything ok | Inspection | Detailed examination of equipment for defects or abnormalities. |
| 5/27/2025 | Public works air Compressor 2 | 30359 WT Maple Plain, MN | everything ok | Inspection | Detailed examination of equipment for defects or abnormalities. |
| 5/28/2025 | Main Lift Station Generator | 30359 WW Maple Plain, MN | exercised weekly, everything ok | Inspection | CHECK OIL. DOCUMENT ON THIS WORK ORDER WHERE AND WHEN THIS EQUIPMENT WAS USED THIS MONTH. IF NOT USED NO DOCUMENTATION IS NEEDED. |

| | | | | | |
|-----------|--------------------------------|--------------------------|---------------------------------|-------------------|--|
| 5/28/2025 | Main Lift Station Generator | 30359 WW Maple Plain, MN | the oil was changed last month | Service Equipment | CHANGE OIL, CHECK FUEL FILTER AND REPACE IF NEEDED. CHECK AIR FILTER AND CLEAN OR REPLACE IF NEEDED. CHECK OVERALL CONDITION OFTHE EQUIPMENT AND REPAIR IF NEEDED. |
| 5/28/2025 | AIR COMPRESSOR | 30359 WT Maple Plain, MN | everything ok | Inspection | CHECK OIL LEVELS AND BELT CONDITION. INSPECT FOR OIL LEAKS OR EBNORMAL WEAR. DOCUMENT HOUR METERS. CONFIRM WATER DRAIN IS WORKING. |
| 5/28/2025 | EMERGENCY GENERATOR | 30359 WT Maple Plain, MN | exercised weekly, everything ok | Inspection | 1. CHECK ALL FLUIDS INCLUDING FUEL 2. DOCUMENT HOUR METER AND CONFIRM EXERCISING UNDER LOAD AT LEAST ONCE A WEEK. 3. INSPECT UNIT FOR UNUSUAL WEAR. 4. IF DURING COLD WEATHER CONFIRM HEATING BLOCK IS WORKING. |
| 5/28/2025 | Fire Station 2 AC Units | 30359 WT Maple Plain, MN | everything ok | Inspection | Detailed examination of equipment for defects or abnormalities. |
| 5/28/2025 | Fire Station 2 Infrared Heater | 30359 WT Maple Plain, MN | everything ok | Inspection | Detailed examination of equipment for defects or abnormalities. |