

Datecompleted	Equipment	Location	Notes	Task	Taskdesc
1/13/2026	HIGH SERVICE PUMP 1	30359 WT Maple Plain, MN	in good operating condition	Inspection	CHECK OIL LEVEL, ADD IF NEEDED. INSPECT UNIT FOR ABNORMAL WEAR AND NOISES.
1/13/2026	HIGH SERVICE PUMP 1	30359 WT Maple Plain, MN	Completed all tasks on work order.	Service Equipment	CHANGE OIL AND GREASE UNIT
1/13/2026	HIGH SERVICE PUMP 2	30359 WT Maple Plain, MN	Completed all tasks on work order.	Service Equipment	CHANGE OIL AND GREASE UNIT
1/13/2026	HIGH SERVICE PUMP 2	30359 WT Maple Plain, MN	in good condition	Inspection	CHECK OIL LEVEL, ADD IF NEEDED. INSPECT UNIT FOR ABNORMAL WEAR AND NOISES.
1/13/2026	AIR COMPRESSOR	30359 WT Maple Plain, MN	in good condition	Inspection	CHECK OIL LEVELS AND BELT CONDITION. INSPECT FOR OIL LEAKS OR EBNORMAL WEAR. DOCUMENT HOUR METERS. CONFIRM WATER DRAIN IS WORKING.
1/13/2026	AIR COMPRESSOR	30359 WT Maple Plain, MN	all tasks completed on workorder.	Service Equipment	CHANGE OIL AND AIR FILTER. DOCUMENT HOUR METERS.
1/13/2026	DEHUMIDIFIERS	30359 WT Maple Plain, MN	all in good condition	Inspection	CHECK AIR FILTER AND REPLACE IF NEEDED, MAKE SURE DRAIN TUBE IS DRAINING PROPERLY.
1/13/2026	MIXER NO 1	30359 WT Maple Plain, MN	in good condition	Inspection	CHECK OIL LEVEL AND TOP OFF IF NEEDED. INSPECT UNIT FOR ABNORMAL WEAR OR NOISES. ADD ONE OR TWO SQUIRTS OF GREASE TO GREASE ZERTS.
1/13/2026	WELL 3	30359 WT Maple Plain, MN	in good condition	Inspection	CHECK OIL LEVEL AND TOP OFF IF NEEDED. INSPECT FOR ABNORMAL WEAR AND NOISES.
1/13/2026	FIRE EXTINGUISHERS	30359 WT Maple Plain, MN	all tasks completed on work order.	Inspection	CONFIRM NO OBSTRUCTIONS TO EXTINGUISHER. CONFIRM PIN IS IN PLACE, GAUGE READS FULL OR IN THE GREEN. REMOVE FROM MOUNT AND TURN UPSIDE DOWN SEVERAL TIMES.

1/14/2026	EMERGENCY GENERATOR	30359 WT Maple Plain, MN	in good condition	Inspection	1. CHECK ALL FLUIDS INCLUDING FUEL 2. DOCUMENT HOUR METER AND CONFIRM EXERCISING UNDER LOAD AT LEAST ONCE A WEEK. 3. INSPECT UNIT FOR UNUSUAL WEAR. 4. IF DURING COLD WEATHER CONFIRM HEATING BLOCK IS WORKING.
1/14/2026	CHEMICAL PUMP TUBING	30359 WT Maple Plain, MN	all is good.	Inspection	INSPECT ALL TUBING USED TO PUMP CHEMICALS AND REPLACE IF NEEDED. USE TUBING RATED FOR THE CHEMICAL BEING PUMPED.
1/14/2026	Kubota ZD326	30359 WT Maple Plain, MN	in winter storage mode.	Service Equipment	Change oil and oil filter. Inspect and clean/replace air filter. Grease all zerts. Inspect tractor for defects.
1/14/2026	Kubota B3030	30359 WT Maple Plain, MN	unit had its annual maintenance last month. serviced by Iano equipment.	Service Equipment	Change oil and oil filter. Inspect and clean/replace air filter. Grease all zerts. Inspect tractor for defects.
1/14/2026	F150 Truck	30359 WT Maple Plain, MN	truck is in winter storage mode.	Service Equipment	Change oil and oil filter. Inspect and clean/replace air filter. Grease all zerts. Inspect tractor for defects.
1/14/2026	CATERPILLAR TRACTOR	30359 WT Maple Plain, MN	in good condition	Monthly PM	Start vehicle and drive to exercise equipment. Check Fluids
1/14/2026	MACK DUMP TRUCK	30359 WT Maple Plain, MN	in good condition	Monthly PM	Start vehicle and drive to exercise equipment. check fluids
1/14/2026	FORD F350 1 TON	30359 WT Maple Plain, MN	in good condition	Inspection	Detailed examination of equipment for defects or abnormalities.
1/14/2026	F150 Truck	30359 WT Maple Plain, MN	exercised, in winter storage mode.	Inspection	Detailed examination of equipment for defects or abnormalities.
1/14/2026	Kubota B3030	30359 WT Maple Plain, MN	in good condition	Inspection	Detailed examination of equipment for defects or abnormalities.
1/14/2026	Kubota ZD326	30359 WT Maple Plain, MN	exercised, in winter storage mode.	Inspection	Detailed examination of equipment for defects or abnormalities.
1/14/2026	ToolCat Bobcat UW56	30359 WT Maple Plain, MN	everything is in good operating condition.	Inspection	Detailed examination of equipment for defects or abnormalities.
1/14/2026	Parks	30359 WT Maple Plain, MN	Everything looks good and winter park is taking shape.	Inspection	Detailed examination of equipment for defects or abnormalities.
1/14/2026	Trails	30359 WT Maple Plain, MN	everything looks good.	Inspection	Detailed examination of equipment for defects or abnormalities.

1/14/2026	Public works air Compressor 1	30359 WT Maple Plain, MN	looks good in operating condition	Inspection	Detailed examination of equipment for defects or abnormalities.
1/14/2026	Public works air Compressor 2	30359 WT Maple Plain, MN	Compressor in good operating condition.	Inspection	Detailed examination of equipment for defects or abnormalities.
1/16/2026	MAIN LIFT STATION	30359 WW Maple Plain, MN	all tasks completed on work order.	LS Monthly PM	<ol style="list-style-type: none"> 1. Test power fail and high level alarm and verify communication equipment will reach emergency contact for your project. 2. Inspect and clean floats. 3. If level indicator verify operating properly. 4. Inspect overall condition of lift station.
1/16/2026	Main Lift Station Generator	30359 WW Maple Plain, MN	in good condition	Inspection	CHECK OIL. DOCUMENT ON THIS WORK ORDER WHERE AND WHEN THIS EQUIPMENT WAS USED THIS MONTH. IF NOT USED NO DOCUMENTATION IS NEEDED.
1/16/2026	Fire Station 2 AC Units	30359 WT Maple Plain, MN	Everything in good operating condition.	Inspection	Detailed examination of equipment for defects or abnormalities.
1/16/2026	Fire Station 2 Infrared Heater	30359 WT Maple Plain, MN	Everything in good operating condition.	Inspection	Detailed examination of equipment for defects or abnormalities.
1/19/2026	FORD F350 1 TON	30359 WT Maple Plain, MN	N/A	Service Equipment	Change oil and oil filter. Inspect and clean/replace air filter. Grease all zerts. Inspect tractor for defects.
1/21/2026	RECYCLE PUMP	30359 WT Maple Plain, MN	Quality Flow Systems pulled pump and performed annual inspection- everything ok	Inspection	PULL PUMP AND INSPECT PUMP. CHANGE OIL IF NEEDED.
1/21/2026	SLUDGE PUMP	30359 WT Maple Plain, MN	Quality Flow Systems pulled pump and performed annual inspection- everything ok	Inspection	PULL PUMP AND INSPECT PUMP. CHANGE OIL IF NEEDED.