

Datecompleted	Equipment	Location	Notes	Task	Taskdesc
6/17/2025	FIRE EXTINGUISHERS	30359 WT Maple Plain, MN	All fire extinguishers are in working order and have just recently been inspected.	Inspection	CONFIRM NO OBSTRUCTIONS TO EXTINGUISHER. CONFIRM PIN IS IN PLACE, GAUGE READS FULL OR IN THE GREEN. REMOVE FROM MOUNT AND TURN UPSIDE DOWN SEVERAL TIMES.
6/17/2025	Parks	30359 WT Maple Plain, MN	Parks are looking good, the women's east stall in VMP is now working as it should. Bathrooms are stocked as needed.	Inspection	Detailed examination of equipment for defects or abnormalities.
6/17/2025	Trails	30359 WT Maple Plain, MN	All trails are looking good,	Inspection	Detailed examination of equipment for defects or abnormalities.
6/17/2025	Public works air Compressor 1	30359 WT Maple Plain, MN	Everything looks good and operational.	Inspection	Detailed examination of equipment for defects or abnormalities.
6/17/2025	Public works air Compressor 2	30359 WT Maple Plain, MN	I'm assuming this is the second compressor that is not operational being it's not wired to power. it is plumbed into the main line, so the tank does serve as an air holding vessel, but it is not operable by its own compressor.	Inspection	Detailed examination of equipment for defects or abnormalities.
6/20/2025	DEHUMIDIFIERS	30359 WT Maple Plain, MN	Dehumidifiers are working properly.	Inspection	CHECK AIR FILTER AND REPLACE IF NEEDED, MAKE SURE DRAIN TUBE IS DRAINING PROPERLY.
6/20/2025	CATERPILLAR TRACTOR	30359 WT Maple Plain, MN	exercised and checked fluids.	Monthly PM	Start vehicle and drive to exercise equipment. Check Fluids
6/20/2025	MACK DUMP TRUCK	30359 WT Maple Plain, MN	Exercised and is in working order.	Monthly PM	Start vehicle and drive to exercise equipment. check fluids
6/20/2025	FORD F350 1 TON	30359 WT Maple Plain, MN	Exercised and in working order.	Inspection	Detailed examination of equipment for defects or abnormalities.
6/20/2025	F150 Truck	30359 WT Maple Plain, MN	Exercised, Brakes are signaling failure on dash. may need to take in and be looked at.	Inspection	Detailed examination of equipment for defects or abnormalities.
6/20/2025	Kubota B3030	30359 WT Maple Plain, MN	Everything is good working order.	Inspection	Detailed examination of equipment for defects or abnormalities.
6/20/2025	Kubota ZD326	30359 WT Maple Plain, MN	Exercised and is working order.	Inspection	Detailed examination of equipment for defects or abnormalities.
6/20/2025	ToolCat Bobcat UW56	30359 WT Maple Plain, MN	Everything is working properly.	Inspection	Detailed examination of equipment for defects or abnormalities.

6/20/2025	Fire Station 2 Infrared Heater	30359 WT Maple Plain, MN	Everything looks good, filters are fairly new.	Inspection	Detailed examination of equipment for defects or abnormalities.
6/23/2025	MAIN LIFT STATION	30359 WW Maple Plain, MN	Cleaned Floats,	LS Monthly PM	<ol style="list-style-type: none"> 1. Test power fail and high level alarm and verify communication equipment will reach emergency contact for your project. 2. Inspect and clean floats. 3. If level indicator verify operating properly. 4. Inspect overall condition of lift station.
6/23/2025	Main Lift Station Generator	30359 WW Maple Plain, MN	Exercised, Checked oil, and fluids. everything looks good.	Inspection	CHECK OIL. DOCUMENT ON THIS WORK ORDER WHERE AND WHEN THIS EQUIPMENT WAS USED THIS MONTH. IF NOT USED NO DOCUMENTATION IS NEEDED.
6/23/2025	CHLORINE BOOSTER PUMP NO 2	30359 WT Maple Plain, MN	Everything looks good.	Inspection	INSPECT PUMPS FOR ABNORMAL WEAR AND NOISES, CLEAN FAN VENT ON TOP OF MOTOR.
6/23/2025	AIR COMPRESSOR	30359 WT Maple Plain, MN	Everything looks good, checked oil level, and drain is working properly.	Inspection	CHECK OIL LEVELS AND BELT CONDITION. INSPECT FOR OIL LEAKS OR EBNORMAL WEAR. DOCUMENT HOUR METERS. CONFIRM WATER DRAIN IS WORKING.
6/23/2025	MIXER NO 1	30359 WT Maple Plain, MN	Everything looks good, checked oil level, and greased.	Inspection	CHECK OIL LEVEL AND TOP OFF IF NEEDED. INSPECT UNIT FOR ABNORMAL WEAR OR NOISES. ADD ONE OR TWO SQUIRTS OF GREASE TO GREASE ZERTS.
6/24/2025	HIGH SERVICE PUMP 1	30359 WT Maple Plain, MN	Greased and checked oil. everything in good shape.	Inspection	CHECK OIL LEVEL, ADD IF NEEDED. INSPECT UNIT FOR ABNORMAL WEAR AND NOISES.
6/24/2025	HIGH SERVICE PUMP 2	30359 WT Maple Plain, MN	Greased, checked oil, everything is good.	Inspection	CHECK OIL LEVEL, ADD IF NEEDED. INSPECT UNIT FOR ABNORMAL WEAR AND NOISES.
6/24/2025	WELL 3	30359 WT Maple Plain, MN	Greased, everything looks good.	Inspection	CHECK OIL LEVEL AND TOP OFF IF NEEDED. INSPECT FOR ABNORMAL WEAR AND NOISES.
6/24/2025	EMERGENCY GENERATOR	30359 WT Maple Plain, MN	Exercised weekly, everything ok. all fluids checked.	Inspection	<ol style="list-style-type: none"> 1. CHECK ALL FLUIDS INCLUDING FUEL 2. DOCUMENT HOUR METER AND CONFIRM EXERCISING UNDER LOAD AT LEAST ONCE A WEEK. 3. INSPECT UNIT FOR UNUSUAL WEAR. 4. IF DURING COLD WEATHER CONFIRM HEATING BLOCK IS WORKING.

6/24/2025	Fire Station 2 AC Units	30359 WT Maple Plain, MN	ac system is not operating properly repair company should be here with in a day to fix issue.	Inspection	Detailed examination of equipment for defects or abnormalities.
-----------	-------------------------	--------------------------	---	------------	--