

Datecompleted	Equipment	Location	Notes	Task	Taskdesc
12/12/2025	HIGH SERVICE PUMP 1	30359 WT Maple Plain, MN	Everything in good condition	Inspection	CHECK OIL LEVEL, ADD IF NEEDED. INSPECT UNIT FOR ABNORMAL WEAR AND NOISES.
12/12/2025	HIGH SERVICE PUMP 2	30359 WT Maple Plain, MN	Everything in good condition.	Inspection	CHECK OIL LEVEL, ADD IF NEEDED. INSPECT UNIT FOR ABNORMAL WEAR AND NOISES.
12/12/2025	CHLORINE BOOSTER PUMP NO 2	30359 WT Maple Plain, MN	Everything in good condition	Inspection	INSPECT PUMPS FOR ABNORMAL WEAR AND NOISES, CLEAN FAN VENT ON TOP OF MOTOR.
12/12/2025	AIR COMPRESSOR	30359 WT Maple Plain, MN	Everything in good condition.	Inspection	CHECK OIL LEVELS AND BELT CONDITION. INSPECT FOR OIL LEAKS OR EBNORMAL WEAR. DOCUMENT HOUR METERS. CONFIRM WATER DRAIN IS WORKING.
12/12/2025	DEHUMIDIFIERS	30359 WT Maple Plain, MN	all in good operating condition.	Inspection	CHECK AIR FILTER AND REPLACE IF NEEDED, MAKE SURE DRAIN TUBE IS DRAINING PROPERLY.
12/12/2025	MIXER NO 1	30359 WT Maple Plain, MN	everything in good operating condition.	Inspection	CHECK OIL LEVEL AND TOP OFF IF NEEDED. INSPECT UNIT FOR ABNORMAL WEAR OR NOISES. ADD ONE OR TWO SQUIRTS OF GREASE TO GREASE ZERTS.
12/12/2025	WELL 3	30359 WT Maple Plain, MN	Everything in good operating condition.	Inspection	CHECK OIL LEVEL AND TOP OFF IF NEEDED. INSPECT FOR ABNORMAL WEAR AND NOISES.
12/12/2025	EMERGENCY GENERATOR	30359 WT Maple Plain, MN	in good condition	Inspection	1. CHECK ALL FLUIDS INCLUDING FUEL 2. DOCUMENT HOUR METER AND CONFIRM EXERCISING UNDER LOAD AT LEAST ONCE A WEEK. 3. INSPECT UNIT FOR UNUSUAL WEAR. 4. IF DURING COLD WEATHER CONFIRM HEATING BLOCK IS WORKING.
12/12/2025	FIRE EXTINGUISHERS	30359 WT Maple Plain, MN	All in good condition	Inspection	CONFIRM NO OBSTRUCTIONS TO EXTINGUISHER. CONFIRM PIN IS IN PLACE, GAUGE READS FULL OR IN THE GREEN. REMOVE FROM MOUNT AND TURN UPSIDE DOWN SEVERAL TIMES.

12/12/2025	CATERPILLAR TRACTOR	30359 WT Maple Plain, MN	Exercised and in operational condition.	Monthly PM	Start vehicle and drive to exercise equipment. Check Fluids
12/12/2025	MACK DUMP TRUCK	30359 WT Maple Plain, MN	Everything in good operational condition and is set up for winter snow removal.	Monthly PM	Start vehicle and drive to exercise equipment. check fluids
12/12/2025	FORD F350 1 TON	30359 WT Maple Plain, MN	Everything looks good and in operating condition.	Inspection	Detailed examination of equipment for defects or abnormalities.
12/12/2025	F150 Truck	30359 WT Maple Plain, MN	New battery installed, in winter storage mode.	Inspection	Detailed examination of equipment for defects or abnormalities.
12/12/2025	Kubota B3030	30359 WT Maple Plain, MN	Everything in good condition, and operational.	Inspection	Detailed examination of equipment for defects or abnormalities.
12/12/2025	Kubota ZD326	30359 WT Maple Plain, MN	exercised but in winter storage mode.	Inspection	Detailed examination of equipment for defects or abnormalities.
12/12/2025	ToolCat Bobcat UW56	30359 WT Maple Plain, MN	Everything looks good, and operational. topped all fluids and exercised	Inspection	Detailed examination of equipment for defects or abnormalities.
12/12/2025	Fire Station 2 AC Units	30359 WT Maple Plain, MN	Everything is operational	Inspection	Detailed examination of equipment for defects or abnormalities.
12/12/2025	Fire Station 2 Infrared Heater	30359 WT Maple Plain, MN	Everything in good operating condition.	Inspection	Detailed examination of equipment for defects or abnormalities.
12/12/2025	Parks	30359 WT Maple Plain, MN	Everything looks good and winter park is taking shape.	Inspection	Detailed examination of equipment for defects or abnormalities.
12/12/2025	Trails	30359 WT Maple Plain, MN	everything looks good.	Inspection	Detailed examination of equipment for defects or abnormalities.
12/12/2025	Public works air Compressor 1	30359 WT Maple Plain, MN	looks good and in operational.	Inspection	Detailed examination of equipment for defects or abnormalities.
12/12/2025	Public works air Compressor 2	30359 WT Maple Plain, MN	Compressor in good operating condition. Compressor in good operating condition.	Inspection	Detailed examination of equipment for defects or abnormalities.
12/18/2025	CATERPILLAR TRACTOR	30359 WT Maple Plain, MN	City admin suggested to not perform due to low activity.	Service Equipment	Change oil and oil filter. Inspect and clean/replace air filter. Grease all zerts. Inspect tractor for defects.

12/18/2025	ToolCat Bobcat UW56	30359 WT Maple Plain, MN	Service performed by lano on site.	Schedule Appointment	Schedule service with Lano.
12/18/2025	MACK DUMP TRUCK	30359 WT Maple Plain, MN	City admin suggested to not perform due to low activity.	Service Equipment	Change oil and oil filter. Inspect and clean/replace air filter. Grease all zerts. Inspect tractor for defects.
12/18/2025	MACK DUMP TRUCK	30359 WT Maple Plain, MN	City admin suggested to not perform due to low activity.	Schedule Appointment	Schedule 2 year service with Lano.
12/19/2025	MAIN LIFT STATION	30359 WW Maple Plain, MN	All task complete on work order.	LS Monthly PM	<ol style="list-style-type: none"> <li>1. Test power fail and high level alarm and verify communication equipment will reach emergency contact for your project.</li> <li>2. Inspect and clean floats.</li> <li>3. If level indicator verify operating properly.</li> <li>4. Inspect overall condition of lift station.</li> </ol>
12/19/2025	MAIN LIFT STATION	30359 WW Maple Plain, MN	<p>All task complete on work order.</p> <p>Pump #1 L1- 50.8, L2-52.8, L3-50.1</p> <p>Pump #2 L1-54.5, L2-54.6, L3-53.8</p>	LS Quarterly PM	TAKE AMP READING FROM EACH PUMP. ARC FLASH PPE REQUIRED
12/19/2025	Main Lift Station Generator	30359 WW Maple Plain, MN	everything looks good.	Inspection	CHECK OIL. DOCUMENT ON THIS WORK ORDER WHERE AND WHEN THIS EQUIPMENT WAS USED THIS MONTH. IF NOT USED NO DOCUMENTATION IS NEEDED.
12/19/2025	MIXER NO 1	30359 WT Maple Plain, MN	Completed all tasks on work order.	Service Equipment	CHANGE GEAR OIL USING ISO FRADE 150