

Datecompleted	Equipment	Location	Notes	Task	Taskdesc
11/6/2025	Parks	30359 WT Maple Plain, MN	Everything looks good and winterized.	Inspection	Detailed examination of equipment for defects or abnormalities.
11/6/2025	Trails	30359 WT Maple Plain, MN	Everything looks good.	Inspection	Detailed examination of equipment for defects or abnormalities.
11/10/2025	CATERPILLAR TRACTOR	30359 WT Maple Plain, MN	Exercised and everything looks good.	Monthly PM	Start vehicle and drive to exercise equipment. Check Fluids
11/10/2025	MACK DUMP TRUCK	30359 WT Maple Plain, MN	Exercised and everything looks good.	Monthly PM	Start vehicle and drive to exercise equipment. check fluids
11/10/2025	FORD F350 1 TON	30359 WT Maple Plain, MN	Everything looks good and exercised.	Inspection	Detailed examination of equipment for defects or abnormalities.
11/10/2025	F150 Truck	30359 WT Maple Plain, MN	Replaced the battery, exercised, and looks good now.	Inspection	Detailed examination of equipment for defects or abnormalities.
11/10/2025	Kubota B3030	30359 WT Maple Plain, MN	Everything looks good and exercised.	Inspection	Detailed examination of equipment for defects or abnormalities.
11/10/2025	Kubota ZD326	30359 WT Maple Plain, MN	Everything looks good and exercised.	Inspection	Detailed examination of equipment for defects or abnormalities.
11/10/2025	ToolCat Bobcat UW56	30359 WT Maple Plain, MN	Everything looks good, and operational. topped all fluids and exercised.	Inspection	Detailed examination of equipment for defects or abnormalities.
11/11/2025	MAIN LIFT STATION	30359 WW Maple Plain, MN	All work order tasks are completed and working properly.	LS Monthly PM	1. Test power fail and high level alarm and verify communication equipment will reach emergency contact for your project. 2. Inspect and clean floats. 3. If level indicator verify operating properly. 4. Inspect overall condition of lift station.
11/11/2025	Main Lift Station Generator	30359 WW Maple Plain, MN	Everything is working properly.	Inspection	CHECK OIL. DOCUMENT ON THIS WORK ORDER WHERE AND WHEN THIS EQUIPMENT WAS USED THIS MONTH. IF NOT USED NO DOCUMENTATION IS NEEDED.
11/11/2025	HIGH SERVICE PUMP 1	30359 WT Maple Plain, MN	Checked fluids, everything is good.	Inspection	CHECK OIL LEVEL, ADD IF NEEDED. INSPECT UNIT FOR ABNORMAL WEAR AND NOISES.

11/11/2025	HIGH SERVICE PUMP 2	30359 WT Maple Plain, MN	Checked fluids and everything is good.	Inspection	CHECK OIL LEVEL, ADD IF NEEDED. INSPECT UNIT FOR ABNORMAL WEAR AND NOISES.
11/11/2025	AIR COMPRESSOR	30359 WT Maple Plain, MN	Checked fluid level, belts, and everything is good.	Inspection	CHECK OIL LEVELS AND BELT CONDITION. INSPECT FOR OIL LEAKS OR EBNORMAL WEAR. DOCUMENT HOUR METERS. CONFIRM WATER DRAIN IS WORKING.
11/11/2025	DEHUMIDIFIERS	30359 WT Maple Plain, MN	Everything looks good.	Inspection	CHECK AIR FILTER AND REPLACE IF NEEDED, MAKE SURE DRAIN TUBE IS DRAINING PROPERLY.
11/11/2025	MIXER NO 1	30359 WT Maple Plain, MN	Greased and checked oil level. Everything is good and operational.	Inspection	CHECK OIL LEVEL AND TOP OFF IF NEEDED. INSPECT UNIT FOR ABNORMAL WEAR OR NOISES. ADD ONE OR TWO SQUIRTS OF GREASE TO GREASE ZERTS.
11/11/2025	WELL 3	30359 WT Maple Plain, MN	Checked all fluids and greased. Working properly and well house is ready for winter. Well #3-hour meter reading- 27650.1	Inspection	CHECK OIL LEVEL AND TOP OFF IF NEEDED. INSPECT FOR ABNORMAL WEAR AND NOISES.
11/11/2025	EMERGENCY GENERATOR	30359 WT Maple Plain, MN	Everything is working properly.	Inspection	1. CHECK ALL FLUIDS INCLUDING FUEL 2. DOCUMENT HOUR METER AND CONFIRM EXERCISING UNDER LOAD AT LEAST ONCE A WEEK. 3. INSPECT UNIT FOR UNUSUAL WEAR. 4. IF DURING COLD WEATHER CONFIRM HEATING BLOCK IS WORKING.
11/11/2025	FIRE EXTINGUISHERS	30359 WT Maple Plain, MN	All are good.	Inspection	CONFIRM NO OBSTRUCTIONS TO EXTINGUISHER. CONFIRM PIN IS IN PLACE, GAUGE READS FULL OR IN THE GREEN. REMOVE FROM MOUNT AND TURN UPSIDE DOWN SEVERAL TIMES.
11/11/2025	Fire Station 2 AC Units	30359 WT Maple Plain, MN	Everything is working properly.	Inspection	Detailed examination of equipment for defects or abnormalities.
11/11/2025	Fire Station 2 Infrared Heater	30359 WT Maple Plain, MN	Everything is working properly.	Inspection	Detailed examination of equipment for defects or abnormalities.
11/11/2025	Public works air Compressor 1	30359 WT Maple Plain, MN	Looks good and operational.	Inspection	Detailed examination of equipment for defects or abnormalities.

11/11/2025	Public works air Compressor 2	30359 WT Maple Plain, MN	All tasks completed on this work order.	Inspection	Detailed examination of equipment for defects or abnormalities.
11/13/2025	BACKWASH BLOWER	30359 WT Maple Plain, MN	Completed task on work order.	Service Equipment	CHANGE OIL AND CHECK CONDITION AND OPERATION OF VENTILATION FAN, CLEAN FAN AND VENTILATION LOUVERS OF ENCLOSURE.
11/13/2025	WELL 3	30359 WT Maple Plain, MN	Oil changed	Service Equipment	CHANGE THE OIL