

AGENDA STAFF REPORT

MEETING NAME: REGULAR BOARD MEETING(S)

MEETING DATE(S): MARCH 17 & 21, 2022

FROM: BRIAN MACY, ASSISTANT GENERAL MANAGER

FOR: ACTION X DIRECTION INFORMATION



AWARD THE CONTRACT AGREEMENT FOR EMERGENCY REPAIR OF 150 LINEAR FEET OF 8-INCH SEWER LINE AND FIVE SERVICE CONNECTIONS ON ACOMA AVENUE TO TRYCO GENERAL ENGINEERING, INC.

STAFF RECOMMENDATION

Authorize the General Manager to approve a contract agreement to complete the Emergency Repair of 150 Linear Feet of 8-inch sanitary sewer on Acoma Avenue in the amount of \$77,600.00 plus a 10% contingency for a total of \$85,360.00, to Tryco General Engineering, Inc. and authorize the General Manager to do all thing necessary to complete the project.

SUMMARY

On February 23, 2022, Mission Springs Water District identified approximately 150 linear feet of sewer line and five residential service connections that were damaged due to tree roots infiltrating the sewer line. Staff prepared an informal emergency bid proposal and solicited three contractors to provide quotes for the repair of the sewer.

ANALYSIS

Mission Springs Water District solicited quotes from three contractors. Below details their cost proposals:

| Contractor: | Cost Proposal: |
|--|-----------------------|
| Tryco General Engineering, Inc. (Desert Hot Springs) | \$77,600.00 |
| Tri-Star Contracting, Inc. (Desert Hot Springs) | \$109,163.00 |
| Jones Brothers Construction Co. (Coachella) | No proposal submitted |

Out of the three contractors Mission Springs Water District contacted, staff received two cost proposals, and determined that the lowest cost proposal submitted was from Tryco General Engineering Inc.

FISCAL IMPACT AND STRATEGIC PLAN IMPLEMENTATION

The cost for all work authorized under this contract was approved in the FY 2022 Wastewater Capital Improvement Budget

ATTACHMENTS

Exhibit A - Contract Agreement, Tryco General Engineering, Inc.

Exhibit B – Acoma Avenue Pipe Replacement Exhibit