

**EUSI, LLC Operational Support Services Relating  
To the  
Wastewater Treatment Facility and Collection System  
September 2025**

Mrs. Rainie Torrance,

Please find below a summary of our services provided associated with the operational support services for the wastewater treatment facilities for the month of September 2025.

- The daily average flow for the month of September 2025 was 0.494 MGD.
- Completed the August 2025 monthly monitoring report for the state.
- Conducted in-house process control testing for the SBRs.
- Sent out the weekly and monthly samples as required by the monitoring permit.
- Tested the plant lift station and plant alarm callouts.
- Administrative coordination with finance and the administrative staff at 3<sup>rd</sup> street is ongoing.
- Inspected facility perimeter fences and percolation ponds.
- Operations staff decanted the digester to limit the amount of sludge that needed to be sent to the drying beds for further processing and ultimate removal to the off-site landfill.
- Drained digester to drying beds 1, 3, 5, 7, 9, 11, 13, and 15.
- Picked up rebuilt pump from Bob's for the Jack Smith lift station. Staff returned the loaner pump to Ft. Mohave.
- Completed routine monthly inspection of the Kubota tractor, the 4" trash pump, and the jetter.
- Requested quotes from 3 vendors for a replacement motive pump so we have a comparison between new and rebuilding the existing pump.
- Preventive Maintenance Program is ongoing per operating hours of the various plant components.
- Completed the bar screen service and inspections throughout the month.
- Completed weekly inspection of the emergency generator prior to and during its weekly test runs.
- Ongoing communication with City staff regarding items associated with the overall wastewater system.

Supplemental repair services, exceptional event(s) during the month of September.

- September 26, 2025 operational staff was called out for a sewer back up at the 19<sup>th</sup> hole restrooms. Team determined to return the morning of September 27, 2025 to address the issue. (1.5 hrs no charge for this activity)
- September 27, 2025 operational staff and City staff coordinated efforts and unclogged the blockage. (3.5 hrs no charge for this activity)

Should you have any questions regarding the monthly activity please feel free to contact me at 602-300-7946.

Sincerely,



Kris Hendricks, EUSI, LLC; Managing Member