

Jessie

Staff Report

02/10/22

**WATER:**

1. The booster station roof is being repaired and next the ceiling will need to be repaired from the water damage.
2. Quite a few people have wanted us to check to see if their water was froze at the meter. It was not. We did however have on at the industrial park freeze at the meter. There has been added insulation put in the meter pit to resolve the issue.
3. We have been keeping well house plowed out and well logs done
4. Fire hydrants are also being plowed out with the storms

**SEWER:**

1. Sewer logs completed as normal
2. The illegal dumping has started happening again. Keeping the auger room cleaned up. We will need to replace the door from the corrosion to keep things from freezing in there. I've also been bouncing ideas off of people to help narrow down where it could be coming from.
3. I've contacted challenger; there are some slide gates that need repaired before we have to start the discharging process. Luckily we have some time yet.
4. Cleaned up the chlorine room and disinfection building to make sure everything is ready for discharge.
5. Our reuse permit is up for renewal; we had the pre application meeting and we are working to get that completed.

**EQUIPMENT/SHOP:**

1. With the break in the weather we went through and service all of the equipment. Checked fluids and greased everything.
2. For the most part Daniel and I drive our personal vehicles for small errands around town. The white pickup down here is on its last leg and the heater works sometimes. We drive the blue service truck when tools or parts are needed, but for the most part that pickup isn't a ton better to drive. We are looking into contacting J.I. Morgan to see if they will be parting with any of their vehicles.

**STREETS:**

1. There is still an ice layer on most of the roads. I will be watching them to keep up with the pot holes when the weather permits.