

Jessie

Staff Report

07/12/21

WATER:

1. Tom Perkins came and looked at the booster station roof. We will be discussing options to get it fixed enough to last through winter.
2. There have been a few complaints and concerns about people using too much water. I haven't found any leaks. I have been data logging their meters to show them when water is being used. The meter head at the heartland inn is too old to data log so I ordered a new one to replace that.

SEWER:

1. Sewer logs completed as normal.
2. Seepage testing was time consuming. Pond three does have a leak. We are scheduling a time for Stewart to come check it out and come up with a plan.
3. Finally got the weeds sprayed on the land app.
4. Land applying has gone well. We are about out of water so we will be harvesting soon.
5. I have been working on the chlorine analyzer, as the numbers aren't reading right so I've been doing it manually.
6. We have gone through quite a bit of chlorine with the hotter temperatures.
7. Also had all of the empty chlorine barrels shipped back.

EQUIPMENT/SHOP:

1. Routine maintenance and cleaning of the equipment and shop.

STREETS:

1. All of the roads were graded and dust abatement was applied. Everything went pretty smooth.
2. I have been working on the Peterson sidewalk. I can only dig until it gets so hot because I will tear up the asphalt. The second section is almost completed.

PARK/RESTROOMS:

1. We got the playground border put down. Other than a few adjustments left to do; it looks much better.