

Jessie
Public Works Staff Report
12/10/20

WATER:

1. Booster Station and Well logs completed as normal.
2. Replaced two dead meter heads.
3. With the colder weather, a few people have asked to have their water checked for leaks.
4. The check valve for the fire pump isn't closing all the way after it ran and has over filled the tank a couple times. Been keeping a close eye on that.
5. Had someone come and fix the problem with the Scada system on the computer. He went through it with me, so I know what to look for next time.
6. Spent some time in the office reading the books I got for water distribution.

SEWER:

1. Sewer logs completed as normal.
2. Received another wonderful mess from illegal dumping in the auger room.
3. Plowed around the lagoons for the first time.
4. Had two new blowers installed and finished the blower room maintenance.

EQUIPMENT/SHOP:

1. Had a hydraulic leak on the loader after the first plow. We resolved the problem but it did use a lot of oil.
2. The s10 pickup is now leaking antifreeze. Will be finding where its coming from and getting it fixed.
3. Turned off the water at the meat shop and made sure the heaters were working to keep everything from freezing.

STREETS:

1. The first plow went pretty smooth. A lot of dirt was dug up however because the roads weren't quite frozen.
2. Did the dirt work for the first section of the Peterson pathway.
3. Cleaned out the storm drains that weren't draining.

PARK/RESTROOMS:

1. Replaced the deadbolt locks on the bathroom doors. Hopefully that will keep people out.
2. Signs were made for the garbage cans at the restroom. However due to being sick I haven't been into city hall to get them.

ANIMAL CONTROL:

1. Found the dog that went missing from Meadow Creek in the sewer lagoon. We removed him per the owner's request and buried him.
2. I have been quarantining the past couple of weeks, so I haven't dealt with many animal complaints.