

New Meadows Water System
 Fire Hydrant Inventory
 Conducted July 15, 2016



Hydrant No.	Manufacturer	Year Manufactured	Age as of 2016	Outlet Number/Size				Functional Y/N	Cross Street East/West	Cross Street Noth/South	Replacement Priority	Notes
				No.	Size	No.	Size					
1	Waterous	2000	16	2	2.5"	1	5"	Y	Virginia	North Commercial		
2	Clow	1993	23	2	2.5"	1	5"	Y	Virginia	West of North Commercial		
3	Clow	1993	23	2	2.5"	1	5"	Y	Nora	North Commercial		
4	Clow	1993	23	2	2.5"	1	5"	Y	Colt	North Commercial		
5	Clow	1993	23	2	2.5"	1	5"	Y	Taylor	North Commercial		
6	Waterous	1979	37	2	2.5"	1	5"	Y	Mclain	North Commercial		
7	Waterous	1975	41	2	2.5"			Y	Mclain	North Miller	High	
8	Waterous	1974	42	2	2.5"			Y	Colt	North Miller	High	
9	Waterous	1975	41	2	2.5"			Y	Nora	North Miller	High	Needs to be painted
10	Mueller	2012	4	2	2.5"	1	5"	Y	Virginia	North Miller		Needs to be painted
11	Waterous	1975	41	2	2.5"			Y	Virginia	North Heigho	High	
12	Mueller	2012	4	2	2.5"	1	5"	Y	Nora	North Heigho		
13	Mueller	2014	2	2	2.5"	1	5"	Unknown	Colt	North Heigho		
14	Waterous	1975	41	2	2.5"			Y	Taylor	North Heigho	High	
15	Waterous	1974	42	2	2.5"			Y	Mclain	North Cunningham	High	
16	Mueller	2015	1	2	2.5"	1	5"	Y	Taylor	North Cunningham		
17	Waterous	1997	19	2	2.5"	1	5"	Y	Colt	North Cunningham		
18	Clow	1993	23	2	2.5"	1	5"	Y	Nora	North Cunningham		
19	Waterous	1997	19	2	2.5"	1	5"	Y	Virgina	North Cunningham		
20	Waterous	1997	19	2	2.5"	1	5"	Y	Virginia	West of Norris		
21	Waterous	1974	42	2	2.5"			Y	Nora	Norris	High	Needs to be painted
22	Waterous	1974	42	2	2.5"			Y	Colt	Norris	High	
23	Clow	1993	23	2	2.5"	1	5"	Y	Nora	East of Norris		Needs to be painted
24	Waterous	2006	10	2	2.5"	1	5"	Y	Virgina	Truesdale		Needs to be painted
25	Clow	1993	23	2	2.5"	1	5"	Y	Highway 55	East of Truesdale		
26	Waterous	1975	41	2	2.5"			Y	Kathrine	Norris	High	
27	Waterous	1994	22	2	2.5"	1	5"	Y	Larae	Norris (North Intersection)		
28	Mueller	2005	11	2	2.5"	1	5"	Y	Larae	North End of Larae		2 1/2" cap off needs flushed
29	Mueller	2005	11	2	2.5"	1	5"	Y	Larae	South End of Larae		Needs to be painted
30	Waterous	1994	22	2	2.5"	1	5"	Y	Larae	Norris (South Intersection)		
31	Waterous	1994	22	2	2.5"	1	5"	Y	Wiley	Norris		
32	Waterous	1994	22	2	2.5"	1	5"	Y	Wiley	Between Heigho/Norris		
33	2 1/2" Standpipe	unknown	unknown	2	2.5"			Unknown	South of Heigho	Wiley	High	Needs to be painted
34	Waterous	1975	41	2	2.5"			Y	Wiley	South Heigho	High	
35	Waterous	1974	42	2	2.5"			Y	Cedric	South Heigho	High	Needs to be painted
36	Waterous	1974	42	2	2.5"			Unknown	Benedict	South Heigho	High	Needs to be painted
37	Mueller	2012	4	2	2.5"	1	5"	Y	Kathrine	South Heigho		
38	Waterous	1975	41	2	2.5"			Y	Kathrine	South Cunningham	High	Needs to be painted
39	Clow	1993	23	2	2.5"	1	5"	Y	Between Virginia/Kathrine	South Cunningham		
40	Waterous	1974	42	2	2.5"			Y	Kathrine	South Miller	High	
41	Clow	1993	23	2	2.5"	1	5"	Y	Cedric	South Miller		
42	Waterous	1974	42	2	2.5"			Y	Benedict	South Miller	High	
43	Clow	1993	23	2	2.5"	1	5"	Y	Speer	South Miller		
44	Mueller	2005	11	2	2.5"	1	5"	Y	Wiley	South Miller		
45	Mueller	1986	30	2	2.5"	1	5"	Y	Speer	Morgan		
46	Mueller	1986	30	2	2.5"	1	5"	Y	West of Cedric	Morgan		
47	Mueller	2007	9	2	2.5"	1	5"	Y	Katherine	South Commercial		
48	Waterous	1990	26	2	2.5"	1	5"	Y	Benedict	South Commercial		
49	Mueller	1983	33	2	2.5"	1	5"	Y	West of Speer	South Commercial		

New Meadows Water System
 Fire Hydrant Inventory
 Conducted July 15, 2016

Age	Color
1-10	Green
11-20	Blue
21-30	Yellow
31-40	Orange
40+	Red

Hydrant No.	Manufacturer	Year Manufactured	Age as of 2016	Outlet Number/Size				Functional Y/N	Cross Street East/West	Cross Street Noth/South	Replacement Priority	Notes
				No.	Size	No.	Size					
50	Clow	1989	27	2	2.5"	1	5"	Y	Katherine	West of South of Commercial		Needs to be painted
51	Clow	1993	23	2	2.5"	1	5"	Y	Highway 95	600 ft West of Commercial		
52	Clow	1993	23	2	2.5"	1	5"	Y	Highway 95	900 ft West of Commercial		Missing 5 1/4" cap, Needs to be painted
53	Clow	1993	23	2	2.5"	1	5"	Y	Highway 95	1200 ft West of Commercial		Needs to be painted
54	Clow	2002	14	2	2.5"	1	5"	Y	Highway 95	1500 ft West of Commercial		
55	Clow	2003	13	2	2.5"	1	5"	Y	Taylor	700 ft West of Commercial		Needs to be painted
56	Waterous	1974	42	2	2.5"			Y	North of Highway 55	East of Norris	High	Needs to be painted
57	Waterous	2006	10	2	2.5"	1	5"	Y	North of Highway 55	East of Truesdale		Needs to be painted
58									North of McClain	Northwest of High School		
59									North of McClain	Northeast of High School		