

Jessie

Staff Report

04/11/2022

**WATER:**

1. The booster station roof and ceiling drywall have been repaired
2. The service line to the auger room broke and had to be dug up and repaired. This took a little longer than most jobs due to slow digging (a lot of unmarked underground wires) and breaking through the concrete floor to run a new water line.
3. There have been a few people call for leaks; luckily they have been on the customer side.
4. Because of snowplowing we've also replaced quite a few broken meter lids and collars

**SEWER:**

1. Sewer logs completed as normal
2. We have started discharging into the river. Everything seems to be running smoothly and testing has come back well so far.
3. Challenger came and fixed the slide gate in the chlorine chamber and I will be having them back to fix a second one once the weather warms up.
4. Working on a plan to fix the leaking lagoon with Kirk and our engineers
5. I have all of my application stuff ready to be sent, just waiting on checks. I also finished classes for the two tests I will be taking. I am feeling confident on passing.

**EQUIPMENT/SHOP:**

1. Brad Steiner came and helped/showed us how the state takes the wing off of their grader. Daniel and I should be able to put it on and take it off ourselves now.
2. With the nicer weather we are starting to wash the equipment between uses
3. Performing regular greasing

**STREETS:**

1. Potholes are never ending. I blade the worst roads in between storms. With the wet weather and still quite a few sink holes the roads aren't going to hold up.
2. There have been a few storm drains that have dealt us a fit, but we have gotten them cleaned out. Daniel also got the jetter running to help with the difficult ones.