



The City of **NORMAN**

225 N. Webster Ave. • P.O. Box 370
Norman, Oklahoma 73069 • 73070

UTILITIES ADMINISTRATION

Phone: 405-366-5443

Fax: 405-366-5447

April 24, 2025

Mr. Scott Sturtz, P.E., CFM
Floodplain Administrator
City of Norman

Re: No Rise Certification
Chardonnay Sewer Interceptor Realignment
Norman, OK

Dear Mr. Sturtz:

This project involves a short realignment of the Woodcrest Creek Sanitary Sewer interceptor line. The existing line has become exposed in the channel of a tributary creek located north of the Vineyards and east of Chardonnay subdivisions. The project will consist of rerouting a new sanitary sewer line outside of the channel of the tributary creek but still within the regulatory floodplain; removing the existing exposed line down to a depth of no more than two feet; capping the remaining line; and abandoning that line in place. The new line will be trenched and reburied with any disturbed areas being returned to original grade after installation is complete.

The channel flow line and banks will not be altered at this location. Any damage to the stream banks will be repaired by installation of rip rap at grade to prevent further erosion. Any material (soil and/or rip rap) placed in the channel will be to replace what has been washed away by erosion and scour or removed during removal of the existing line and is considered routine maintenance. There will not be any increase in the Base Flood Elevation on any adjacent property.

Please contact me at (405) 366-5377 if you have any questions or need further information.

Sincerely,

Kenneth J. Giannone, PE
Capital Projects Engineer
City of Norman Utilities Department

