



The City of **NORMAN**

225 N Webster Ave · P.O Box 370
Norman, Oklahoma · 73069 · 73070

UTILITIES ENGINEERING
Phone: 405-366-5443
Fax: 405-366-5447

February 6, 2026

Jason Murphy, CFM
Storm Water Program Manager
City of Norman

Re: No Rise Certification
Sewer Maintenance Program 18 – Buckhorn Drive Aerial Crossing Replacement
Norman, OK

Dear Mr. Murphy:


This project consists of replacing an existing 8-inch sanitary sewer aerial crossing over Brookhaven Creek near Buckhorn Drive as part of the City of Norman's Sewer Maintenance Program 18. The proposed work includes removal of the existing sewer pipe and casing and installation of a new 8-inch sanitary sewer utilizing the existing pier structures at the current alignment and slope. No expansion of the crossing footprint is proposed.

The project does not include modification of the creek channel, channel banks, or floodplain geometry. Construction activities will be limited to removal and replacement of the aerial sewer infrastructure using existing supports. Any minor disturbance to the stream banks resulting from construction access will be repaired and restored to pre-construction conditions upon completion of the work.

Based on the proposed improvements, there will be no increase in flood elevations within the regulatory floodway or on any adjacent properties as a result of the project. Accordingly, the proposed work meets the requirements for a no-rise certification under City of Norman floodplain regulations.

Please contact me at (405) 366-5426 if you have any questions or require additional information.

Sincerely,


Nathan Madenwald, PE
Utilities Engineer
City of Norman Utilities Department

