



The City of
NORMAN

225 N Webster Ave · P.O Box 370
Norman, Oklahoma · 73069 · 73070

UTILITIES ENGINEERING
Phone: 405-366-5443
Fax: 405-366-5447

February 6, 2026

Jason Murphy, CFM
Storm Water Program Manager
City of Norman

Re: No Rise Certification
Sewer Maintenance Program 18 – Bishop Creek Aerial Crossing Reroute
Norman, OK

Dear Mr. Murphy:

This project involves the rerouting of an existing sanitary sewer line away from an aging aerial crossing over Bishop Creek near E. Boyd Street. The proposed work includes installation of a new sanitary sewer alignment by open-cut methods, construction of a new manhole to facilitate the reroute, removal of the existing aerial crossing, and abandonment of the remaining portions of the existing sewer line in place. All disturbed areas will be restored to original grade following construction.

The proposed work will not alter the existing channel alignment, channel flow line, or floodplain conveyance. Temporary excavation and construction activities will be confined to the immediate work area and will be backfilled upon completion. Any material removed from the channel during removal of the existing aerial crossing is considered routine maintenance and will be replaced as necessary to restore pre-construction conditions. Stream banks disturbed during construction will be stabilized and restored to prevent erosion.

Based on the proposed scope of work, the project will not result in any increase in the Base Flood Elevation within the regulatory floodway or on any adjacent property. Therefore, this project complies with the City of Norman floodplain regulations and constitutes a no-rise condition.

Please contact me at (405) 366-5426 if you have any questions or require additional information.

Sincerely,

Nathan Madenwald, PE
Utilities Engineer
City of Norman Utilities Department

