



CITY OF NOVI CITY COUNCIL
JULY 27, 2026

SUBJECT: Approval to purchase a new replacement sewage pump from Kennedy Industries for the Liberty Park Pump Station, in the amount of \$32,675.

SUBMITTING DEPARTMENT: Department of Public Works, Engineering Division

KEY HIGHLIGHTS:

- The Liberty Park Pump Station is a sewage pump station with two pumps that are 21 years old.
- One pump has failed and is beyond the ability to repair it.

FINANCIAL IMPACT

	FY 2026/27
EXPENDITURE REQUIRED	\$ 32,675
BUDGET	
Water & Sewer Fund 592-536-00-976-261	\$ 32,675
APPROPRIATION REQUIRED	\$ 0
FUND BALANCE IMPACT	\$ 0

BACKGROUND INFORMATION:

Kennedy Industries, the City's pump maintenance contractor and pump supplier, completed an inspection at the Liberty Park Pump Station on one of the sewage pumps not performing properly. The attached report indicates the pump was significantly damaged and beyond repair (pumps in this station are 21 years). Kennedy Industries provided a quote for replacement of this pump for \$32,675.

Given the age of these pumps, being at the end of the typical life for sewage pumps, the second pump in this station may also need to be replaced. Once the first pump is replaced, the second pump will be inspected to verify its condition, and it will be replaced or repaired as appropriate.

Kennedy Industries is the sole distributor of Flygt pumps in the region. The price quoted includes \$31,575 for the replacement pump, plus \$1,100 for testing and verification it is operating properly.

The lead time to acquire the pump is approximately six weeks. A rental pump will be used while waiting for the new pump to arrive.

RECOMMENDED ACTION: Approval to purchase a new replacement sewage pump for the Liberty Park Pump Station, in the amount of \$32,675.