



May 28, 2025

TO: City Clerk - Cortney Hanson

FROM: Fire Marshal – Andrew Copeland

CITY COUNCIL

Mayor

Justin Fischer

Mayor Pro Tem

Laura Marie Casey

Dave Staudt

Brian Smith

Ericka Thomas

Matt Heintz

Priya Gurumurthy

City Manager

Victor Cardenas

Director of Public Safety

Chief of Police

Erick W. Zinser

Fire Chief

John B. Martin

Assistant Chief of Police

Scott R. Baetens

Assistant Fire Chief

Todd Seog

RE: Fireworks display for Barrels of Wine (C/O Eddie Hesano), 136 E. Walled Lake Dr. Walled Lake Michigan 48390.

Date/Time: July 19, 2025 @ approx.. 10pm.

The loading of the fireworks onto two barges and lighting off of the fireworks has been reviewed under the following:

- **2015 International Fire Code** (City adopted Fire Prevention Code)
- **P.A. 328 of 1931** as Amended, State of Michigan Fireworks Law
- **NFPA 1123**, Code for Fireworks Display

RECOMMENDED for APPROVAL.

1. Elizabeth Overfield is named the operator. A copy of her license is attached, and received a copy of the pyrotechnic operator's license. Robert Overfield is named the assistant.
2. On the application, the exact location of proposed display is off the shore of Eddies Barrels of Wine 136 E Walled Lake Dr. This is on Walled Lakes side of the lake.
3. The application states that the fireworks will be lite offshore from 1159 E. Lake Dr, Novi.
4. Absolutely no smoking or use of open flames in the safety zone.
5. All unauthorized personnel and the general public will be kept away during the fireworks being loaded onto the barge.
6. The storage method and location of the fireworks prior to the show shall be provided and shall be in compliance with NFPA 1123, at no time shall the storage of fireworks be left unattended.
7. The installation of the motor tubes and racks or other launch devices shall be inspected prior to the loading of any pyrotechnics device by a fire department representative.

Novi Public Safety Administration

45125 Ten Mile Road
Novi, Michigan 48375
248.348.7100
248.347.0590 fax

cityofnovi.org

This fireworks show is proposed to have 8.0" shell(s) as the largest shell to be shot off. This review and approval is based on this information and the submittal. **At no time shall a shell larger than 8.0" be used in this show.**

It shall be noted, that whenever, in the opinion of the Fire Chief or his designee, any hazardous condition exists, the fireworks loading shall be postponed until the condition is corrected. This is to include no rain prior to event.

Sincerely,

Andrew Copeland – Fire Marshal
City of Novi Fire Department