



Water & Sewer Collection Department Monthly Report
October 2020

Department News

#42 well project underway.

Monthly Activities

Pumped **17,904,000** gallons of water from the wells.
Completed **36** work orders from City Hall.
Performed **104** locates marking location of city water, sewer, storm sewers and electrical.
Collected **3** water meter readings from walking routes.
Delivered **35** red door tags giving the final notice of impending shut down of services.
Shut down **8** services for nonpayment.
Took **8** Bacteria tests of the water system – All passed.
Monthly safety check lists and departmental safety meeting completed.
Responded to **1** sewer backup call. **1** homeowner and **0** City sewer surcharge issues.
Daily water rounds consisting of chlorine residual testing, well and lift station checks.

Nonscheduled Work Performed

Dig and repair curb stop 10 Block 4th Street SE
Repair CL2 leaks 59 well
Dig and repaired main break 500 Block North Fredrick

Scheduled Work Performed

Landscape previous excavations
Bi annual hydrant flushing
Pour concrete sidewalks after curb stop repair
Remove and replace Limitourque at WPCP
Assist WPCP with diffuser replacement
Help with trees

Up Coming Projects

42 well completion