

Wastewater Department January 2021

Department News

UV system will need some repairs to operate based on flow. UV system will need to be replaced in the very near future.

Monthly Activities

Treated **21,520,000** gallons of waste water

Largest daily flow was **780,000** gallons.

Average daily flow was 690,000 gallons.

Applied **63,000** gallons of biosolids to the reed beds

Achieved a 97.7 % Biochemical Oxygen Demand removal

Achieved a 96.9 % Total Suspended Solids removal

Analyzed **471** wastewater samples in the cities state certified laboratory

35 samples submitted to Test America for testing.

Monthly safety check lists and departmental safety meeting completed.

Completed and submitted state Monthly Operating Report and the five industrial reports.

Daily collection of samples, performance of tests, calculate and record analysis results.

Nonscheduled Work Performed

Plowed snow for Street Department

Scheduled Work Performed

Decant water off storage tank.

Record temperatures and calibrate various lab equipment.

Perform preventative maintenance on all the various blowers, pumps, and process equipment. Attend City wide safety meeting at OFD.

Up Coming Projects

Getting Matt and Kieley certified for their respective license