

Date of Issuance: 10/30/2020
 Owner: City of Oelwein, Iowa
 Contractor: Maguire Iron, Inc.
 Engineer: FOX Engineering
 Project: West Water Tower Repainting

Effective Date: 11/9/2020
 Owner's Contract No.:
 Contractor's Project No.:
 Engineer's Project No.: 3406-19A
 Contract Name:

The Contract is modified as follows upon execution of this Change Order:

Item 1: Perform welding repairs to fill the open vent holes located around the upper perimeter of the elevated storage tank walls. With the new vent to be installed, these are no longer required and are recommended for removal.

Attachments: *Figure CO-3.1*

CHANGE IN CONTRACT PRICE	CHANGE IN CONTRACT TIMES
Original Contract Price: \$ <u>765,220.00</u>	Original Contract Times: Substantial Completion: <u>120 calendar days</u> Ready for Final Payment: <u>150 calendar days</u>
Increase from previously approved Change Orders No. <u>1</u> to No. <u>2</u> : \$ <u>56,500.00</u>	Increase from previously approved Change Orders No. <u>1</u> to No. <u>2</u> : Substantial Completion: <u>10 days</u> Ready for Final Payment: <u>10 days</u>
Contract Price prior to this Change Order: \$ <u>821,720.00</u>	Contract Times prior to this Change Order: Substantial Completion: <u>130 calendar days</u> Ready for Final Payment: <u>160 calendar days</u>
Increase of this Change Order: \$ <u>9,700.00</u>	Increase of this Change Order: Substantial Completion: <u>0 calendar days</u> Ready for Final Payment: <u>0 calendar days</u>
Contract Price incorporating this Change Order: \$ <u>831,420.00</u>	Contract Times with all approved Change Orders: Substantial Completion: <u>130 calendar days</u> Ready for Final Payment: <u>160 calendar days</u>

RECOMMENDED:
 By: Matthew Hawes
 Engineer (if required)
 Title: Project Engineer
 Date: 11-5-2020

ACCEPTED:
 By: _____
 Owner (Authorized)
 Title: _____
 Date: _____

ACCEPTED:
 By: [Signature]
 Contractor (Authorized)
 Title: Project Manager
 Date: 11-3-20

Approved by Funding Agency (if applicable)

By: _____ Date: _____
 Title: _____

**WEST WATER TOWER REPAINTING
CITY OF OELWEIN, IOWA**

FIGURE CO-3.1: Tower Vent Holes

