



Utility Department Monthly Report March 2021

Department News

Monthly Activities

Pumped **19,901,000** gallons of water from the wells.
Completed **61** work orders from City Hall.
Performed **53** locates marking location of city water, sewer, storm sewers and electrical.
Collected **0** water meter readings from walking routes.
Delivered **20** red door tags giving the final notice of impending shut down of services.
Shut down **7** services for nonpayment.
Took **8** Bacteria tests of the water system – All passed.
Dug **0** Graves.
0 Tree removals.
Monthly safety check lists and departmental safety meeting completed.
Responded to **4** sewer backup call. **3** homeowner and **1** City sewer surcharge issues.
Daily water rounds consisting of chlorine residual testing, well and lift station checks.

Nonscheduled Work Performed

Dig and repair main break 5th Ave SW.
Dig and repair main break 100 Block 9th Ave SE.
Dig and repair main break 5th Ave SE.
Repair Street Light 1st Street & Rock Island
Repair Collapsed manhole 1300 Block 1st Street SE.
Barricade several frost boils in various roads.
Dig and repair collapsed sewer 600 Block North Fredrick
Dig and repair curb stop 3rd Street SW.
Clean out grit chamber at WPCP and repair motor overload relay.
Repair broken valve boxes 5th Ave SW, 12th Ave SE,

Scheduled Work Performed

Equipment maintenance.
Meter changes
Repair Valve Box 4th Street & North Fredrick
Repair broken drainage tile lines in Reed Bed # 4.
Clean Decant basin at WPCP.
Clean Storm Sewer Catch Basins.
Fabricate portable 4 way stop signs.
Saw and Repair all water cuts



Up Coming Projects

- Prison Industries House sewer install.
- Repair roads damaged by frost boils.
- Grade and rock alleys.
- Landscape previous excavations.
- Install control wiring at WPCP.
- Street Sweeping.
- Sign replacement.