

RESOLUTION NO. _____-2024

RESOLUTION APPROVING HVAC SYSTEM HEAT PUMP REPAIR WITH WALDINGER CORPORATION IN THE AMOUNT OF \$12,288.89 FOR THE OELWEIN PUBLIC LIBRARY

WHEREAS, the Library has 4 compressors which heat and cool the building and one has failed; and

WHEREAS, one compressor had been replaced in the past, the second was replaced in November of 2024, the third has failed, and the fourth is the original; and,

WHEREAS, a TXV valve that regulates the refrigerant flow is faulty and will be replaced at a cost of \$2,000-\$2,500; and,

WHEREAS, the total cost is \$12,288.89 from Waldinger Corporation; and,

WHEREAS, franchise fees reserve will fund the project; and,

NOW, THEREFORE, BE IT RESOLVED by the City Council of Oelwein, Iowa approves a HVAC system heat pump repair with Waldinger Corporation in the amount of \$12,288.89 for the Oelwein Public Library.

Passed and approved this 9th day of December, 2024.

Brett DeVore, Mayor

It was moved by _____ and seconded by _____ that the Resolution as read be adopted, and upon roll call there were:

AYES NAYS ABSENT ABSTAIN

Ricchio
Weber
Lenz
Garrigus
Seeders
Payne

Attest:

Dylan Mulfinger, City Administrator

Recorded December 10, 2024