



Water & Sewer Collection Department Monthly Report
August 2020

Department News

#42 well project underway.

Monthly Activities

Pumped **19,866,000** gallons of water from the wells.

Completed **34** work orders from City Hall.

Performed **93** locates marking location of city water, sewer, storm sewers and electrical.

Collected **0** water meter readings from walking routes.

Delivered **35** red door tags giving the final notice of impending shut down of services.

Shut down **12** services for nonpayment.

Took **8** Bacteria tests of the water system – All passed.

Monthly safety check lists and departmental safety meeting completed.

Responded to **1** sewer backup call.

Daily water rounds consisting of chlorine residual testing, well and lift station checks.

Nonscheduled Work Performed

Dig and repair curb box and stem 100 Block 3rd Ave SE

Repair chlorine leaks 80 well

Repair chlorine leaks 42 well

Scheduled Work Performed

Assist with several concrete road repairs

Assist with several storm sewer repairs

Repair cement driveways damaged from curb stop repairs

Up Coming Projects