



Water & Sewer Collection Department Monthly Report  
February 2020

### Department News

#42 well project underway.

### Monthly Activities

Pumped **17,783,000** gallons of water from the wells.

Completed **40** work orders from City Hall.

Performed **23** locates marking location of city water, sewer, storm sewers and electrical.

Collected **6** water meter readings from walking routes.

Delivered **17** red door tags giving the final notice of impending shut down of services.

Shut down **2** services for nonpayment.

Took **8** Bacteria tests of the water system – All passed.

Monthly safety check lists and departmental safety meeting completed.

Responded to **1** sewer backup call.

Daily water rounds consisting of chlorine residual testing, well and lift station checks.

### Nonscheduled Work Performed

Work on Reed Bed #2 /unplug fill pipe

Pick up scrap metal from FD

Dig and repair main break 10<sup>th</sup> Street SE

Dig and repair main break Hillside Drive

Dig and repair main break East Charles

Dig and repair main break 4<sup>th</sup> Ave SE

Dig and repair main break 3<sup>rd</sup> Street SE

### Scheduled Work Performed

Cleaned shop and vehicles.

Still installing water meters

Install floor drain and pipe for Street Department addition

80 Well start up

### Up Coming Projects

Clean and televise sewer in the NE for sewer study