



Water & Sewer Collection Department Monthly Report November 2020

Department News

#42 well project underway.

Monthly Activities

Pumped **16,563,000** gallons of water from the wells.
Completed **25** work orders from City Hall.
Performed **63** locates marking location of city water, sewer, storm sewers and electrical.
Collected **3** water meter readings from walking routes.
Delivered **44** red door tags giving the final notice of impending shut down of services.
Shut down **14** services for nonpayment.
Took **8** Bacteria tests of the water system – All passed.
Monthly safety check lists and departmental safety meeting completed.
Responded to **1** sewer backup call. **2** homeowner and **0** City sewer surcharge issues.
Daily water rounds consisting of chlorine residual testing, well and lift station checks.

Nonscheduled Work Performed

Dig and repair curb stop 300 Block 5th Ave SW
Dig and repair curb stop 300 5th Ave SE
Root saw 300 Block 8th Ave SW
Repair CL2 leaks 59 well
Dig and repaired main break 13th Ave NW
Dig and repair curb stop 3rd Street NW
Dig and repair main break 500 Block North Fredrick
Dig up plugged drainage tile 13th Ave NE

Scheduled Work Performed

Replace diffusers at WPCP
Landscape previous excavations
Clean up and seed stump grindings

Up Coming Projects

Bring West water tower back online