



Water & Sewer Collection Department Monthly Report
October 2019

Department News

#42 well project underway.

Monthly Activities

Pumped **17,032,000** gallons of water from the wells.
Completed **75** work orders from City Hall.
Performed **103** locates marking location of city water, sewer, storm sewers and electrical.
Collected **3** water meter readings from walking routes.
Delivered **25** red door tags giving the final notice of impending shut down of services.
Shut down **12** services for nonpayment.
Took **8** Bacteria tests of the water system – All passed.
Monthly safety check lists and departmental safety meeting completed.
Responded to **1** sewer backup call. **1** homeowner and **0** City sewer surcharge issues.
Daily water rounds consisting of chlorine residual testing, well and lift station checks.

Nonscheduled Work Performed

Bypass sewer on 5th Ave NE due to high flow
Dig and repair water main break 100 Block 9th Ave SE
Work on plant drain check valves
Check valves leading to the 42 well
Dig and repair curb stop 21 5th Ave SE
Dig and repair curb stop 310 1st Ave NW
Repair back shop heater exhaust pipe
Dig and repair curb box 615 1st Street NE
Dig and repair valve on 12th Ave SW
Dig and repair main break 4th Street and 5th Ave SE

Scheduled Work Performed

Start 42 well
Por concrete driveway that was removed to facilitate curb stop repair
Bi annual hydrant flushing

Up Coming Projects

42 well completion