

Monthly Operations Report for July - Town of Palmer Lake Water Department

Groundwater Treatment Plant: 7.49 acre-feet (2,442,000 gallons total), averaging 78,775 gallons per day.

Surface Water Plant: 9.68 acre-feet (3,155,000 gallons total), averaging 101,775 gallons per day.

Operational Activities:

Groundwater Treatment Plant: Media and underdrain replacement delayed due to needing correct brackets for underdrains.

High Zone Storage Tank: Coating project complete; waiting to install new isolation valve.

New SCADA remote access laptop on order from Timberline Electric.

New laptop received from Colorado Rural Water Association Apprenticeship Program.

Meter reading software has been upgraded.