



PO Box 264
Harrisburg | NC 28075
Phone 704.721.6449
Fax 704.721.6459
NC Firm License Number: C-1351

June 26, 2020

Mecklenburg County Code Enforcement

Project: The Building Center – Holtech Saw Upfit

Per the information provided to GAR Engineering concerning the Holtech Saw Upfit for The Building Center project located at 10202 Industrial Dr. in Pineville NC 28134, GAR Engineering, Inc. has found the following;

The Saw is to be installed under a 62' x 24' stand-alone structure which has a minimum separation of 10' from any other structure. Based on the dimensions provided which gives a total area of 1,488 square feet, a sprinkler system is not required in this area. This is based on 2018 North Carolina Fire Code 903.2.11.7 which requires an automatic sprinkler system to be provided in woodworking operations which exceed 2,500 square feet.

Please don't hesitate to reach out to GAR Engineering, Inc. if you have any questions or concerns.

Sincerely,

Gregory A. Riffe, P.E.
President

