



2323 Fourth Street, PO Box 483 Peru, IL 61354  
Phone: 815-224-1650 Toll Free: 800-659-4659  
www.testinc.com

March 3, 2022

**Client:** Village of Poplar Grove  
Attn: Don Sattler, Village President  
200 Hill Street  
P.O. Box 01  
Poplar Grove, IL 61065

**Plant Type:** Wastewater Treatment Plants: North: Class II Sequential batch reactors (SBR).  
South: Class I Sequential batch reactors (SBR).  
Water Treatment Plants: Well Supply with Chemical Addition in all 3 locations

For the water system you will find attached the daily inspection and monitoring reports for each of the water plants and the distribution system testing record. For the wastewater side we have included the monthly DMR for both wastewater plants.

Outlined below are the processes and actions taken during January 2023 in Poplar Grove to improve the facilities equipment beyond required and routine maintenance, testing, inspection and reporting. At times we will also list upcoming needed improvements that may need attention by the Village.

**Lift Stations:**

- Cleaned all lift station floats and transducers.
- Ran and tested portable generators under load.
- Sable came out and got a measurement to get a bad check valve replaced at the end of Waco lift station fixed.
- They came and inspected the lift station at Oak Lawn just to ensure it's working as well as it can.

**North WWTP:**

- All standard monthly checks/maintenance/cleaning and procedures were completed.
- All personnel have taken safety classes on electrical safety, lock out tag out, confined space and emergency action planning.
- Main lift station has been working as it should.
- We fixed an issue with a decanter on SBR #1. We need to look in to rethinking or changing the way those open. There has to be a better way than those actuators that we can't get and that are expensive when we do get them. Plus, they only last about 2-3 years.
- We had the restraints break off one of the decanters. We fixed it when flows were high because we could get out on the decanter.
- We serviced the screen. Upon servicing it, we found issues and the manufacturer has been out to diagnose. The repair will be covered under warranty.
- We have ordered some transducers to replace the bad ones in SBR3 and to replace the one on the shelf from Woodstock lift station last month.
- Decanted digesters.



2323 Fourth Street, PO Box 483 Peru, IL 61354

Phone: 815-224-1650 Toll Free: 800-659-4659

[www.testinc.com](http://www.testinc.com)

- Tested all emergency wash stations.

**South WWTP:**

- All standard monthly checks/maintenance/cleaning and procedures were completed.
- UV lights are pulled and ready to go back in. We were able to get by this year without replacing the bulbs, but will have to next winter. We have put this in the budget.
- We had a blower go bad on one of the floating mixers. Sable is getting us a price for a new one.
- Transferred sludge to drying beds.
- Decanted digesters.
- Found that the sludge transfer pumps in the old plant need to be rebuilt. I plan on discussing this with David to find the more cost efficient solution.
- We replaced some leaking air line connections.
- Cleaned sand filter room.
- Tested all emergency wash stations.
- Decanted digesters.

**Water System:**

- Cleaned well houses.
- Changed pump head and chemical line at well 4.
- Tested the big portable generator under load and had the block heater replaced.
- All required EPA testing has been done.

All operations and plant inspections have been performed by me or under my direct supervision. As always, if you have any questions concerning the above, please do not hesitate to contact me.

Submitted by,  
Total Environmental Service Technologies, Inc.


A handwritten signature in black ink, appearing to read "Ion Stear".

Ion Stear  
Certified Operator/Manager



Name:  
E-Mail:  
Date/Time:

Ion :Stear  
istear@estline.com  
2023-02-28 12:04 (Time Zone: -06:00)







Name: Elaine Bumgamer  
E-Mail: ebumgamer@testinc.com  
Date/Time: 2023-02-20 15:22 (Time Zone: -06:00)

*Report Last Signed By*

User: IONSTEAR  
Name: Ion Stear  
E-Mail: istear@testinc.com  
Date/Time: 2023-02-28 12:04 (Time Zone: -06:00)

**DMR Copy of Record**

**Permit:** IL0071447  
**Major:** Yes  
**Permitted Feature:** 001 External Outfall  
**Facility:** POPLAR GROVE SOUTH STP VILLAGE OF  
 12211 STATE ROUTE 76  
 POPLAR GROVE, IL 61065

**Permittee:** POPLAR GROVE, VILLAGE OF  
 200 S HILL ST  
 POPLAR GROVE, IL 61065  
**Discharge:** 001-S SEMI ANNUAL SAMPLING @ 001

**Report Dates & Status:** From 08/01/22 to 01/31/23  
**DMR Due Date:** 02/25/23  
**Status:** NetDMR Validated

**Monitoring Period:** From 08/01/22 to 01/31/23  
**DMR Due Date:** 02/25/23  
**Facility Location:** POPLAR GROVE SOUTH STP VILLAGE OF  
 12211 STATE ROUTE 76  
 POPLAR GROVE, IL 61065

**Considerations for Form Completion:**  
**BOW ID:** W0070150006  
**Principal Executive Officer:** Ion Stear  
**Telephone:** 815-224-1650

**First Name:** Ion  
**Last Name:** Stear  
**No Data Indicator (NDDI):** -  
**Certified Operator:**

Parameter Name	Monitoring Location	Season	# Param. NDDI	Sample Permit Req. Value (SD)	Quantity of Loading	Quality of Concentration	Value 1	Value 2	Value 3	Units	# of Ex. Frequency of Analyte	Sample Type
----------------	---------------------	--------	---------------	-------------------------------	---------------------	--------------------------	---------	---------	---------	-------	-------------------------------	-------------

00556	Oil & Grease	1 - Effluent Gross	0	-	Sample Permit Req. Value (SD)	<	0.005	28 - ug/L	Req Mon DAILY MX	28 - ug/L	0	GR - GRAB
00720	Cyanide, total [as CN]	1 - Effluent Gross	0	-	Sample Permit Req. Value (SD)	<	0.005	28 - ug/L	Req Mon DAILY MX	28 - ug/L	0	GR - GRAB
00722	Cyanide, free [amenable to chlorination]	1 - Effluent Gross	0	-	Sample Permit Req. Value (SD)	=	0.216	19 - mg/L	Req Mon DAILY MX	19 - mg/L	0	24 - COMP24
00951	Fluoride, total [as F]	1 - Effluent Gross	0	-	Sample Permit Req. Value (SD)	<	0.01	19 - mg/L	Req Mon DAILY MX	19 - mg/L	0	24 - COMP24
01002	Arsenic, total [as As]	1 - Effluent Gross	0	-	Sample Permit Req. Value (SD)	=	0.0319	19 - mg/L	Req Mon DAILY MX	19 - mg/L	0	24 - COMP24
01007	Barium, total [as Ba]	1 - Effluent Gross	0	-	Sample Permit Req. Value (SD)	<	0.001	19 - mg/L	Req Mon DAILY MX	19 - mg/L	0	24 - COMP24
01027	Cadmium, total [as Cd]	1 - Effluent Gross	0	-	Sample Permit Req. Value (SD)	<	0.005	19 - mg/L	Req Mon DAILY MX	19 - mg/L	0	24 - COMP24
01032	Chromium, hexavalent [as Cr]	1 - Effluent Gross	0	-	Sample Permit Req. Value (SD)	<	0.005	19 - mg/L	Req Mon DAILY MX	19 - mg/L	0	GR - GRAB
01034	Chromium, total [as Cr]	1 - Effluent Gross	0	-	Sample Permit Req. Value (SD)	<	0.01	19 - mg/L	Req Mon DAILY MX	19 - mg/L	0	24 - COMP24
01042	Copper, total [as Cu]	1 - Effluent Gross	0	-	Sample Permit Req. Value (SD)	<	0.005	19 - mg/L	Req Mon DAILY MX	19 - mg/L	0	24 - COMP24
01045	Iron, total [as Fe]	1 - Effluent Gross	0	-	Sample Permit Req. Value (SD)	=	0.0324	19 - mg/L	Req Mon DAILY MX	19 - mg/L	0	24 - COMP24
01048	Iron, dissolved [as Fe]	1 - Effluent Gross	0	-	Sample Permit Req. Value (SD)	<	0.1	19 - mg/L	Req Mon DAILY MX	19 - mg/L	0	24 - COMP24
01051	Lead, total [as Pb]	1 - Effluent Gross	0	-	Sample Permit Req. Value (SD)	<	0.01	19 - mg/L	Req Mon DAILY MX	19 - mg/L	0	24 - COMP24

Sample Permit# Req Value NOE											
01055	Manganese, total [as Mn]	1 - Effluent Gross	0	0.0174	19 - mg/L	09999 - See Permit	24 - COMP24	09999 - See Permit	24 - COMP24	09999 - See Permit	24 - COMP24
01067	Nickel, total [as Ni]	1 - Effluent Gross	0	0.005	19 - mg/L	09999 - See Permit	24 - COMP24	09999 - See Permit	24 - COMP24	09999 - See Permit	24 - COMP24
01077	Silver, total [as Ag]	1 - Effluent Gross	0	0.001	19 - mg/L	09999 - See Permit	24 - COMP24	09999 - See Permit	24 - COMP24	09999 - See Permit	24 - COMP24
01092	Zinc, total [as Zn]	1 - Effluent Gross	0	0.044	19 - mg/L	09999 - See Permit	24 - COMP24	09999 - See Permit	24 - COMP24	09999 - See Permit	24 - COMP24
01147	Selenium, total [as Se]	1 - Effluent Gross	0	0.005	19 - mg/L	09999 - See Permit	24 - COMP24	09999 - See Permit	24 - COMP24	09999 - See Permit	24 - COMP24
32730	Phenolics, total recoverable	1 - Effluent Gross	0	0.011	19 - mg/L	09999 - See Permit	GR - GRAB	09999 - See Permit	GR - GRAB	09999 - See Permit	GR - GRAB
71900	Mercury, total [as Hg]	1 - Effluent Gross	0	0.5	3M - mg/L	09999 - See Permit	GR - GRAB	09999 - See Permit	GR - GRAB	09999 - See Permit	GR - GRAB

**Submission Note**  
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**  
 No errors.

**Comments**

**Attachments**  
 No attachments.

**Report Last Saved By**  
 POPPLAR GROVE, VILLAGE OF

**User:**  
 ebungamer

**Name:**  
 Elaine Bungamer

**E-Mail:**  
 ebungamer@tesinc.com

**Date/Time:**  
 2023-02-17 10:13 (Time Zone: -06:00)

**Report Last Signed By**  
 IONSTEAR

**User:**  
 Ion Stear

**Name:**  
 istear@tesinc.com

**E-Mail:**  
 2023-02-28 12:04 (Time Zone: -06:00)

**DMR Copy of Record**

**Permit**  
 Permit #: IL0071447  
 Major: Yes  
 Facility: POPLAR GROVE SOUTH STP, VILLAGE OF  
 12211 STATE ROUTE 76  
 POPLAR GROVE, IL 61065

Permitted Features: INF Influent Structure  
 Discharge: INF-L INFLUENT MONITORING  
 Facility Location: POPLAR GROVE, VILLAGE OF  
 200 S HILL ST  
 POPLAR GROVE, IL 61065

Report Dates & Status: From 01/01/23 to 01/31/23  
 DMR Date: 02/25/23  
 Status: **Not DMR Validated**

Monitoring Period: From 01/01/23 to 01/31/23  
 Considerations for Form Completion: **NeIDMR Validated**

BOW ID: W0070150006  
 Principal Executive Officer: Ion Stear  
 Certified Operator: 815-224-1650

Last Name: Stear  
 Telephone: 815-224-1650

No Data Indicator (NODI):  
 Form NODI: --

Scale	Parameter Name	Monitoring Location	Season #	Param. NODI	Sample Permit Req.	Value 1	Qualifier 1	Value 2	Qualifier 2	Value 3	Qualifier 3	Quality or Concentration	Units	# of Ex.	Frequency of Analysis	Sample Type
	00310 BOD, 5-day, 20 deg. C	G - Raw Sewage Influent	0	--	Sample Permit Req. Value NODI			131.214				Req Mon MO AVG	19 - mg/L	0	03DOW - 3 Days Every Week	CP - COMPOS
	00530 Solids, total suspended	G - Raw Sewage Influent	0	--	Sample Permit Req. Value NODI			149.571				Req Mon MO AVG	19 - mg/L	0	03DOW - 3 Days Every Week	CP - COMPOS
	00665 Phosphorus, total (as P)	1 - Effluent Gross	0	--	Sample Permit Req. Value NODI			4.751		8.63		Req Mon MO AVG	19 - mg/L	0	03DOW - 3 Days Every Week	CP - COMPOS
	50050 Flow, in conduit or thru treatment plant	G - Raw Sewage Influent	0	--	Sample Permit Req. Value NODI			0.127		0.188		Req Mon DAILY MX	03 - MGD	0	9999 - Continuous	9999 - Continuous

**Submission Note**  
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**  
 No errors.

**Comments**  
 No attachments

**Attachments**  
 Report Last Saved By: POPLAR GROVE, VILLAGE OF

User: ebumgamer  
 Name: Elaine Bumgamer  
 E-Mail: ebumgamer@lestinc.com  
 Date/Time: 2023-02-20 15:23 (Time Zone: -06:00)

Report Last Signed By: IONSTEAR  
 Name: Ion Stear  
 E-Mail: lstear@lestinc.com  
 Date/Time: 2023-02-28 12:04 (Time Zone: -06:00)

**VILLAGE OF POPLAR GROVE - WEST**  
**FOR THE MONTH OF January 2023**  
**ILLINOIS ENVIRONMENTAL PROTECTION AGENCY**  
**DIVISION OF PUBLIC WATER SUPPLIES**

**IL0070350**  
**MONTHLY OPERATING REPORT**

Date	Time	Flow Meter		Hour Meter Well 4		Chlorine Feed		Free		Phosphate Feed		Flouride Feed		Operator Initials
		Reading	Pumpage	Reading	Hours	Scale	lbs Used	Scale	lbs Used	Scale	lbs Used	Scale	lbs Used	
31-Dec	08:00	360943	0	8069.55	0	152.00	2.0	0.88	46	4.00	397.80	1.70	JH	
1-Jan	08:00	361025	58	8071.45	0.69	150.00	0.0	1.25	42	2.00	396.10	1.10	JH	
2-Jan	08:00	361083	93	8072.14	2.26	150.00	1.0	1.02	40/100	4.00	395.00	1.80	KL	
3-Jan	08:00	361176	78	8074.4	2.07	149.00	0.0	0.90	96	2.00	393.20	1.20	KL	
4-Jan	08:00	361254	41	8076.47	1.21	149.00	1.0	0.40	94	2.00	392.00	0.80	DH	
5-Jan	08:00	361295	66	8077.68	1.45	148.00	1.0	0.68	92	2.00	391.20	0.90	KL	
6-Jan	08:00	361361	66	8079.13	1.4	147.00	0.0	1.01	90	4.00	390.30	1.00	KL	
7-Jan	08:00	361427	70	8080.53	1.76	147.00	1.0	0.82	86	2.00	389.30	1.20	KL	
8-Jan	08:00	361497	68	8082.29	1.56	146.00	0.0	0.76	84	2.00	388.10	1.40	KL	
9-Jan	08:00	361565	70	8083.85	1.61	146.00	1.0	0.64	82	2.00	386.70	1.50	KL	
10-Jan	08:00	361635	67	8085.46	1.53	145.00	2.0	0.70	80	2.00	385.20	1.30	KL	
11-Jan	08:00	361702	46	8086.99	1.05	143.00	2.0	1.94	78	2.00	383.90	0.90	KL	
12-Jan	08:00	361748	66	8088.04	1.31	141.00	2.0	1.92	76	4.00	383.00	1.10	KL	
13-Jan	08:00	361814	64	8089.35	1.67	139.00	2.0	2.08	72	2.00	381.90	1.10	KL	
14-Jan	08:00	361878	68	8091.02	1.56	137.00	3.0	1.88	70	4.00	380.80	1.40	DH	
15-Jan	08:00	361946	68	8092.58	1.57	134.00	2.0	1.61	66	2.00	379.40	1.30	KL	
16-Jan	08:00	362014	47	8094.15	1.07	132.00	1.0	1.81	64	4.00	378.10	1.10	KL	
17-Jan	08:00	362061	67	8095.22	1.55	131.00	2.0	1.88	60	2.00	377.00	1.10	KL	
18-Jan	08:00	362128	64	8096.77	1.46	129.00	2.0	1.92	58	4.00	375.90	1.30	KL	
19-Jan	08:00	362192	46	8098.23	1.01	127.00	1.0	1.63	54	4.00	374.60	0.80	KL	
20-Jan	08:00	362238	66	8099.24	1.14	126.00	2.0	1.75	50/100	2.00	373.80	1.00	KL	
21-Jan	08:00	362304	67	8100.38	1.95	124.00	3.0	1.86	98	4.00	372.80	1.40	KL	
22-Jan	08:00	362371	69	8102.33	1.58	121.00	1.0	1.92	94	6.00	371.40	1.20	KL	
23-Jan	08:00	362440	66	8103.91	1.53	120.00	3.0	1.72	88	6.00	370.20	1.30	KL	
24-Jan	08:00	362506	69	8105.44	1.58	117.00	2.0	1.47	82	2.00	368.90	1.60	KL	
25-Jan	08:00	362575	45	8107.02	1.03	115.00	2.0	1.37	80	2.00	367.30	0.80	DH	
26-Jan	08:00	362620	67	8108.05	1.53	113.00	1.0	1.45	78	4.00	366.50	1.10	KL	
27-Jan	08:00	362687	66	8109.58	1.42	112.00	2.0	1.48	74	4.00	365.40	1.30	KL	
28-Jan	08:00	362753	68	8111	2	110.00	2.0	1.35	70	4.00	364.10	1.40	JH	
29-Jan	08:00	362821	69	8113	1.28	108.00	2.0	1.44	66	6.00	362.70	1.20	JH	
30-Jan	08:00	362890	68	8114.28	1.57	106.00	2.0	1.12	60	4.00	361.50	1.30	DH	
31-Jan	08:00	362958	69	8115.85	1.57	104.00		1.47	56		360.20	1.40	DH	
1-Feb	08:00	363027		8117.42		102.00		1.46	54		358.8		DH	
TOT			1933					45.59						
AVE			62					1.38						
MAX			93					2.08						
MIN			0					0.40						

SIGNATURE:  **Jon Stear**  
PHONE: 815-224-1650

VILLAGE OF POPLAR GROVE - SOUTH  
 FOR THE MONTH OF January 2023  
 ILLINOIS ENVIRONMENTAL PROTECTION AGENCY  
 DIVISION OF PUBLIC WATER SUPPLIES

IL0070300  
 MONTHLY OPERATING REPORT

Date	Time	Flow Meter		Hour Meter Well 5		Hour Meter Well 6		Chlorine Feed		Free		Phosphate Feed		Flouride Feed		Operator Initials
		Reading	Pumpage	Reading	Hours	Reading	Hours	Scale	lbs Used	Scale	Free	Scale	lbs Used	Scale	lbs Used	
31-Dec	09:00	575858	70	3974	1	4757.60	0	132.00	1.0	1.43	80	4.00	417.00	1.80	JH	
1-Jan	09:00	575928	71	3975	1.1	4757.60	0	131.00	1.0	1.17	76	4.00	415.20	1.40	JH	
2-Jan	09:00	575999	88	3976.1	1.3	4757.60	0	130.00	1.0	1.14	72	4.00	413.80	2.00	KL	
3-Jan	09:00	576087	70	3977.4	1.1	4757.60	0	129.00	1.0	1.10	68	4.00	411.80	1.80	KL	
4-Jan	09:00	576157	51	3978.5	0.9	4757.60	0	128.00	1.0	1.26	64	4.00	410.00	1.00	DH	
5-Jan	09:00	576208	70	3979.4	1.1	4757.60	0	127.00	1.0	1.33	60	2.00	409.00	1.80	KL	
6-Jan	09:00	576278	69	3980.5	1	4757.60	0	126.00	1.0	1.41	58	6.00	407.20	1.40	KL	
7-Jan	09:00	576347	70	3981.5	1.1	4757.60	0	125.00	1.0	1.40	52	2.00	405.80	1.60	KL	
8-Jan	09:00	576417	76	3982.6	1.2	4757.60	0	124.00	2.0	1.42	50	4.00	404.20	1.60	KL	
9-Jan	09:00	576493	82	3983.8	1.3	4757.60	0	122.00	1.0	1.49	46	4.00	402.60	2.00	KL	
10-Jan	09:00	576575	53	3985.1	0.9	4757.60	0	121.00	1.0	1.43	42	4.00	400.60	1.40	KL	
11-Jan	09:00	576628	71	3986	1.1	4757.60	0	120.00	1.0	1.44	38/100	2.00	399.20	1.40	KL	
12-Jan	09:00	576699	69	3987.1	1.1	4757.60	0	119.00	1.0	1.38	98	4.00	397.80	1.40	KL	
13-Jan	09:00	576768	52	3988.2	0.8	4757.60	0	118.00	1.0	1.40	94	4.00	396.40	1.60	KL	
14-Jan	09:00	576820	71	3989	1.1	4757.60	0	117.00	2.0	1.33	90	2.00	394.80	1.40	DH	
15-Jan	09:00	576891	71	3990.1	1.1	4757.60	0	115.00	1.0	1.31	88	4.00	393.40	1.80	KL	
16-Jan	09:00	576962	14	3991.2	0.2	4757.60	0	114.00	0.0	1.35	84	2.00	391.60	0.40	KL	
17-Jan	09:00	576976	139	3991.4	2.2	4757.60	0	114.00	3.0	1.01	82	6.00	391.20	3.00	KL	
18-Jan	09:00	577115	52	3993.6	0.8	4757.60	0	111.00	1.0	1.33	76	4.00	388.20	1.20	KL	
19-Jan	09:00	577167	70	3994.4	1.1	4757.60	0	110.00	0.0	1.30	72	2.00	387.00	1.40	KL	
20-Jan	09:00	577237	52	3995.5	0.8	4757.60	0	110.00	2.0	1.36	70	2.00	385.60	1.40	KL	
21-Jan	09:00	577289	87	3996.3	1.4	4757.60	0	108.00	0.0	1.31	68	6.00	384.20	1.80	KL	
22-Jan	09:00	577376	71	3997.7	1.1	4757.60	0	108.00	1.0	1.38	62	4.00	382.40	1.80	KL	
23-Jan	09:00	577447	71	3998.8	1.1	4757.60	0	107.00	1.0	1.30	58	4.00	380.60	1.60	KL	
24-Jan	09:00	577518	69	3999.9	1.1	4757.60	0	106.00	3.0	1.28	54/100	2.00	379.00	1.40	KL	
25-Jan	09:00	577587	53	4001	0.8	4757.60	0	103.00	1.0	1.12	98	2.00	377.60	1.40	DH	
26-Jan	09:00	577640	69	4001.8	1.1	4757.60	0	102.00	1.0	1.20	96	4.00	376.20	1.40	KL	
27-Jan	09:00	577709	69	4002.9	1.1	4757.60	0	101.00	1.0	1.15	92	4.00	374.80	1.60	KL	
28-Jan	09:00	577778	62	4004	1	4757.60	0	100.00	1.0	1.23	88	4.00	373.20	1.40	JH	
29-Jan	09:00	577840	78	4005	1.1	4757.60	0	99.00	2.0	1.18	84	4.00	371.80	1.60	JH	
30-Jan	09:00	577918	67	4006.1	1.1	4757.60	0	97.00	1.0	1.24	80	4.00	370.20	1.60	DH	
31-Jan	09:00	577985	69	4007.2	1.1	4757.60	0	96.00	1.0	1.32	76	4.00	368.60	2.00	DH	
1-Feb	09:00	578054	-578054	4008.3	-4008.3	4757.60	-4757.60	95.00	95.00	72	72	72.00	366.60	366.60	DH	
TOT			2127				0			41.50						
AVE			69				0			1.30						
MAX			139				0			1.49						
MIN			14				0			1.01						

SIGNATURE:  Ion Stear  
 PHONE: 815-224-1650

VILLAGE OF POPLAR GROVE - NORTH  
 FOR THE MONTH OF January 2023  
 ILLINOIS ENVIRONMENTAL PROTECTION AGENCY  
 DIVISION OF PUBLIC WATER SUPPLIES

IL0070150  
 MONTHLY OPERATING REPORT

Date	Time	Flow Meter		Hour Meter Well 2		Hour Meter Well 3		Chlorine Feed		Phosphate Feed		Flouride Feed		Operator Initials
		Reading	Pumpage	Reading	Hours	Reading	Hours	Scale	lbs Used	Scale	lbs Used	Scale	lbs Used	
31-Dec	10:00	360586	145	10063.5	0	29166.00	11.00	115.00	2.0	46	8.00	39.00	1.0	JH
1-Jan	10:00	360731	268	10063.5	0	29177.00	10.70	113.00	1.0	38	8.00	38.00	0.8	JH
2-Jan	10:00	360999	207	10063.5	0	29187.70	10.40	112.00	2.0	30/100	6.00	37.25	0.3	KL
3-Jan	10:00	361206	222	10063.5	0	29198.10	11.30	110.00	2.0	94	10.00	37.00	1.0	KL
4-Jan	10:00	361428	153	10063.5	0	29209.40	7.70	108.00	2.0	84	6.00	36.00	0.8	DH
5-Jan	10:00	361581	208	10063.5	0	29217.10	10.40	106.00	2.0	78	8.00	35.25	0.3	KL
6-Jan	10:00	361789	23	10063.5	0	29227.50	9.70	104/160	1.0	70	6.00	35.00	1.0	KL
7-Jan	10:00	361812	381	10063.5	0	29237.20	10.70	159.00	1.0	64	8.00	34.00	0.3	KL
8-Jan	10:00	362193	230	10063.5	0	29247.90	11.60	158.00	2.0	56	8.00	33.75	0.8	KL
9-Jan	10:00	362423	155	10063.5	0	29259.50	7.80	156.00	2.0	48	8.00	33.00	0.8	KL
10-Jan	10:00	362578	125	10063.5	0	29267.30	6.20	154.00	4.0	40	4.00	32.25	0.3	KL
11-Jan	10:00	362703	130	10063.5	0	29273.50	6.60	150.00	1.0	36/100	6.00	32.00	0.3	KL
12-Jan	10:00	362833	118	10063.5	0	29280.10	6.40	149.00	1.0	94	4.00	31.75	0.8	KL
13-Jan	10:00	362959	118	10063.5	0	29286.50	5.90	148.00	4.0	90	4.00	31.00	0.3	KL
14-Jan	10:00	363077	125	10063.5	0	29292.40	6.30	144.00	1.0	86	4.00	30.75	0.5	DH
15-Jan	10:00	363202	128	10063.5	0	29298.70	6.40	143.00	1.0	82	6.00	30.25	0.3	KL
16-Jan	10:00	363330	147	10063.5	0	29305.10	7.30	142.00	2.0	76	6.00	30.00	0.3	KL
17-Jan	10:00	363477	121	10063.5	0	29312.40	9906.10	140.00	1.0	70	4.00	29.75	0.8	KL
18-Jan	10:00	363598	113	10063.5	0	39218.50	-9894.30	139.00	2.0	66	4.00	29.00	0.0	KL
19-Jan	10:00	363711	133	10063.5	0	29324.20	6.60	137.00	1.0	62	6.00	29.00	0.3	KL
20-Jan	10:00	363844	111	10063.5	0	29330.80	5.70	136.00	2.0	56	4.00	28.75	0.8	KL
21-Jan	10:00	363955	158	10063.5	0	29336.50	7.90	134.00	3.0	52	4.00	28.00	0.3	KL
22-Jan	10:00	364113	146	10063.5	0	29344.40	10007.30	131.00	1.0	48	4.00	27.75	0.8	KL
23-Jan	10:00	364259	127	10063.5	0	39351.70	-9993.70	130.00	1.0	42/100	4.00	27.00	0.3	KL
24-Jan	10:00	364386	123	10063.5	0	29358.00	6.70	129.00	2.0	96	4.00	26.75	0.5	KL
25-Jan	10:00	364509	128	10063.5	0	29364.70	5.90	127.00	2.0	92	4.00	26.25	0.3	DH
26-Jan	10:00	364637	129	10063.5	0	29370.60	6.40	125.00	1.0	88	6.00	26.00	0.3	KL
27-Jan	10:00	364766	116	10063.5	0	29377.00	5.00	124.00	2.0	82	4.00	25.75	0.8	KL
28-Jan	10:00	364882	123	10063.5	0	29382.00	7.00	122.00	2.0	78	4.00	25.00	0.0	JH
29-Jan	10:00	365005	173	10063.5	0	29389.00	8.70	120.00	2.0	74	6.00	25.00	0.3	JH
30-Jan	10:00	365178	121	10063.5	0	29397.70	6.00	118.00	2.0	68	6.00	24.75	0.0	DH
31-Jan	10:00	365299	127	10063.5	0	29403.70	6.40	116.00	1.0	62	4.00	24.75	0.8	DH
1-Feb	10:00	365426	-365426	10063.5	-10063.5	29410.1	-29410.10	115.0	115.0	58	58.00	24	24.0	DH
TOT			4713				238			47.94				
AVE			152				8			1.45				
MAX			381				10007			2.10				
MIN							-9994			0.60				

SIGNATURE:  Jon Stear  
 PHONE: 815-224-1650

**VILLAGE OF POPLAR GROVE**  
**FOR THE MONTH OF January 2023**  
**DAILY DISTRIBUTION MONITORING REPORT**

**ILLINOIS ENVIRONMENTAL PROTECTION AGENCY**  
**DIVISION OF PUBLIC WATER SUPPLIES**

Date	North System (Wells 2 & 3)			West System (Well 4)			South System (Wells 5 & 6)			Operator Initials			
	Site #	Free Cl <sub>2</sub>	Total Cl <sub>2</sub>	PO <sub>4</sub>	Site #	Free Cl <sub>2</sub>	Total Cl <sub>2</sub>	PO <sub>4</sub>	Site #		Free Cl <sub>2</sub>	Total Cl <sub>2</sub>	PO <sub>4</sub>
1-Jan													
2-Jan													
3-Jan	School	1.06		1.04	Gas Station	0.41		0.68	Tower	0.97		0.91	KL
4-Jan	VH	0.41		0.79	Oak lawn	0.4		0.52	Tower	0.82		0.52	DH
5-Jan	Tower	1.54		1.65	Tower	0.82		1.64	Tower	1.1		0.84	KL
6-Jan	School	1.1		0.98	Garage	0.62		1.01	Tower	1.22		0.85	KL
7-Jan													
8-Jan													
9-Jan	Tower	0.98		0.82	Tower	0.58		1.3	Tower	0.86		0.92	KL
10-Jan	School	1.07		1.69	Gas Station	0.68		0.85	Tower	1.17		1.26	KL
11-Jan	Tower	1.1		1.3	Oal Lawn	0.42		0.42	Tower	1.13		1.07	KL
12-Jan	School	0.6		1.77	Garage	0.74		0.72	Tower	0.71		1.01	KL
13-Jan	School	0.62		1.81	Tower	2.14		1.29	Tower	0.71		0.98	KL
14-Jan													
15-Jan													
16-Jan	Tower	1.4		1.27	Gas station	0.55		1.04	Tower	1.05		1.1	KL
17-Jan	School	1.31		1.98	Garage	1.54		0.78	Tower	1.08		1.01	KL
18-Jan	VH	0.56		1.64	oak Lawn	0.52		0.68	Tower	1.07		0.94	KL
19-Jan	School	1.61		1.17	tower	1.82		1.04	Tower	1.02		0.9	KL
20-Jan	Tower	1.65		1.46	oak Lawn	0.65		0.72	Tower	1.08		0.89	KL
21-Jan													
22-Jan													
23-Jan	Tower	1.92		1.97	Gas station	0.64		1.1	Tower	0.87		0.94	KL
24-Jan	School	1.21		1.37	Oak Lawn	0.43		0.6	Tower	0.91		1.01	KL
25-Jan	VH	0.56		1.81	Tower	0.91		1.19	Tower	0.93		0.94	KL
26-Jan	School	1.3		1.1	Garge	1.2		0.84	Tower	1.01		0.98	KL
27-Jan	Tower	1.62		1.01	Oak Lawn	1.52		1.81	Tower	1.1		1.08	KL
28-Jan													
29-Jan	School	0.81		0.95	Oak lawn	1.35		1.25	Tower	1.24		0.94	KL
30-Jan	VH	0.55		1.35	garage	1.33		1.14	tower	0.94		0.86	KL
31-Jan													

Signature:  Ion Stear  
 PHONE: 815-224-1650