



2323 Fourth Street, PO Box 483 Peru, IL 61354

Phone: 815-224-1650 Toll Free: 800-659-4659

[www.testinc.com](http://www.testinc.com)

June 8, 2023

**Client:** Village of Poplar Grove  
Attn: Don Sattler, Village President  
200 Hill Street  
P.O. Box 01  
Poplar Grove, IL 61065

**Plant Type:** Wastewater Treatment Plants: North: Class II Sequential batch reactors (SBR).  
South: Class I Sequential batch reactors (SBR).  
Water Treatment Plants: Well Supply with Chemical Addition in all 3 locations

For the water system you will find attached the daily inspection and monitoring reports for each of the water plants and the distribution system testing record. For the wastewater side we have included the monthly DMR for both wastewater plants.

Outlined below are the processes and actions taken during April 2023 in Poplar Grove to improve the facilities equipment beyond required and routine maintenance, testing, inspection and reporting. At times we will also list upcoming needed improvements that may need attention by the Village.

**Lift Stations:**

- Cleaned all lift station floats and transducers.
- Ran and tested portable generators under load.
- Check all dialers to ensure they are working.
- Checked and cleaned out grease (that we can with our net).
- Collins is set to come the first week in June to clean all the lift stations.

**North WWTP:**

- All standard monthly checks/maintenance/cleaning and procedures were completed.
- Still waiting on parts for the screen.
- Decanted digesters.
- Tested all emergency wash stations.
- We are having an issue with the disk filter. We tried to run it as we do periodically to ensure it will work when we need it to. The issue we are having is that the rollers will not engage to turn it over. We will call Gasvoda and have someone look at it to get it working in case we need to use it.
- We will be cleaning the EQ tank in the next couple of weeks.
- We will have a septic company come out to clean the duckweed off the top of the EQ tank.

**South WWTP:**

- All standard monthly checks/maintenance/cleaning and procedures were completed.
- We repaired the influent sampler. We were having an issue with it not pulling samples.



2323 Fourth Street, PO Box 483 Peru, IL 61354

Phone: 815-224-1650 Toll Free: 800-659-4659

[www.testinc.com](http://www.testinc.com)

- Cleaned and inspected brushes on influent screen.
- Transferred sludge to drying beds. We have been making a lot of headway on the sludge handling. I know we're doing it the old-fashioned way and not using the press, but we're having really good luck doing it this way and saving the village a lot of money on chemicals.
- We had a pump short out on one of the sand filters. We are looking at pump options because the pump that was shorted out was only a year and a half old and only had a 90-day warranty. They were the cheapest option last time, so we are looking at other options.
- We will be cleaning the EQ tank in the next couple weeks.
- We will have a septic company come out to clean the duckweed off the top of the EQ tank.
- Tested all emergency wash stations.
- Decanted digesters.

**Water System:**

- Cleaned well houses.
- Lead and copper samples will be disrupted soon.
- We have had a lot of water testing due this year. It's just in its cycle. Everything has been well within limits and there are no issues.
- Returned water tower levels to summer operation settings.
- All required EPA testing has been done.

All operations and plant inspections have been performed by me or under my direct supervision. As always, if you have any questions concerning the above, please do not hesitate to contact me.

Submitted by,  
Total Environmental Service Technologies, Inc.

Ion Stear  
Certified Operator/Manager

## DMR Copy of Record

Permit#:	IL0023451	Permittee:	POPLAR GROVE, VILLAGE OF 200 NORTH HILL STREET POPLAR GROVE, IL 61065	Facility:	POPLAR GROVE - NORTH WWTP, VILLAGE OF 205 EDSON RD POPLAR GROVE, IL 61065	
Major:	No	Permittee Address:		Facility Location:		
Permitted Feature:	001 External Outfall	Discharge:	001-4 STP OUTFALL			
Report Dates & Status	From 04/01/23 to 04/30/23	DMR Due Date:	05/25/23	Status:	No DMR Validated	
Monitoring Period:						
Considerations for Form Completion						
BOW ID: W007150007; DMR LOAD LIMITS DISPLAYED, MONITORING LOCATION "1" IS FOR MONTHLY AVERAGE AND DAILY MAXIMUM, MONITORING LOCATION "8" IS FOR WEEKLY AVERAGE.						
Principal Executive Officer	Ion Stear	Title:	Certified Operator	Telephone#:	815-224-1650	
Last Name:						
No Data Indicator (NODI)	-					
Form NODI:		Monitoring Location Session # Permit, NODI	Quantity or Load/Unit	Quality or Concentration	Frequency of Analysis	
Code		Sample	Qualifier 1	Qualifier 2	Qualifier 3	
00300 Oxygen, dissolved [DO]	1 - Effluent Gross 0	Permit Req. Value NODI	=	3.265	=	02/DA - 2 Days Every Week
00400 pH	1 - Effluent Gross 0	Permit Req. Value NODI	>=	6.25 MN WK-AV >=	5.0 DAILY MN 19 - mg/L	02/DA - 2 Days Every Week
00530 Solids, total suspended	1 - Effluent Gross 0	Permit Req. Value NODI	=	7.37	=	02/DA - 2 Days Every Week
00610 Nitrogen, ammonia total [as N]	1 - Effluent Gross 0	Permit Req. Value NODI	<=	6.0 MINIMUM	<=	02/DA - 2 Days Every Week
50050 Flow, in conduit or thru treatment plant	1 - Effluent Gross 0	Permit Req. Value NODI	=	40.532	=	02/DA - 2 Days Every Week
50060 Chlorine, total residual	1 - Effluent Gross 0	Permit Req. Value NODI	<=	250.0 MO AVG	<=	02/DA - 2 Days Every Week
80082 BOD, carbonaceous [5 day, 20 °C]	1 - Effluent Gross 0	Permit Req. Value NODI	=	13.173	<	02/DA - 2 Days Every Week
		Permit Req. Value NODI	<=	104.0 MO AVG	<	02/DA - 2 Days Every Week
Submission Note						
If a parameter row does not contain any values for the Sample# nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.						
Edit Check Errors						
No errors.						
Comments						
Attachments						
No attachments.						
Report Last Saved By						
POPLAR GROVE, VILLAGE OF						
User:						
Name:	Elaine Bumgarner					
E-Mail:	elainebumgarner@testing.com					
Date/Time:	2023-05-26 13:14 (Time Zone: -05:00)					
Report Last Signed By						
User:	IONSTAR					

Name: Ian Stear  
E-Mail: i.stear@iesinc.com  
DateTime: 2023-05-31 11:33 (Time Zone: -05:00)

## DMR Copy of Record

<b>Permit</b>	<b>Permit #: IL0023451</b>	<b>Permittee:</b> No	<b>Permittee Address:</b> 200 NORTH HILL STREET POPLAR GROVE, IL 61065	<b>Facility Location:</b> POPLAR GROVE - NORTH WWTP, VILLAGE OF 205 EDSON RD POPLAR GROVE, IL 61065
<b>Permitted Feature:</b>	<b>INF</b>	<b>Discharge #:</b> Influent Structure	<b>INF-4</b>	
<b>Report Dates &amp; Status</b>	<b>From 04/01/23 to 04/30/23</b>	<b>DMR Due Date:</b> 05/22/23	<b>Status:</b>	<b>NetDMR Validated</b>
<b>Considerations for Form Completion</b>				
<b>BOW ID:</b>	<b>W0070500007</b>	<b>Title:</b> Ion Shear	<b>Certified Operator</b>	<b>Telephone:</b> 815-224-1650
<b>Principal Executive Officer</b>				
<b>First Name:</b> Last Name: Last Name, <b>No Data Indicator (NODI)</b>				
<b>Form NODI:</b>		<b>Monitoring Location:</b> Benton & Benton, MO/IL	<b>Quantity or Length:</b> Dissolved 1 Value 1	<b>Quantity or Concentration:</b> Dissolved 2 Value 2
<b>Date:</b>		<b>Sample:</b> Permit Rate Value (NODI)	<b>Units:</b> Dissolved 1 Value 1 Value 2	<b>Units:</b> Dissolved 2 Value 2 Value 3
<b>00310</b>	<b>BOD, 5-day, 20 deg. C</b>	<b>G - Raw Sewage influent</b>	<b>0</b>	<b>&lt;</b>
<b>00530</b>	<b>Solids, total suspended</b>	<b>G - Raw Sewage influent</b>	<b>0</b>	<b>=</b>
<b>50050</b>	<b>Flow, in conduit or thru treatment plant</b>	<b>G - Raw Sewage influent</b>	<b>0</b>	<b>=</b>
<b>Submission Note</b>				
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.				
<b>Edit Check Errors</b>				
No errors.				
<b>Comments</b>				
<b>Attachments</b>				
<b>No attachments.</b>				
<b>Report Last Saved By</b>				
<b>POPLAR GROVE, VILLAGE OF</b>				
User:	ebungamer	Name:	Elaine	Bungamer
E-Mail:		E-Mail:		ebungamer@testinc.com
Date/Time:		Date/Time:		2023-05-26 13:14 (Time Zone: -05:00)
<b>Report Last Signed By</b>				
User:	IONSTAR	Name:	Ion	Spear
E-Mail:		E-Mail:		istea@testinc.com
Date/Time:		Date/Time:		2023-05-31 11:33 (Time Zone: -05:00)

DMR Copy of Record

Permit		Permit #: IL0071447 Yes:		Permittee Address: POPLAR GROVE, VILLAGE OF 200 S HILL ST POPLAR GROVE, IL 61065		Facility Location: Facility Location: 12211 STATE ROUTE 76 POPLAR GROVE, IL 61065																	
Permitted Feature: External Outfall		Discharge: 004a STP OUTFALL																					
Report Dates & Status: From 04/01/23 to 04/30/23		DNR Due Date: 05/25/23		Status: NetDNR Validated																			
Monitoring Period: Considerations for Form Completion		First Name: Ion Last Name: Stear		Certified Operator		Telephone: 815-224-1650																	
BOW ID: W0070150006; DMF LOAD LIMITS DISPLAYED.																							
Principal Executive Officer																							
No Data Indicator (NOD)																							
Form NODID	Methodology	Monitoring Location	Parameter # Parameter NOID	Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 3	Value 3	Qualifier 4	Value 4	Units	Quality for Characterization	Quantity for Characterization	Unit	Value	Units	Value	Units	Value	Frequency of Analysis	Sample Type
00400 pH			Sample: Permit Ref: Value NOID	=	7.22	=	6.0 MINIMUM		<=	9.0 MAXIMUM	=	8.7		12 - SU	03DW - 3 Days Every Week	GR - GRAB							
00530 Solids, total suspended			Sample: Permit Ref: Value NOID	=	10.009	=	18.765		<=	2.667	=	5.0	DAILY MX	19 - mg/L	03DW - 3 Days Every Week	GR - GRAB							
00600 Nitrogen, total [as N]			Sample: Permit Ref: Value NOID	=	0.437	=	0.664		<=	1.5 MO AVG	=	11.61		11.61	Req Man MO AVG	19 - mg/L	01/30 - Monthly	CP - COMPOS					
00610 Nitrogen, ammonia total [as N]			Sample: Permit Ref: Value NOID	=	31.0 MO AVG	<=	98.0 DAILY MX		<=	1.5 MO AVG	=	0.111		0.111	Req Man DAILY MX	19 - mg/L	01/30 - Monthly	CP - COMPOS					
00610 Nitrogen, ammonia total [as N]			Sample: Permit Ref: Value NOID	=	0.437	=	0.514		<=	1.5 MO AVG	=	0.137		0.137	3.8 WKLY AVG	19 - mg/L	03DW - 3 Days Every Week	CP - COMPOS					
00665 Phosphorus, total [as P]			Sample: Permit Ref: Value NOID	=	21.0 MO AVG	<=	79.0 WKLY AVG		<=	1.0 MO AVG	=	0.226		0.226	19 - mg/L	03DW - 3 Days Every Week	CP - COMPOS						
50050 Flow, in conduit or thru treatment plant			Sample: Permit Ref: Value NOID	=	0	=	0.45		=	0.85	=	0.85		0.85	Req Man DAILY MX	03 - MGD	03DW - 3 Days Every Week	CP - COMPOS					
50060 Chlorine, total residual			Sample: Permit Ref: Value NOID	=	0	=	0		=	0.06 DAILY MX	=	0.0		0.0	19 - mg/L	03DW - 3 Days Every Week	CL0CC - Chlorination/Occumrmas GR - GRAB						
80082 BOH, carbonaceous (5 day, 20 C)			Sample: Permit Ref: Value NOID	=	10.059	=	33.777		<	2.667	=	9.0	DAILY MX	19 - mg/L	03DW - 3 Days Every Week	CP - COMPOS							
			Sample: Permit Ref: Value NOID	=	208.0 MO AVG	<=	417.0 DAILY MX		<=	10.0 MO AVG	=	200.0	DAILY MX	19 - mg/L	03DW - 3 Days Every Week	CP - COMPOS							

*Report Last Saved By*

POPLAR GROVE, VILLAGE OF

User: ebungamer

Name: Elaine Bumgamer

E-Mail: ebungamer@testinginc.com

Date/Time: 2023-05-26 13:19 (Time Zone: -05:00)

*Report Last Signed By*

User: ionstear

Name: Ion Stear

E-Mail: istear@testinginc.com

Date/Time: 2023-05-31 11:33 (Time Zone: -05:00)

## DMR Copy of Record

Permit #: IL0071447	Permittee: POPLAR GROVE, VILLAGE OF	Facility: POPLAR GROVE SOUTH STP, VILLAGE OF		
Major: Yes	Permittee Address: 200 S HILL ST	Facility Location: POPLAR GROVE, IL 61065		
Permitted Feature: INF influent Structure	Discharge: INF-L INFLUENT MONITORING			
Report Dates & Status				
Monitoring Period: From 04/01/23 to 04/30/23	DMR Due Date: 05/25/23	NetDMR Validated		
Considerations for Form Completion				
BOW ID: W0070750006	Principal Executive Officer			
First Name: Ian	Last Name: Stear	Telephone: 815-224-1650		
No Data Indicator (NODI)				
Form NODI:	Monitoring Location: Treatment Plant (NODI)	Quantity or Location: Quantity 1 Value 1 Qualifier 1 Quantity 2 Value 2 Qualifier 2 Quantity 3 Value 3 Qualifier 3		
Code: C	Permit Number: G - Raw Sewage influent 0	Units: Req Mon MO AVG		
00310 BOD, 5-day, 20 deg. C	Sample: Permit Reg. Value (10D)	Value 1: 60.0	Frequency of Analysis: 03DW - 3 Days Every Week CP - COMPOS	
00530 Solids, total suspended	Sample: Permit Reg. Value (10D)	Value 2: <	Value 3: Req Mon MO AVG	Units: 19 - mgL
00665 Phosphorus, total [as P]	Sample: Permit Reg. Value (10D)	Value 2: 76.333	Frequency of Analysis: 03DW - 3 Days Every Week CP - COMPOS	
50050 Flow, in conduit or thru treatment plant	Sample: Permit Reg. Value (10D)	Value 3: = 2.795	Value 1: Req Mon MO AVG	Units: 19 - mgL
	Value 1: 0.491	Value 2: 13.1	Frequency of Analysis: 03DW - 3 Days Every Week CP - COMPOS	
	Value 3: Req Mon Daily MX 03 - MGD	Value 1: Req Mon Daily MX 19 - mgL	Value 2: 0	Frequency of Analysis: 03DW - 3 Days Every Week CP - COMPOS
	Value 3: 0	Value 1: 9999 - Continuous	Frequency of Analysis: 9999 - Continuous	
Submission Note				
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.				
Edit Check Errors				
No errors.				
Comments				
Attachments				
No attachments.				
Report Last Saved By				
POPLAR GROVE, VILLAGE OF				
User: Elaine Burgamer	E-Mail: elaine.burgamer@testinginc.com	Date/Time: 2023-05-26 13:19 (Time Zone: -05:00)		
User: Ian Stear	E-Mail: istear@testinginc.com	Date/Time: 2023-05-31 11:33 (Time Zone: -05:00)		

VILLAGE OF POPLAR GROVE  
 FOR THE MONTH OF Apr-23  
 ILLINOIS ENVIRONMENTAL PROTECTION AGENCY  
 DIVISION OF PUBLIC WATER SUPPLIES

DAILY DISTRIBUTION MONITORING REPORT

Date	Site #	North System (Wells 2 & 3)			West System (Well 4)			South System (Wells 5 & 6)			Fluoride Analysis							
		Free Cl <sub>2</sub>	Total Cl <sub>2</sub>	PO <sub>4</sub>	Site #	Free Cl <sub>2</sub>	Total Cl <sub>2</sub>	PO <sub>4</sub>	Site #	Free Cl <sub>2</sub>	Total Cl <sub>2</sub>	PO <sub>4</sub>	Operator Initials	Slope Standard	Well #2	Well #3	Well #4	Well#5-6
1															0.65	0.51	0.52	
2															0.62	0.53	0.74	
3	Elem	1.04	0.92		Garage	0.91		1.01	Tower	1.43		0.99	DH		0.89	0.91	0.82	
4	F.H.	0.89	1.11		Tower	0.9		0.82	Tower	1.15		1.06	DH		0.41	0.80	0.60	
5	Village	0.62	1.04		Gas st	0.7		0.94	Tower	1.12		0.95	DH		0.74	0.62	0.74	
6	Tower	1.14	0.95		Tower	1.05		0.96	Tower	1.11		1.15	DH		0.50	0.58	0.62	
7															0.91	0.74	0.77	
8															0.78	0.67	0.64	
9															0.97	0.49	0.65	
10	Tower	0.89	0.91		Tower	1.13		0.99	Tower	1.05		1.12	DH		0.52	0.52	0.70	
11	Village	0.98	0.9		Gas	0.84		1.14	Tower	1.11		1.22	DH		0.67	0.58	0.77	
12	School	1.57	1.08	D.L. Office	0.56	0.74		1.01	Tower	1.11		1.11	DH		0.85	0.68	0.73	
13	F.H.	0.85	1.15		Garage	1.25		0.95	Tower	0.99		1.33	DH		0.65	0.72	0.78	
14	Tower	1.1	0.83		Tower	1.19		1.04	Tower	1.04		1.37	DH		0.74	0.78	0.82	
15															0.72	0.78	0.74	
16															1.10	0.75	0.71	
17	School	0.97	1.03		Gas	1.09		0.93	Tower	1.32		1.23	DH		0.98	0.74	0.83	
18	Village	0.9	1.26	D.L. Office	0.64	0.72		1.43	Tower	1.14		1.14	DH		0.89	0.59	0.83	
19	Tower	1.12	0.95		Garage	1.38		1.09	Tower	1.49		0.94	DH		0.70	0.58	0.68	
20	F.H.	0.9	1.21		Tower	0.91		0.73	Tower	1.48		1.14	DH		1.20	0.56	0.71	
21	School	0.95	0.85		Gas	0.9		1.08	Tower	1.49		1.07	DH		0.59	0.58	0.72	
22															0.71	0.70	0.72	
23															0.69	0.73	0.73	
24	Tower	1.11	0.89	D.L. Office	0.83	0.56		1.23				1.01	DH		0.85	0.63	0.70	
25	Village	0.76	0.88		Gas	0.91		0.88	Tower	1.9		1.06			0.65	0.62	0.75	
26	Tower	1.09	0.91		Tower	1.11		1.03	Golf cours	1.11		0.88			0.52	0.93	0.79	
27															0.57	0.98	0.81	
28	Elem	1.08	1.01		Garage	1.49		1.1	Tower	1.46		1.1			0.81	0.69	0.81	
29															0.94	0.68	0.95	
30															0.76	0.85	0.79	
31																		

Signature:  
PHONE: 815-224-1650

Jean Stearn

VILLAGE OF POPLAR GROVE - NORTH  
 FOR THE MONTH 1 Apr-23  
 ILLINOIS ENVIRONMENTAL PROTECTION AGENCY  
 DIVISION OF PUBLIC WATER SUPPLIES

IL0070150  
 MONTHLY OPERATING REPORT

Date	Time	Pumpag e	Hour Meter Well 2	Hour Meter Well 3	Reading	Hours	Reading	Hours	Chlorine Feed	Scale	Ibs Used	Free	Phosphate Feed	Scale	Ibs Used	Fluoride Feed	Scale	Ibs Used	Operator Initials
31-Mar	11:15	373177	133	100635	0	29796.20	0.00	73.00	0.0	1.40	86	0.00	0.65	29.00	0.0	0.0	DH		
1-Apr	11:15	373310	111	100635	0	29802.80	5.50	71.00	1.0	1.48	82	6.00	0.89	29.00	1.0	0.0	DH		
2-Apr	11:15	373421	161	100635	0	29808.30	8.00	70.00	2.0	1.26	76	4.00	0.88	28.00	0.0	0.0	DH		
3-Apr	11:15	373582	129	100635	0	29816.30	6.40	68.00	2.0	1.48	72	6.00	0.93	28.00	0.5	0.5	DH		
4-Apr	11:15	373711	131	100635	0	29822.70	6.40	66.00	2.0	1.97	66	4.00	0.78	27.50	0.5	0.5	DH		
5-Apr	11:15	373842	107	100635	0	29829.10	5.80	64.00	1.0	1.22	62	6.00	0.87	27.00	0.3	0.3	DH		
6-Apr	11:15	373949	131	100635	0	29834.90	6.10	63.00	1.0	1.16	56	4.00	0.85	26.75	0.5	0.5	DH		
7-Apr	11:15	374080	104	100635	0	29841.00	5.10	62.00	1.0	1.25	52	6.00	1.09	26.25	0.3	0.3	DH		
8-Apr	11:15	374184	174	100635	0	29846.10	8.70	61.00	2.0	1.29	46	4.00	0.75	26.00	0.8	0.8	DH		
9-Apr	11:15	374358	152	100635	0	29854.80	7.50	59.00	2.0	1.35	42	6.00	0.57	25.25	0.7	0.7	DH		
10-Apr	11:15	374510	142	100635	0	29862.30	7.10	57.00/160	1.0	0.81	36.00/100	4.00	0.80	25.00/51	0.5	0.5	DH		
11-Apr	11:15	374652	136	100635	0	29869.40	6.70	159.00	2.0	1.67	96	6.00	1.21	50.50	0.5	0.5	DH		
12-Apr	11:15	374788	170	100635	0	29876.10	8.40	157.00	3.0	1.35	90	6.00	0.86	50.00	0.0	0.0	DH		
13-Apr	11:15	374958	112	100635	0	29884.50	5.50	154.00	1.0	1.10	84	4.00	0.92	50.00	0.5	0.5	DH		
14-Apr	11:15	375070	119	100635	0	29890.00	6.10	153.00	1.0	1.27	80	4.00	0.79	49.50	0.3	0.3	DH		
15-Apr	11:15	375189	138	100635	0	29896.10	5.90	152.00	2.0	1.15	76	6.00	0.83	49.25	0.5	0.5	DH		
16-Apr	11:15	375327	181	100635	0	29902.00	9.90	150.00	3.0	1.53	70	8.00	0.55	48.75	0.8	0.8	DH		
17-Apr	11:15	375508	136	100635	0	29911.90	6.60	147.00	1.0	1.81	62	4.00	0.60	48.00	0.3	0.3	DH		
18-Apr	11:15	375644	125	100635	0	29918.50	6.30	146.00	2.0	0.82	58	4.00	0.62	47.75	0.5	0.5	DH		
19-Apr	11:15	375769	130	100635	0	29924.80	6.50	144.00	1.0	1.12	54	6.00	0.91	47.25	0.3	0.3	DH		
20-Apr	11:15	375899	129	100635	0	29931.30	6.30	143.00	2.0	1.27	48	4.00	1.10	47.00	0.5	0.5	DH		
21-Apr	11:15	376028	134	100635	0	29937.60	6.60	141.00	2.0	1.18	44	6.00	0.53	46.50	0.5	0.5	DH		
22-Apr	11:15	376162	127	100635	0	29944.20	6.40	139.00	1.0	1.22	38/100	6.00	0.76	46.00	1.0	1.0	DH		
23-Apr	11:15	376289	152	100635	0	29950.60	7.50	138.00	2.0	1.19	94	6.00	0.89	45.00	0.0	0.0	DH		
24-Apr	11:15	376441	120	100635	0	29958.10	5.90	136.00	1.0	1.09	88	4.00	0.87	45.00	0.5	0.5	DH		
25-Apr	11:15	376561	119	100635	0	29964.00	5.90	135.00	1.0	1.10	84	2.00	0.89	44.50	0.3	0.3	DH		
26-Apr	11:15	376680	155	100635	0	29969.90	7.21	134.00	2.0	1.19	82	8.00	0.85	44.25	0.3	0.3	DH		
27-Apr	11:15	376835	139	100635	0	29977.11	7.49	132.00	2.0	1.17	74	6.00	0.91	44.00	0.3	0.3	DH		
28-Apr	11:15	376974	127	100635	0	29984.60	6.20	130.00	1.0	1.41	68	4.00	0.85	43.75	0.5	0.5	DH		
29-Apr	11:15	377101	108	100635	0	29990.80	5.40	129.00	1.0	1.37	64	4.00	0.65	43.25	0.3	0.3	DH		
30-Apr	11:15	377209	176	100635	0	29996.20	7.80	128.00	4.0	1.46	60	10.00	0.75	43.00	0.8	0.8	DH		
1-May	11:15	377385	0	100635	0	30004.00	0.00	124.00	0.0	1.25	50	0.00	0.45	42.25	0.0	0.0			
TOT																			
AVE																			
MAX																			
MIN																			

SIGNATURE: \_\_\_\_\_  
 PHONE: 815-224-1650

Ion Stear

VILLAGE OF POPLAR GROVE - WEST  
 FOR THE MONTH Apr-23  
 ILLINOIS ENVIRONMENTAL PROTECTION AGENCY  
 DIVISION OF PUBLIC WATER SUPPLIES

IL0070350  
 MONTHLY OPERATING REPORT

Date	Time	Flow Meter Pumpage	Hour Meter Well 4		Chlorine Feed			Phosphate Feed			Fluoride Feed			Operator Initials
			Reading	Reading	Hours	Scale	Ibs Used	Free	Scale	Ibs Used	PO4 mg/L	Scale	Ibs Used	
31-Mar	11:40	3666807	0	8204.23	0	98.00	1.0	1.03	66	4.00	1.08	372.40	0.70	DH
1-Apr	11:40	3666865	61	8205.57	1.4	97.00	1.0	1.06	62	4.00	1.23	371.70	1.20	DH
2-Apr	11:40	3666926	57	8206.97	1.3	96.00	1.0	1.08	58	2.00	1.15	370.50	1.00	DH
3-Apr	11:40	3666983	56	8208.27	1.3	95.00	1.0	1.80	56	2.00	1.82	369.50	1.40	DH
4-Apr	11:40	367039	57	8209.57	1.28	94.00	1.0	1.71	54	4.00	1.75	368.10	1.70	DH
5-Apr	11:40	367096	85	8210.85	1.92	93.00	1.0	1.89	50	6.00	1.46	366.40	0.50	DH
6-Apr	11:40	367181	29	8212.77	0.7	92.00	0.0	1.31	44	2.00	1.02	365.90	1.50	DH
7-Apr	11:40	367210	57	8213.47	1.32	92.00	1.0	2.03	42	4.00	1.09	364.40	0.10	DH
8-Apr	11:40	367267	89	8214.79	2.02	91.00	1.0	2.07	38	4.00	1.55	364.30	1.60	DH
9-Apr	11:40	367356	88	8216.81	2.02	89.00	2.0	1.12	34	6.00	1.24	362.70	1.60	DH
10-Apr	11:40	367444	58	8218.83	1.33	8.00/160.0	1.0	1.41	28/100	4.00	1.45	1.10/438.	1.60	DH
11-Apr	11:40	367502	60	8220.16	1.36	159.00	1.0	1.21	96	96.00	1.13	437.00	1.10	DH
12-Apr	11:40	367562	58	8221.52	1.33	158.00	1.0	1.51	92	2.00	1.32	435.70	0.90	DH
13-Apr	11:40	367620	56	8222.85	1.3	157.00	2.0	1.83	90	4.00	1.34	434.80	0.90	DH
14-Apr	11:40	367676	57	8224.15	1.29	155.00	1.0	2.06	86	4.00	1.38	433.90	1.30	DH
15-Apr	11:40	367733	57	8225.44	1.31	154.00	1.0	1.80	82	4.00	1.62	432.60	1.10	DH
16-Apr	11:40	367790	86	8226.75	1.99	153.00	1.0	1.76	78	6.00	1.13	431.50	1.30	DH
17-Apr	11:40	367876	59	8228.74	1.36	152.00	1.0	1.45	72	4.00	1.18	430.20	1.20	DH
18-Apr	11:40	367935	60	8230.1	1.36	151.00	1.0	1.44	68	4.00	1.03	429.00	1.10	DH
19-Apr	11:40	367995	58	8231.46	1.34	150.00	1.0	1.32	64	4.00	1.14	427.90	1.50	DH
20-Apr	11:40	368053	57	8232.8	1.3	149.00	1.0	1.27	60	2.00	1.02	426.40	0.80	DH
21-Apr	11:40	368110	58	8234.1	1.34	148.00	1.0	1.03	58	4.00	0.90	425.60	0.90	DH
22-Apr	11:40	368168	58	8235.44	1.34	147.00	1.0	1.06	54	2.00	1.00	424.70	1.20	DH
23-Apr	11:40	368226	87	8236.78	1.99	146.00	1.0	1.08	52	6.00	0.88	423.50	1.60	DH
24-Apr	11:40	368313	59	8238.77	1.37	145.00	2.0	1.56	46	4.00	1.32	421.90	1.30	DH
25-Apr	11:40	368372	59	8240.14	1.31	143.00	1.0	1.48	42	2.00	1.24	420.60	1.40	DH
26-Apr	11:40	368431	87	8241.45	2.06	142.00	2.0	1.51	40	8.00	1.15	419.20	1.20	DH
27-Apr	11:40	368518	88	8243.51	2.01	140.00	2.0	1.62	32	4.00	1.22	418.00	1.70	DH
28-Apr	11:40	368606	41	8245.52	0.87	138.00	1.0	1.96	28/100	2.00	0.90	416.30	0.70	DH
29-Apr	11:40	368647	46	8246.39	1.11	137.00	0.0	1.51	98	2.00	1.17	415.60	1.00	DH
30-Apr	11:40	368693	87	8247.5	2.02	137.00	3.0	2.06	96	6.00	1.13	414.60	1.60	DH
1-May	11:40	368780	0	8249.52	0	134.00	0.0	1.46	90	0.00	1.11	413.00	0.00	DH
TOT				1915						48.49		39.15		
AVE				62						1.52		1.22		
MAX				89						2.07		1.82		
MIN				0						1.03		0.88		

SIGNATURE:  
 PHONE: 815-224-1650

Jon Stear

VILLAGE OF POPLAR GROVE - SOUTH  
 FOR THE MONTH OF APRIL 2023  
 ILLINOIS ENVIRONMENTAL PROTECTION AGENCY  
 DIVISION OF PUBLIC WATER SUPPLIES

IL0070300  
 MONTHLY OPERATING REPORT

Date	Time	Flow Meter Reading Pumpage e	Hour Meter Well 5 Reading	Hours	Hour Meter Well 6 Reading	Hours	Scale	Chlorine Feed lbs Used	Free	Scale	Phosphate Feed lbs Used	PO4 mg/L	Fluoride Feed Scale	Ibs Used	Operator Initials
31-Mar	12:00	581821	0	4066.9	0	4757.95	0	98.00	0.0	1.71	80	0.00	1.00	376.20	DH
1-Apr	12:00	581890	52	4068	0.8	4757.95	0	97.00	1.0	1.55	76	2.00	1.03	375.00	DH
2-Apr	12:00	581942	87	4068.8	1.4	4757.95	0	96.00	2.0	1.32	74	4.00	1.10	373.60	DH
3-Apr	12:00	582029	52	4070.2	0.8	4757.95	0	94.00	1.0	1.35	70	4.00	1.41	371.40	DH
4-Apr	12:00	582081	69	4071	1.1	4757.95	0	93.00	1.0	1.50	66	2.00	0.85	370.40	DH
5-Apr	12:00	582150	68	4072.1	1	4757.95	0	92.00	2.0	1.54	64	4.00	0.88	368.40	DH
6-Apr	12:00	582218	53	4073.1	0.8	4757.95	0	90.00	1.0	1.49	60	4.00	0.76	366.80	DH
7-Apr	12:00	582271	69	4073.9	1.1	4757.95	0	89.00	1.0	1.53	56	2.00	0.77	365.60	DH
8-Apr	12:00	582340	69	4075	1.1	4757.95	0	88.00	1.0	1.51	54	4.00	0.64	364.20	DH
9-Apr	12:00	582409	105	4076.1	1.6	4757.95	0	87.00	1.0	1.41	50	6.00	0.80	362.40	DH
10-Apr	12:00	582514	70	4077.7	1	4757.95	0	5.00/160.0	1.0	1.57	44	2.00	0.91	50.00/455	DH
11-Apr	12:00	582584	68	4078.7	1.1	4757.95	0	159.00	1.0	1.94	42	4.00	0.89	453.20	DH
12-Apr	12:00	582652	68	4079.8	1	4757.95	0	158.00	0.0	1.89	38	6.00	0.81	452.00	DH
13-Apr	12:00	582720	86	4080.8	1.4	4757.95	0	158.00	1.0	0.00	34	4.00	0.95	450.60	DH
14-Apr	12:00	582806	51	4082.2	0.7	4757.95	0	157.00	2.0	2.00	30	4.00	0.83	448.60	DH
15-Apr	12:00	582857	86	4082.9	1.6	4757.95	0	155.00	2.0	2.00	28/100	2.00	0.96	447.40	DH
16-Apr	12:00	582943	105	4084.5	1.4	4757.95	0	153.00	3.0	2.00	96	4.00	0.75	445.70	DH
17-Apr	12:00	583048	69	4085.9	1	4757.95	0	150.00	1.0	2.00	90	4.00	0.85	443.60	DH
18-Apr	12:00	583117	68	4086.9	1.1	4757.95	0	149.00	2.0	1.55	86	4.00	0.83	441.80	DH
19-Apr	12:00	583185	70	4088	1.1	4757.95	0	147.00	1.0	1.58	82	2.00	0.88	440.20	DH
20-Apr	12:00	583255	52	4089.1	0.8	4757.95	0	146.00	1.0	1.45	80	4.00	0.76	438.60	DH
21-Apr	12:00	583307	69	4089.9	1	4757.95	0	145.00	2.0	1.81	76	2.00	0.83	437.40	DH
22-Apr	12:00	583376	68	4090.9	1.1	4757.95	0	143.00	1.43	1.48	74	4.00	0.89	436.00	DH
23-Apr	12:00	583444	70	4092	1.1	4757.95	0	142.00	1.0	1.22	70	4.00	0.90	434.40	DH
24-Apr	12:00	583514	70	4093.1	1	4757.95	0	141.00	2.0	1.75	66	2.00	0.72	432.80	DH
25-Apr	12:00	583584	71	4094.1	1	4757.95	0	139.00	1.0	1.65	64	3.00	0.78	431.20	DH
26-Apr	12:00	583655	68	4095.1	1.2	4757.95	0	138.00	1.0	1.55	61	3.00	0.80	430.00	DH
27-Apr	12:00	583723	85	4096.3	1.3	4757.95	0	137.00	1.0	1.45	58	6.00	0.91	427.80	DH
28-Apr	12:00	583808	53	4097.6	0.8	4757.95	0	136.00	1.0	1.34	52	2.00	0.96	425.60	DH
29-Apr	12:00	583861	69	4098.4	1.1	4757.95	0	135.00	2.0	1.40	50	4.00	1.02	424.40	DH
30-Apr	12:00	583930	88	4099.5	1.3	4757.95	0	133.00	1.0	1.51	46	6.00	0.75	423.20	DH
1-May	12:00	584018	0	4100.8	0	4757.95	0	132.00	1.81	40	0.00	1.51	421.20	0.00	
TOT													49.86	28.73	
AVE													1.56	0.90	
MAX													2.00	1.51	
MIN													0.00	0.64	

SIGNATURE: \_\_\_\_\_  
 PHONE: 815-224-1650

Ion Stear