



January 5, 2022

Client: Village of Poplar Grove
Attn: Don Sattler, Village President
200 Hill Street
P.O. Box 01
Poplar Grove, IL 61065

2323 Fourth Street
P.O. Box 483
Peru, Illinois 61354
815-224-1650
800-659-4659
FAX 815-224-1688
www.testinc.com

Plant Type: Wastewater Treatment Plants: North: Class II Sequential batch reactors (SBR).
South: Class I Sequential batch reactors (SBR).
Water Treatment Plants: Well Supply with Chemical Addition in all 3 locations

For the water system you will find attached the daily inspection and monitoring reports for each of the water plants and the distribution system testing record. For the wastewater side we have included the monthly DMR for both wastewater plants.

Outlined below are the processes and actions taken during December 2021 in Poplar Grove to improve the facilities equipment beyond required and routine maintenance, testing, inspection and reporting. At times we will also list upcoming needed improvements that may need attention by the Village.

Lift Stations:

- Rush power came out and PMed the generator.
- Pulled floats and cleaned grease off of them.

North WWTP:

- Fixed level transducer that was working inconsistently for influent flow. Decanted digesters.
- Pulled all floats and transducers, clean rags off of them
- Had evergreen come out to help remove all the pin floc and put it in the digester where it can be disposed of.
- Because of the screen being down we are manually raking the bar screen.
- Did a major clean at the north plant.
- Rush power came out and PMed the generator.

South WWTP:

- Sent sludge to drying bed.
- All heat trace and cold weather precautions have been taken.
- Rush power came out and PMed the generators

Water System:

- We Installed shelves as work benches at the well houses to work off of, rather than the old school desk that were there.

All operations and plant inspections have been performed by me or under my direct supervision. As always, if you have any questions concerning the above, please do not hesitate to contact me.

Submitted by,
Total Environmental Service Technologies, Inc.
Ion Stear
Certified Operator/Manager

VILLAGE OF POPLAR GROVE
DAILY DISTRIBUTION MONITORING REPORT
FOR THE MONTH OF November 2021
ILLINOIS ENVIRONMENTAL PROTECTION AGENCY
DIVISION OF PUBLIC WATER SUPPLIES

Date	North System (Wells 2 & 3)				West System (Well 4)				South System (Wells 5 & 6)				Operator Initials	1.0 mg/L Standard	Fluoride Analysis			
	Site #	Free Cl ₂	Total Cl ₂	PO ₄	Site #	Free Cl ₂	Total Cl ₂	PO ₄	Site #	Free Cl ₂	Total Cl ₂	PO ₄			Well #2	Well #3	Well #4	Well #5-6
1																0.47	1.40	1.06
2	ELM	0.61		1.36	Gas	0.37		0.62	Tower	0.58		1.76	JS			0.46	0.99	1.01
3	Tower	0.82		0.77	Garage	0.57		0.7	Tower	0.55		1.29	JS			0.49	1.15	1.09
4	Tower	0.67		0.96	tower	0.7		0.71	Tower	0.43		1.26	KL			0.46	0.89	0.98
5	Tower	0.55		0.61	tower	0.76		1.13	Tower	0.75		1.15	JS			0.44	0.81	0.98
6																0.46	0.98	1.04
7																0.45	1.40	0.98
8	ELM	0.33		1.47	Gas	0.3		0.77	Tower	0.59		1.13	JS			0.44	0.84	0.94
9	Tower	0.66		1.24	Tower	0.58		1.15	Tower	0.73		1.33	JS			0.44	0.80	0.88
10	Tower	0.74		1.48	Garage	0.37		0.71	Tower	0.71		1.08	JS			0.45	0.83	0.97
11	Village	0.21		1.63	Tower	0.6		1.01	Tower	0.78		1.07	JS			0.47	0.84	1.02
12	Tower	0.59		1.24	Tower	0.7		1.1	Tower	0.74		2	JS			0.45	0.74	0.92
13																2.00	0.79	0.55
14																0.88	0.77	0.71
15	Tower	0.62		1.1	Tower	0.53		0.79	Tower	0.63		1.15	KL			1.01	1.08	1.02
16	ELM	0.41		1.12	Garage	0.35		1.11	Tower	0.63		1.32	JS			1.14	0.81	1.09
17	Tower	0.77		0.5	Tower	0.51		1.28	Tower	0.61		1.82	JS			0.93	0.82	0.99
18	Village	0.41		0.9	Garage	0.4		0.65	Tower	0.77		1.96	JS			0.82	0.85	0.96
19	Tower	0.69		1.14	Tower	0.8		1.38	Tower	0.8		1.1	JS			0.95	0.77	1.00
20																3.00	0.78	0.76
21																3.40	0.78	0.72
22	Tower	0.74		1.01	Gas Station	0.36		1.04	Tower	0.78		1.01	KL			0.21	0.68	0.70
23	Village	0.4		1.81	Garage	0.32		1.29	Tower	0.77		1.04	KL			2.00	0.97	0.86
24	Tower	0.66		1.89	Tower	1		1.19	Tower	0.8		0.91	KL			2.00	0.93	0.94
25																2.20	0.93	1.01
26																2.00	1.02	0.90
27																2.10	0.75	0.61
28																2.00	0.88	0.92
29	ELM	0.1		1.38	Gas	0.13		0.79	Tower	0.7		0.72	JS			2.20	0.88	0.96
30	Tower	0.57		0.73	Tower	0.64		0.89	Tower	0.64		0.89	JS			2.10	0.92	0.92



Signature: _____ Ion Stear

PHONE: 815-224-1650

IL0070350

Ion Stear

SIGNATURE: _____
PHONE: 815-224-1650

VILLAGE OF POPLAR GROVE - SOUTH
FOR THE MONTH November 2021
ILLINOIS ENVIRONMENTAL PROTECTION AGENCY
DIVISION OF PUBLIC WATER SUPPLIES

IL0070300
MONTHLY OPERATING REPORT

Date	Time	Flow Meter		Hour Meter Well 4		Hour Meter Well 5		Scale	Chlorine Feed		Free	Scale	Phosphate Feed		Flouride Feed		Operator Initials
		Reading	Pumpage	Reading	Hours	Reading	Hours		lbs Used				lbs Used		Scale	lbs Used	
31-Oct		541348	62	3429	1.1	4751.30	0	152.00	2.0		1.00	112	2.00		444.00	1.80	JS
1		541410	86	3430.1	1	4751.30	0	150.00	1.0		1.06	110	4.00		442.20	2.20	JS
2	07:20	541496	53	3431.1	1.2	4751.30	0	149.00	1.0		1.24	106	2.00		440.00	1.00	JS
3	07:25	541549	54	3432.3	0.8	4751.30	0	148.00	1.0		1.13	104	3.00		439.00	1.60	JS
4	10:51	541603	93	3433.1	1.5	4751.30	0	147.00	0.0		0.79	101	2.00		437.40	2.20	KL
5	08:50	541696	44	3434.6	0.7	4751.30	0	147.00	1.0		1.11	99	1.00		435.20	1.20	JS
6	09:15	541740	46	3435.3	0.7	4751.30	0	146.00	1.0		0.98	98	5.00		434.00	0.80	KL
7	08:05	541786	95	3436	1.5	4751.30	0	145.00	1.0		1.03	93	1.00		433.20	2.60	KL
8	08:55	541881	70	3437.5	1	4751.30	0	144.00	1.0		0.81	92	3.00		430.60	1.60	JS
9	08:45	541951	75	3438.5	1.3	4751.30	0	143.00	1.0		1.44	89	3.00		429.00	2.00	JS
10	08:45	542026	52	3439.8	0.8	4751.30	0	142.00	1.0		0.83	86	2.00		427.00	1.20	JS
11	07:12	542078	54	3440.6	0.8	4751.30	0	141.00	0.0		0.82	84	2.00		425.80	1.40	JS
12	09:12	542132	55	3441.4	0.9	4751.30	0	141.00	1.0		0.98	82	3.00		424.40	1.20	JS
13	08:25	542187	99	3442.3	1.6	4751.30	0	140.00	1.0		0.84	79	5.00		423.20	2.60	JS
14	09:30	542286	54	3443.9	0.8	4751.30	0	139.00	1.0		0.85	74	2.00		420.60	1.20	JS
15	08:20	542340	92	3444.7	1.5	4751.30	0	138.00	0.0		0.78	72	4.00		419.40	2.20	KL
16	09:00	542432	55	3446.2	0.8	4751.30	0	138.00	0.5		1.15	67	2.00		415.80	1.40	JS
17	09:00	542487	56	3447	0.9	4751.30	0	138.00	0.0		0.59	65/120	3.00		414.40	2.00	JS
18	09:00	542543	67	3447.9	1	4751.30	0	137.50	0.0		1.02	117	4.00		412.40	1.80	JS
19	09:10	542610	78	3448.9	1.3	4751.30	0	142.00	4.5		1.43	113	2.00		410.60	1.40	KL
20	08:50	542688	46	3450.2	0.7	4751.30	0	140.00	1.0		0.96	111	1.00		409.20	2.00	KL
21	08:00	542734	95	3450.9	1.5	4751.30	0	140.00	1.0		1.12	110	2.00		407.20	1.80	KL
22	08:30	542829	57	3452.4	0.9	4751.30	0	139.00	1.0		1.16	108	4.00		405.40	2.00	KL
23	08:15	542886	88	3453.3	1.4	4751.30	0	138.00	0.0		0.84	104	2.00		403.40	1.60	KL
24	08:15	542974	72	3454.7	1.1	4751.30	0	138.00	1.0		1.02	102	3.00		401.80	2.60	KL
25	08:10	543046	110	3455.8	1.8	4751.30	0	137.00	0.0		1.21	99	3.00		399.20	2.00	KL
26	08:00	543156	72	3457.6	1.1	4751.30	0	137.00	0.0		1.11	96	2.00		397.20	2.20	JS
27	08:55	543228	80	3458.7	1.3	4751.30	0	140.00	-3.0		1.10	94	4.00		395.00	2.60	JS
28	09:08	543308	92	3460	1.4	4751.30	0	142.00	-2.0		0.08	90	3.00		392.40	1.80	JS
29	09:00	543400	81	3461.4	1.3	4751.30	0	141.00	1.0		0.79	87	87.00		390.60	390.60	JS
30	09:05	543481		3462.7		4751.30											
TOT			2133				0				30.16						27.71
AVE			71				0				0.97						0.89
MAX			110				0				1.44						2.00
MIN			13				0				0.08						0.46

SIGNATURE:  Jon Stear
PHONE: 815-224-1650

VILLAGE OF POPLAR GROVE - NORTH
 FOR THE MONTH OF November 2021
 ILLINOIS ENVIRONMENTAL PROTECTION AGENCY
 DIVISION OF PUBLIC WATER SUPPLIES

11.0070150
 MONTHLY OPERATING REPORT

Date	Time	Flow Meter Reading	Pumpage	Hour Meter Well 2 Reading	Hours	Scale	Chlorine Feed lbs Used	Free	Scale	Phosphate Feed lbs Used	PO4 mg/L	Scale	Flouride Feed lbs Used	Operator Initials
31-Oct	08:40	298530527	157918	10062.1	0	26083.80	1.0	0.56	81	7.00	0.05	47.00	-4.0	JS
1	08:00	298688445	122566.3	10062.1	0	26097.50	2.0	0.82	74	5.00	1.41	51.00	0.0	JS
2	09:00	298811011.3	92428.3	10062.1	0	26097.50	0.0	0.72	69	4.00	0.81	51.00	0.0	JS
3	08:10	298903439.6	159043.1	10062.1	0	26102.00	2.0	0.82	65	5.00	0.77	51.00	0.0	JS
4	08:15	299062482.7	97594	10062.1	0	26109.80	0.0	0.67	60	4.00	0.96	51.00	0.0	KL
5	07:20	299160076.7	98364.2	10062.1	0	26114.60	1.0	0.55	56/100	6.00	0.61	51.00	0.5	JS
6	08:35	299258440.9	155951.1	10062.1	0	26119.30	1.0	0.46	94	4.00	0.80	50.50	0.5	KL
7	07:35	299414392	124742.5	10062.1	0	26126.90	1.0	0.66	90	4.00	1.27	50.00	0.0	KL
8	07:30	299539134.5	142630.9	10062.1	0	26133.00	1.0	0.67	86	4.00	1.35	50.00	0.0	JS
9	07:10	299681765.4	106531.2	10062.1	0	26140.00	1.0	0.66	82	3.00	1.24	50.00	-1.0	JS
10	07:25	299788296.6	150359.6	10062.1	0	26145.20	0.0	0.74	79	7.00	1.48	51.00	0.0	JS
11	08:55	299938566.2	116390.4	10062.1	0	26152.60	2.0	0.73	72	5.00	1.02	51.00	0.0	JS
12	07:25	300035046.6	89842.4	10062.1	0	26158.30	0.0	0.59	67	3.00	1.24	51.00	6.0	JS
13	07:40	300144889	146449.7	10062.1	0	26162.70	1.0	0.66	64	6.00	0.70	45.00	9.0	JS
14	08:45	300291338.7	121356.9	10062.1	0	26169.80	1.0	0.76	58/90	2.00	1.53	36.00	7.0	JS
15	07:00	300412695.6	128878.5	10062.1	0	26175.80	1.0	0.62	88	6.00	1.10	29.00	5.7	KL
16	07:35	300541574.1	136814.4	10062.1	0	26182.00	1.0	0.79	82	6.00	1.01	23.30	5.3	JS
17	07:15	300678388.5	93710.7	10062.1	0	26188.80	0.0	0.77	76	3.00	0.50	18.00	3.5	JS
18	07:30	300772099.2	120012.3	10062.1	0	26193.40	1.0	0.71	73	4.00	0.84	14.50	3.5	JS
19	07:15	300892111.5	134115.8	10062.1	0	26199.20	2.0	0.69	69	6.00	1.14	11.00	2.0	JS
20	07:20	301026227.3	104994.6	10062.1	0	26205.80	1.0	0.61	63	2.00	0.93	9.00	3.5	KL
21	07:20	301131221.9	172793	10062.1	0	26210.90	1.0	0.50	61	8.00	1.12	5.50	1.0	KL
22	07:10	301304014.9	93770.9	10062.1	0	26219.40	1.0	0.74	53	2.00	1.01	4.50	2.5	KL
23	07:10	301397785.8	144102.6	10062.1	0	26224.00	1.0	0.55	51	2.00	0.86	2/51	2.0	KL
24	07:15	301541888.4	113048.2	10062.1	0	26231.00	1.0	0.66	49	6.00	1.89	49.00	3.0	KL
25	07:15	301654936.6	142062.9	10062.1	0	26236.60	0.0	0.51	43	4.00	0.72	46.00	3.0	KL
26	07:00	301796999.5	129654.1	10062.1	0	26243.50	1.0	0.65	39	6.00	0.83	43.00	3.0	KL
27	08:10	301926653.6	112104.2	10062.1	0	26249.90	1.0	0.61	33/80	3.00	0.65	40.00	2.5	JS
28	08:30	302038757.8	165425.8	10062.1	0	26255.40	1.0	0.59	77	5.00	1.10	37.50	3.5	JS
29	07:30	302204183.6	103033.9	10062.1	0	26263.50	1.0	0.64	72	4.00	0.85	34.00	1.0	JS
30	07:22	302307217.5		10062.1		26268.50		0.57	68		0.73	33.00		JS
TOT			3776691					20.28						
AVE			125890		185			0.65						
MAX			172793		6			0.82						
MIN			89142		14			0.46						
					0									

SIGNATURE:  Jon Shear
 PHONE: 815-224-1650

Permit	IL0071447	Permittee:	POPULAR GROVE, VILLAGE OF	Facility:	POPULAR GROVE SOUTH STP, VILLAGE OF						
Permit #:	Yes	Permittee Address:	200 S HILL ST POPULAR GROVE, IL 61065	Facility Location:	12211 STATE ROUTE 76 POPULAR GROVE, IL 61065						
Major:											
Permitted Feature:	INF Influent Structure	Discharge:	INF-L INFLUENT MONITORING								
Report Dates & Status	From 11/01/21 to 11/30/21	DMR Due Date:	12/25/21	Status:	NetDMR Validated						
Monitoring Period:											
Considerations for Form Completion											
BOW ID: W0070150006											
Principal/Executive Officer											
First Name:	Ion	Title:									
Last Name:	Stear										
No Data Indicator (NODI)											
Form NODI:											
Cat#	Parameter Name	Monitoring Location	Season & Param. NODI	Quantity of Sampling	Quality or Concentration	# of Ex.	Sample Type				
				Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units	
00310	BOD, 5-day, 20 deg. C	G - Raw Sewage Influent	0	-							
				Sample	Permit Req.	Value NODI					
				Permit Req.	Value NODI						
				Sample	Permit Req.	Value NODI					
				Permit Req.	Value NODI						
00530	Solids, total suspended	G - Raw Sewage Influent	0	-							
				Sample	Permit Req.	Value NODI					
				Permit Req.	Value NODI						
				Sample	Permit Req.	Value NODI					
				Permit Req.	Value NODI						
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	-							
				Sample	Permit Req.	Value NODI					
				Permit Req.	Value NODI						
				Sample	Permit Req.	Value NODI					
				Permit Req.	Value NODI						
50050	Flow, in conduit or thru treatment plant	G - Raw Sewage Influent	0	-							
				Sample	Permit Req.	Value NODI					
				Permit Req.	Value NODI						
				Sample	Permit Req.	Value NODI					
				Permit Req.	Value NODI						

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

No errors.

Comments

Attachments

Report Last Saved By

User:

Name, ebumnamer@teslinc.com
E-Mail, Claire Dunnington

Date	Time	Duration	Cost	Notes
2021-12-08	13:51	1:10	00.00	

Users: _____

E-Mail: istat@testing.com
0034 43 47 4426

Date/Time: 2021-12-17 11:36 (Time Zone: -06:00)

DMR Copy of Record

Permit #: Major:	IL0071447 Yes	Permittee: Permittee Address:	POPLAR GROVE, VILLAGE OF 200 S HILL ST POPLAR GROVE, IL 61065	Facility: Facility Location:	POPLAR GROVE SOUTH STP, VILLAGE OF 12211 STATE ROUTE 76 POPLAR GROVE, IL 61065
Permitted Feature:	001 External Outfall	Discharge:	001-0 STP OUTFALL		
Report Dates & Status					
Monitoring Period:	From 11/01/21 to 11/30/21	DMR Due Date:	12/25/21	Status:	Not DMR Validated
Considerations for Form Completion					
BOW ID: W0070150006; DMF LOAD LIMITS DISPLAYED.					
Principal Executive Officer					
First Name:	Ion	Title:			
Last Name:	Stear				
No Data Indicator (NOD)					
Telephone:	815-224-1650				

Code	Parameter Name	Monitoring Location	Reason # Param. NOD	Sample Permit Req	Value NOD	Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 3	Value 3	Units	# of Ex.	Frequency of Analysis	Sample Type
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	1	-	-	-	-	-	-	-	-	-	-	-	03DW - 3 Days Every Week	GR - GRAB
00400	pH	1 - Effluent Gross	0	-	-	-	-	-	-	-	-	-	-	-	03DW - 3 Days Every Week	GR - GRAB
00530	Solids, total suspended	1 - Effluent Gross	0	-	-	-	-	-	-	-	-	-	-	-	03DW - 3 Days Every Week	CP - COMPOS
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	-	-	-	-	-	-	-	-	-	-	-	0130 - Monthly	CP - COMPOS
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	2	-	-	-	-	-	-	-	-	-	-	-	03DW - 3 Days Every Week	CP - COMPOS
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	-	-	-	-	-	-	-	-	-	-	-	03DW - 3 Days Every Week	CP - COMPOS
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	-	-	-	-	-	-	-	-	-	-	-	9999 - Continuous	CP - COMPOS
50060	Chlorine, total residual	1 - Effluent Gross	0	-	-	-	-	-	-	-	-	-	-	-	9999 - Continuous	GR - GRAB
80082	BOD, carbonaceous (5 day, 20 C)	1 - Effluent Gross	0	-	-	-	-	-	-	-	-	-	-	-	03DW - 3 Days Every Week	CP - COMPOS

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Code	Parameter Name	Monitoring Location	Field	Type	Description	Acknowledge
00400	pH	1 - Effluent Gross	Quality or Concentration Sample Value 1	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct.	Yes
Comments						
Attachments						
No attachments						

DMR Copy of Record

Permit #:	IL0023451	Permittee:	POPLAR GROVE, VILLAGE OF	Facility:	POPLAR GROVE - NORTH WWTP, VILLAGE OF
Major:	No	Permittee Address:	PO BOX 1 POPLAR GROVE, IL 61065	Facility Location:	205 EDSON RD POPLAR GROVE, IL 61065
Permitted Feature:	INF Influent Structure	Discharge:	INF-L INFLUENT MONITORING	Status:	NetDMR Validated
Report Dates & Status		DMR Due Date:	12/25/21		
Monitoring Period:	From 11/01/21 to 11/30/21				
Considerations for Form Completion					
BOW ID: W0070150007					
Principal Executive Officer					
First Name:	Ion	Title:		Telephone:	815-224-1650
Last Name:	Stear				
No Data Indicator (NODI)					

Code	Parameter Name	Monitoring Location	Season & Month NODI	Sample Permit Req. Value NODI	Quantity or Loading	Quality or Concentration	Units	Qualifier 1 Value 1	Qualifier 2 Value 2	Qualifier 3 Value 3	Units	# of Ex.	Frequency of Analysis	Sample Type
00310	BOD, 5-day, 20 deg. C	G - Raw Sewage Influent	0	--										
				Sample Permit Req. Value NODI										
00530	Solids, total suspended	G - Raw Sewage Influent	0	--										
				Sample Permit Req. Value NODI										
50050	Flow, in conduit or thru treatment plant	G - Raw Sewage Influent	0	--										
				Sample Permit Req. Value NODI										

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments
No attachments

Report Last Saved By
POPLAR GROVE, VILLAGE OF

User: ebungamer
Name: Elaine Bungamer
E-Mail: ebungamer@testing.com
Date/Time: 2021-12-08 13:35 (Time Zone: -06:00)

Report Last Signed By

User: IONSTEAR
Name: Ion Stear
E-Mail: istear@testing.com
Date/Time: 2021-12-17 11:38 (Time Zone: -06:00)

DMR Copy of Record

Permit		Permittee:		Facility:		Frequency of Analysis:	
Permit #:	IL0023451	POPLAR GROVE, VILLAGE OF		POPLAR GROVE - NORTH WWTP, VILLAGE OF			
Major:	No.	PO BOX 1		205 EDSON RD			
		POPLAR GROVE, IL 61065		POPLAR GROVE, IL 61065			
Permitted Feature:		Discharge:		Status:		Telephone:	
001-0		STP OUTFALL		12/25/21		815-224-1650	
Report Dates & Status		DMR Due Date:		Status:			
Monitoring Period:		11/01/21 to 11/30/21		NeDMR Validated			
Considerations for Form Completion							
BOW ID: W0070150007, DMF LOAD LIMITS DISPLAYED, MONITORING LOCATION *1* IS FORMONTHLY AVERAGE AND DAILY MAXIMUM MONITORING LOCATION *8* IS FORWEEKLY AVERAGE.							
Principal Executive Officer							
First Name:		Ion					
Last Name:		Stear					
No Data Indicator (NODI)							
Form NODI:							
Parameter Name		Monitoring Location Season #		Sample Permit Reg.		Sample Type	
00300 Oxygen, dissolved [DO]		1 - Effluent Gross 1		Value NODI		02DA - 2 Days Every Week GR - GRAB	
00400 pH		1 - Effluent Gross 0		Value NODI		02DA - 2 Days Every Week GR - GRAB	
00530 Solids, total suspended		1 - Effluent Gross 0		Value NODI		02DA - 2 Days Every Week CP - COMPOS	
00610 Nitrogen, ammonia total [as N]		1 - Effluent Gross 1		Value NODI		02DA - 2 Days Every Week CP - COMPOS	
50050 Flow, in conduit or thru treatment plant		1 - Effluent Gross 0		Value NODI		9999 - Continuous	
50060 Chlorine, total residual		1 - Effluent Gross 0		Value NODI		9999 - Continuous	
80082 BOD, carbonaceous [5 day, 20 C]		1 - Effluent Gross 0		Value NODI		02DA - 2 Days Every Week CP - COMPOS	
Submission Note							
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.							
Edit Check Errors							
No errors.							
Comments							
Attachments							
No attachments							
Report Last Saved By							
PCPLAR GROVE, VILLAGE OF							
User:		ebungamer					
Name:		Elaine Bungamer					
E-Mail:		ebungamer@estinc.com					
Date/Time:		2021-12-08 13:42 (Time Zone: -06:00)					
Report Last Signed By							
User:		IONSTEAR					