September 2, 2020

TEST Inc.
2323 Fourth Street
P.O. Box 483
Peru, Illinois 61354
815-224-1650
800-659-4659
FAX 815-224-1688
www.testinc.com

Client: Village of Poplar Grove
Attn: Owen Costanza, Village President
200 Hill Street
P.O. Box 01
Poplar Grove, IL 61065

Plant Type: Wastewater Treatment Plants: North: Class II Sequential batch reactors (SBR).
South: Class I Sequential batch reactors (SBR).
Water Treatment Plants: Well Supply with Chemical Addition in all three locations

Enclosed you will find the daily inspection and monitoring reports for each water plant, the distribution system testing record.

Outlined below is the flow at each wastewater plant and the actions taken during the past month in Poplar Grove to improve the facilities equipment.

Wastewater flow information:

South Wastewater Plant Discharge Totals (July 2020)

Influent:	Total:	5.053	MG	**Effluent:**	Total:	8.649	MG
	Ave:	0.163	MGD		Ave:	0.279	MGD

North Wastewater Plant Discharge Totals (July 2020)

Influent:	Total:	11.904	MG	**Effluent:**	Total:	12.803	MG
	Ave:	0.384	MGD		Ave:	0.413	MGD

Improvements Completed August 2020

Lift Stations:

- All pumps manually tested.
- Dry wells have been inspected.
- Inspected wet well areas & floats and cleaned as needed.
- Collins came out to finish cleaning the lift stations they didn't get to the last time they were here.
- All routine checks and tests performed for the month.
- Tested all alarm functions on lift stations to insure there working as they should.
- Test ran all generators under load to insure they will work when needed.

North WWTP:

- SBR 4 was starting to get some foam on it, we bought and have been using Foam buster and Quikzyme to remove it and it has been working.
- We repositioned the broken mount for the decanter on SBR1
- Took SBR1 down to reattach the broken decanter mount to the floor.
- Did a lot of "housekeeping" cleaning.
- Had an issue with a digester blower, it's under warranty, Hardy pro air came out and inspected it and said we needed and new pulley because it's out of balance and wore.

- All process control testing has been don't to insure the ideal operation of the plant.
- Cleaned spray nozzles on inlet screen.
- Exercised/cleaned all emergency eye and body wash stations.
- Cleaned rags and build up out of inlet screen.
- Decanted digesters.
- Exercised portable generators.
- All Required IEPA testing was completed for the month.

South WWTP:

- Did a bunch of "housekeeping" cleaning. Sweeping, cleaning cob webs, weed trimming and pulling.
- Received quotes from 3 different vendors to replace the bad digester blower at the south plant. W.M Meyer and sons was the best price. Blower was ordered and has a lead time of 5-6 weeks.
- Transferred sludge to drying bed. Cleaned scum out of sand filter channels.
- Exercised/ cleaned all emergency eye and body wash stations.
- All process control has been done to ensure the plant is running optimum.
- Transferred sludge to Digester #3 from Digester 1 and 2 to thicken.
- Decanted all 3 digesters.
- All Required IEPA testing was completed for the month.

Water System:

- Cleaned the inside base of all the water towers.
- Sampled all the bac-t's necessary for the water main project on 173.
- Fixed Fluoride pump at well 3.
- Changed chemical line at well 3.
- Fixed fluoride line leak at well 4.
- Clean all dust and cobwebs from well houses.
- Tested/ cleaned all emergency eye and body wash stations.
- All water plant numbers and chemicals were checked daily and adjusted if necessary.
- Hawkins came and filled up all our chemicals.
- All required IEPA testing was completed during the past month.
- All normal checks and cleaning was done at the well house and towers, garbage emptied, Thermostats checked for working order.

All operations and plant inspections have been performed by me or under my direct supervision. If you have any questions concerning the above, please do not hesitate to contact me.

Submitted by,
Total Environmental Service Technologies, Inc.

Ion Stear
Certified Operator/Manager

TEST Inc.

VILLAGE OF POPLAR GROVE - WEST
FOR THE MONTH OF 2020
ILLINOIS ENVIRONMENTAL PROTECTION AGENCY
DIVISION OF PUBLIC WATER SUPPLIES

IL0070350
MONTHLY OPERATING REPORT

Date	Time	Flow Meter		Hour Meter Well 4		Chlorine Feed			Phosphate Feed			Flouride Feed		Operator
		Reading	Pumpage	Reading	Hours	Scale	lbs Used	Free	Scale	lbs Used	PO4 mg/L	Scale	lbs Used	
30-Jun	8:59	309452	63	6902.15	1.43	142.00	0.5	0.34	97	4.00	1.42	395.10	0.90	JS
1	9:01	309515	61	6903.58	1.35	141.50	0.5	0.27	93	4.00	2.00	394.20	0.90	JS
2	8:00	309576	90	6904.93	1.97	141.00	1.0	0.24	89	1.00	1.44	393.30	1.80	IS
3	8:00	309666	54	6906.90	1.16	140.00	1.0	0.52	88	4.00	1.20	391.50	1.50	IS
4	8:00	309720	114	6908.06	2.52	139.00	1.0	0.29	84	2.00	0.57	390.00	3.30	MS
5	8:00	309834	56	6910.58	1.15	138.00	0.0	0.72	82	2.00	0.71	386.70	1.60	MS
6	8:00	309890	83	6911.73	1.88	138.00	1.0	0.43	80	6.00	0.71	385.10	2.40	MS
7	8:00	309973	59	6913.61	1.32	137.00	1.5	0.66	74 / 120	2.00	1.22	382.70	2.20	MS
8	8:38	310032	61	6914.93	1.32	135.50	0.0	0.38	118	4.00	1.45	380.50	2.00	JS
9	8:51	310093	43	6916.25	1.03	134.50	1.0	0.29	114	4.00	1.40	378.50	1.20	JS
10	8:32	310136	135	6917.28	2.85	132.5/103	0.0	0.06	110	9.00	2.00	377.30	3.90	JS
11	9:04	310271	56	6920.13	1.24	103.00	2.0	0.21	101	1.00	1.28	373.40	1.70	JS
12	8:00	310327	68	6921.37	1.45	101.00	0.0	0.12	100	8.00	1.21	371.70	1.80	MS
13	7:30	310395	91	6922.82	2.02	101.00	1.0	0.25	92	6.00	1.08	369.90	3.00	MS
14	8:00	310486	55	6924.84	1.21	100.00	1.0	2.01	86	1.00	1.07	366.90	2.00	MS
15	8:48	310541	58	6926.05	1.25	99.00	1.0	1.21	85	3.00	1.37	364.90	1.70	JS
16	8:36	310599	61	6927.30	1.34	98.00	1.0	1.96	82	6.00	1.36	363.20	1.70	JS
17	8:34	310660	112	6928.64	2.46	97.00	1.5	1.52	76 /132	6.00	1.47	361.50	3.50	JS
18	8:30	310772	59	6931.10	1.3	95.50	0.5	1.65	126	4.00	1.35	358.00	1.50	JS
19	8:00	310831	59	6932.40	1.23	95.00	2.0	1.68	122	7.00	1.17	356.50	1.40	MS
20	8:57	310890	89	6933.63	1.99	93.00	1.0	1.56	115	2.00	1.50	355.10	2.80	JS
21	8:39	310979	58	6935.62	1.27	92.00	0.5	1.10	113	3.00	1.36	352.30	1.80	JS
22	8:38	311037	57	6936.89	1.27	91.50	0.5	1.10	110	4.00	1.13	350.50	1.10	JS
23	8:47	311094	37	6938.16	0.85	91.00	-1.0	1.30	106	2.00	1.16	349.40	1.10	JS
24	8:15	311131	74	6939.01	1.62	92.00	2.0	0.94	104	4.00	1.10	348.30	2.20	MS
25	8:00	311205	50	6940.63	1.07	90.00	0.0	0.99	100	2.00	1.03	346.10	1.90	IS
26	8:00	311255	54	6941.70	1.17	90.00	1.0	1.28	98	4.00	2.11	344.20	1.50	MS
27	8:00	311309	57	6942.87	1.21	89.00	1.0	1.10	94	4.00	1.24	342.70	1.20	MS
28	8:00	311366	56	6944.08	1.2	88.00	1.0	0.92	90	2.00	1.69	341.50	1.80	MS
29	8:00	311422	55	6945.28	1.18	87.00	1.0	0.83	88	0.00	2.35	339.70	1.70	MS
30	8:00	311477	25	6946.46	0.72	86.00	0.0	0.91	88	0.00	1.50	338.00	0.40	MS
31	8:00	311502	95	6947.18	1.96	86.00	1.0	0.95	88	8.00	1.21	337.60	2.70	IS
1	8:00	311597		6949.14		85.00		0.87	80		1.26	334.90		MS
TOT			2050					28.66			44.12			
AVE			66					0.87			1.34			
MAX			135					2.01			2.35			
MIN			25					0.06			0.57			

SIGNATURE:
PHONE: 815-224-1650

Jon Stear

VILLAGE OF POPLAR GROVE - SOUTH
FOR THE MONTH OF 2020
ILLINOIS ENVIRONMENTAL PROTECTION AGENCY
DIVISION OF PUBLIC WATER SUPPLIES

IL0070300
MONTHLY OPERATING REPORT

		Flow Meter		Hour Meter Well 5		Hour Meter Well 6		Chlorine Feed			Phosphate Feed			Flouride Feed		Operator
Date	Time	Reading	Pumpage	Reading	Hours	Reading	Hours	Scale	lbs Used	Free	Scale	lbs Used	PO4 mg/L	Scale	lbs Used	Initials
30-Jun	10:26	496226	103	2723.3	1.5	4756.10	0	132.00	2.0	1.26	114	6.00	0.42	402.00	3.60	JS
1	10:45	496329	96	2724.8	1.5	4756.10	0	130.00	2.0	1.21	108	7.00	1.34	398.40	3.40	JS
2	8:00	496425	184	2726.3	0.8	4756.10	0	128.00	3.0	2.20	101	10.00	1.79	395.00	5.60	IS
3	8:00	496609	89	2727.1	3.5	4756.10	0	125.00	1.0	1.13	91	5.00	1.28	389.40	3.20	IS
4	8:00	496698	140	2730.6	2.1	4756.10	0	124.00	2.0	1.16	86	6.00	0.80	386.20	0.00	MS
5	8:00	496838	146	2732.7	0	4756.10	0	122.00	3.0	4.00	80	8.00	1.78	381.80	4.80	MS
6	8:00	496984	145	2735.0	2.3	4756.10	0	119.00	2.0	1.11	72 /120	10.00	1.08	377.00	4.60	MS
7	8:00	497129	92	2737.3	1.4	4756.10	0.4	117.00	1.0	0.92	110	3.00	0.82	372.40	3.20	JS
8	9:52	497221	88	2738.7	1.4	4756.50	0	116.00	2.0	1.09	107	5.00	1.07	369.20	2.60	JS
9	9:57	497309	93	2740.1	1.4	4756.50	0	114.00	2.0	1.10	102	4.00	0.70	366.60	3.00	JS
10	9:45	497402	93	2741.5	1.5	4756.50	0	112.00	1.0	1.00	98	5.00	0.49	363.60	3.20	JS
11	9:30	497495	94	2743.0	1.4	4756.50	0	111.00	1.0	0.96	93	3.00	0.30	360.40	3.20	JS
12	10:00	497589	153	2744.4	2.4	4756.50	0	110.00	3.0	2.00	90	10.00	1.68	357.60	5.00	MS
13	9:30	497742	98	2746.8	1.5	4756.50	0	107.00	1.0	1.00	80	6.00	1.04	352.60	3.40	MS
14	9:30	497840	140	2748.3	2.3	4756.50	0	106.00	3.0	1.02	74 /120	7.00	0.97	349.20	5.60	JS
15	9:39	497983	51	2750.6	2.8	4756.50	0	103.00	0.5	0.99	113	3.00	0.93	344.80	1.60	JS
16	9:20	498034	97	2753.4	0.1	4756.50	0	102.50	1.5	0.91	110	5.00	0.94	343.20	3.40	JS
17	9:14	498131	146	2753.5	1.7	4756.50	0	101.00	2.0	1.05	105	8.00	1.01	339.80	4.40	JS
18	9:05	498277	132	2755.2	-3	4756.50	0	99.00	2.0	1.07	97	7.00	0.96	335.40	4.20	JS
19	8:00	498409	90	2752.2	6.4	4756.50	0	97.00	2.0	0.25	90	7.00	1.06	331.20	3.40	MS
20	7:36	498499	94	2758.6	1.5	4756.50	0	95.00	1.5	1.18	83	5.00	1.23	327.80	2.80	JS
21	9:31	498595	134	2760.1	0	4756.50	0	93.50	1.5	0.94	78	6.00	0.40	325.00	4.20	JS
22	9:35	498731	93	2762.5	1.2	4756.50	0	92.00	1.5	0.94	72 / 92	4.00	0.99	320.80	3.60	JS
23	8:12	498824	147	2763.7	2.3	4756.50	0	90.50	2.5	0.86	88	8.00	0.70	317.20	4.60	JS
24	8:00	498971	139	2766.0	2.2	4756.50	0	88.00	0.0	1.05	80	6.00	1.16	317.60	9.40	MS
25	8:00	499110	90	2768.2	1.4	4756.50	0	88.00	4.0	0.95	74	4.00	1.03	308.20	3.20	IS
26	8:00	499200	134	2769.6	2.1	4756.50	0	84.00	2.0	0.82	70	6.00	0.93	305.00	4.40	MS
27	8:00	499334	90	2771.7	1.4	4756.50	0	82.00	1.0	0.83	64	8.00	1.15	304.60	6.00	MS
28	8:00	499424	140	2773.1	2.2	4756.50	0	81.00	1.0	0.88	56/78	8.00	1.19	297.60	4.40	MS
29	8:00	499564	92	2775.3	1.4	4756.50	0	80.00	3.0	0.87	70	2.00	1.16	293.20	3.20	MS
30	8:00	499656	141	2776.7	2.2	4756.50	0	77.00	2.0	0.84	68	8.00	1.14	290.00	4.80	MS
31	8:00	499797	133	2778.9	2.1	4756.50	0	75.00	2.0	0.91	60	10.00	1.17	285.20	4.20	IS
1	8:00	499930		2,781.0		4756.50	0	73.00		0.42	50		0.56	281.00		MS
TOT			3697				0			36.92			33.27			
AVE			116				0			1.12			1.01			
MAX			184				0			4.00			1.79			
MIN			51				0			0.25			0.30			

SIGNATURE: Jon Stear
PHONE: 815-224-1650

VILLAGE OF POPLAR GROVE - NORTH
FOR THE MONTH OF 2020
ILLINOIS ENVIRONMENTAL PROTECTION AGENCY
DIVISION OF PUBLIC WATER SUPPLIES

IL0070150
MONTHLY OPERATING REPORT

Date	Time	Flow Meter		Hour Meter Well 2		Hour Meter Well 3		Chlorine Feed			Phosphate Feed			Flouride Feed		Operator Initials
		Reading	Pumpage	Reading	Hours	Reading	Hours	Scale	lbs Used	Free	Scale	lbs Used	PO4 mg/L	Scale	lbs Used	
30-Jun	8:55	234033252.2	148580.9	1006.8	0	23055.80	6.50	134.00	2.0	0.95	115	8.00	0.72	38.00	1.0	JS
1	8:30	234181833.1	130930.9	1006.8	0	23062.30	5.90	132.00	1.0	0.71	107	7.00	0.69	37.00	1.0	JS
2	8:00	234312764.0	129906	1006.8	0	23068.20	5.70	131.00	1.0	0.84	100	7.00	1.05	36.00	0.5	IS
3	8:00	234442670.0	141610	1006.8	0	23073.90	6.12	130.00	2.0	1.26	93	5.00	1.59	35.50	0.5	IS
4	10:30	234584280.0	158483	1006.8	0	23080.02	7.48	128.00	2.0	0.79	88	8.00	0.38	35.00	1.0	MS
5	9:30	234742763.0	159890	1006.8	0	23087.50	6.90	126.00	1.0	1.26	80	8.00	0.65	34.00	1.0	MS
6	9:00	234902653.0	122447	1006.8	0	23094.40	5.40	125.00	1.0	1.13	72	6.00	0.28	33.00	0.5	MS
7	7:00	235025100.0	155832.3	1006.8	0	23099.80	7.00	124.00	2.0	1.20	66 / 120	6.00	1.09	32.50	1.3	MS
8	8:14	235180932.3	162291.7	1006.8	0.1	23106.80	7.10	122.00	4.0	1.07	114	8.00	0.76	31.25	0.8	JS
9	8:27	235343224.0	94423.7	1006.9	0	23113.90	4.30	118.00	3.0	2.12	106	5.00	0.56	30.50	0.5	JS
10	8:10	235437647.7	115463.4	1006.9	0	23118.20	5.20	115.00	2.0	0.81	101	7.00	2.13	30.00	0.5	JS
11	8:36	235553111.1	131020.9	1006.9	0	23123.40	5.80	113.00	3.0	1.74	94	4.00	0.54	29.50	0.5	JS
12	8:00	235684132.0	166272	1006.9	0	23129.20	5.50	110.00	2.0	1.92	90	6.00	0.88	29.00	1.0	MS
13	8:00	235850404.0	71162.5	1006.9	0	23134.70	5.10	108.00	2.0	1.67	84	5.00	0.99	28.00	0.8	MS
14	8:07	235921566.5	123476.7	1006.9	0	23139.80	5.50	106.00	2.0	1.19	79	5.00	1.01	27.25	0.8	JS
15	8:20	236045043.2	129736	1006.9	0	23145.30	5.80	104.00	2.0	1.24	74/120	6.00	0.65	26.50	0.5	JS
16	8:20	236174779.2	129924.5	1006.9	0	23151.10	5.80	102.00	2.0	1.26	114	6.00	1.15	26.00	0.8	JS
17	8:13	236304703.7	139873.2	1006.9	0	23156.90	6.30	100.00	1.0	0.83	108	5.00	0.89	25.25	0.5	JS
18	8:00	236444576.9	161581.1	1006.9	0	23163.20	7.20	99.00	2.0	1.28	103	7.00	1.24	24.75	0.8	JS
19	8:00	236606158.0	108278.3	1006.9	0	23170.40	4.80	97.00	2.0	1.24	96	5.00	0.96	24.00	0.3	JS
20	9:35	236714436.3	102620.1	1006.9	0	23175.20	4.60	95.00	1.5	1.25	91	6.00	0.81	23.75	0.8	JS
21	8:15	236817056.4	112671.6	1006.9	0	23179.80	5.10	93.50	1.5	1.06	85	5.00	1.04	23.00	0.5	JS
22	8:15	236929728.0	163047	1006.9	0	23184.90	7.30	92.00	2.0	0.96	80	8.00	1.28	22.50	0.5	JS
23	8:00	237092775.0	100365	1006.9	0	23192.20	4.60	90.00	2.0	0.93	72	4.00	1.81	22.00	0.8	MS
24	7:30	237193140.0	173311	1006.9	0	23196.80	7.70	88.00	2.0	1.32	68	8.00	0.81	21.25	0.5	MS
25	8:00	237366451.0	131346	1006.9	0	23204.50	5.90	86.00	1.0	1.01	60	6.00	0.89	20.75	0.8	IS
26	8:00	237497797.0	143763	1006.9	0	23210.40	6.50	85.00	1.0	0.97	54	6.00	0.56	20.00	1.0	MS
27	7:00	237641560.0	143090	1006.9	0	23216.90	6.40	84.00	2.0	0.99	50/120	8.00	0.70	19.00	-0.8	MS
28	8:00	237784650.0	162735	1006.9	0	23223.30	7.30	82.00	2.0	0.64	112	4.00	1.21	19.75	1.8	MS
29	8:00	237947385.0	174038	1006.9	0	23230.60	7.90	80.00	1.0	0.76	108	10.00	1.34	18.00	1.0	MS
30	8:00	238121423.0	134596	1006.9	0	23238.50	5.40	79.00	2.0	0.94	98	8.00	0.87	17.00	1.0	MS
31	8:00	238256019.0	160701	1006.9	0	23243.90	7.90	77.00	2.0	0.84	90	8.00	0.99	16.00	1.0	IS
1	8:00	238416720		1006.9		23257.8		75.0		0.8	82		1.13	15		MS
TOT			4222767				188			36.93			31.65			
AVE			136218				6			1.12			0.96			
MAX			174038				8			2.12			2.13			
MIN			71163				4			0.64			0.28			

SIGNATURE: Jon Stear
PHONE: 815-224-1650

VILLAGE OF POPLAR GROVE **DAILY DISTRIBUTION MONITORING REPORT**
FOR THE MONTH OF 2020
ILLINOIS ENVIRONMENTAL PROTECTION AGENCY
DIVISION OF PUBLIC WATER SUPPLIES

Date	North System (Wells 2 & 3)				West System (Well 4)				South System (Wells 5 & 6)				Operator Initials	Flouride Analysis				
	Site #	Free Cl_2	Total Cl_2	PO_4	Site #	Free Cl_2	Total Cl_2	PO_4	Site #	Free Cl_2	Total Cl_2	PO_4		1.0 mg.L Standard	Well #2	Well #3	Well #4	Well#5-6
1	Tower	0.71		0.69	Tower	0.13		1.30	Tower	0.82		1.65	JS			1.20	1.00	0.66
2	Tower	0.68		0.72	Tower	0.91		1.70	Tower	0.76		1.23	JS			0.97	0.60	0.80
3																1.50	0.66	0.85
4																0.80	0.66	0.52
5																0.86	0.72	2.00
6	Tower	1.13		0.28	Tower	0.31		0.83	Tower	0.87		1.38	MS			0.53	0.59	0.80
7	Tower	1.20		1.09	Tower	0.38		1.20	Tower	0.87		1.20	MS			0.89	0.52	0.73
8	Tower	1.07		0.76	Tower	0.22		1.45	Tower	0.81		1.28	JS			0.87	0.43	0.66
9	Tower	2.12		0.56	Tower	0.21		1.20	Tower	0.97		1.33	JS			0.90	0.35	0.74
10	Tower	0.81		2.13	Tower	0.50		1.57	Tower	0.70		1.38	JS			1.00	0.47	0.71
11																0.98	0.66	0.76
12																1.00	0.33	2.00
13	Tower	1.67		0.99	Tower	0.04		1.10	Tower	0.67		1.68	MS			1.20	0.65	0.79
14	Tower	1.19		1.01	Tower	1.97		1.04	Tower	0.75		1.29	JS/MS			0.91	0.61	0.76
15	Tower	1.24		0.68	Tower	1.77		1.15	Tower	0.76		1.48	JS			0.93	0.69	0.72
16	Tower	1.26		1.15	Tower	1.53		1.16	Tower	1.04		1.19	JS			1.40	0.46	0.85
17	Tower	0.83		0.89	Tower	1.39		1.30	Tower	0.69		1.54	JS			0.84	0.60	0.90
18																0.96	0.57	0.81
19																0.74	0.55	0.78
20	Tower	1.25		0.81	Tower	1.39		1.16	Tower	0.73		1.32	JS			0.77	0.56	0.85
21	Tower	1.06		1.04	Tower	1.08		1.28	Tower	0.69		1.43	JS			1.10	0.64	0.67
22	Tower	0.96		1.28	Tower	0.33		1.10	Tower	0.71		1.59	JS			0.87	0.57	0.84
23	Tower	0.93		1.81	Tower	1.05		1.20	Tower	0.65		1.39	JS			1.40	0.63	0.73
24	Tower	1.32		0.88	Tower	1.14		1.24	Tower	0.70		1.39	MS			1.10	0.73	0.92
25																0.99	0.91	0.70
26																1.10	1.50	0.92
27	Tower	0.99		0.70	Tower	0.88		1.01	Tower	0.55		1.16	MS			0.69	1.10	0.24
28	Tower	0.64		1.21	Tower	0.61		1.39	Tower	0.59		1.31	MS			1.30	0.81	0.87
29	Tower	0.73		1.34	Tower	0.81		1.31	Tower	0.51		1.46	MS			1.30	0.59	0.84
30	Tower	0.94		0.87	Tower	0.96		1.26	Tower	0.5		1.56	MS			0.32	0.21	0.24
31																1.30	0.73	2.00
1																		

Signature: Jon Stear
PHONE: 815-224-1650

DMR Copy of Record

Permit

Permit #:	**IL0023451**	**Permittee:**	POPLAR GROVE, VILLAGE OF	**Facility:**	POPLAR GROVE - NORTH WWTP, VILLAGE OF
Major:	No	**Permittee Address:**	PO BOX 1 POPLAR GROVE, IL 61065	**Facility Location:**	205 EDSON RD POPLAR GROVE, IL 61065
Permitted Feature:	INF Influent Structure	**Discharge:**	**INF-L** INFLUENT MONITORING		

Report Dates & Status

Monitoring Period:	**From 07/01/20 to 07/31/20**	**DMR Due Date:**	**08/25/20**	**Status:**	**NetDMR Validated**

Considerations for Form Completion

BOW ID: W0070150007

Principal Executive Officer

First Name:	Ion	**Title:**	Certified Operator	**Telephone:**	
Last Name:	Stear				

No Data Indicator (NODI)

Form NODI: --

Parameter Code	Parameter Name	Monitoring Location	Season #	Param. NODI		Quantity or Loading Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Quality or Concentration Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units	# of Ex.	Frequency of Analysis	Sample Type
00310	**BOD, 5-day, 20 deg. C**	G - Raw Sewage Influent	0	--	Sample						<	67.0					19 - mg/L		02/DA - 2 Days Every Week	CP - COMPOS
					Permit Req.							Req Mon MO AVG					19 - mg/L	0	02/DA - 2 Days Every Week	CP - COMPOS
					Value NODI															
00530	**Solids, total suspended**	G - Raw Sewage Influent	0	--	Sample						=	101.5					19 - mg/L		02/DA - 2 Days Every Week	CP - COMPOS
					Permit Req.							Req Mon MO AVG					19 - mg/L	0	02/DA - 2 Days Every Week	CP - COMPOS
					Value NODI															
50050	**Flow, in conduit or thru treatment plant**	G - Raw Sewage Influent	0	--	Sample	=	0.384	=	0.577	03 - MGD									99/99 - Continuous	
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD								0	99/99 - Continuous	
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

POPLAR GROVE, VILLAGE OF

User:	ebumgarner
Name:	Elaine Bumgarner
E-Mail:	ebumgarner@testinc.com
Date/Time:	2020-08-24 08:27 (Time Zone: -05:00)

Report Last Signed By

User:	IONSTEAR
Name:	Ion Stear
E-Mail:	istear@testinc.com
Date/Time:	2020-08-24 08:42 (Time Zone: -05:00)

DMR Copy of Record

Permit

Permit #:	**IL0023451**	**Permittee:**	POPLAR GROVE, VILLAGE OF	**Facility:**	POPLAR GROVE - NORTH WWTP, VILLAGE OF
Major:	No	**Permittee Address:**	PO BOX 1 POPLAR GROVE, IL 61065	**Facility Location:**	205 EDSON RD POPLAR GROVE, IL 61065
Permitted Feature:	001 External Outfall	**Discharge:**	**001-0** STP OUTFALL		

Report Dates & Status

Monitoring Period:	**From 07/01/20 to 07/31/20**	**DMR Due Date:**	**08/25/20**	**Status:**	**NetDMR Validated**

Considerations for Form Completion

BOW ID: W0070150007; DMF LOAD LIMITS DISPLAYED.MONITORING LOCATION "1" IS FORMONTHLY AVERAGE AND DAILY MAXIMUM.MONITORING LOCATION "8" IS FORWEEKLY AVERAGE.

Principal Executive Officer

First Name:	Ion	**Title:**	Certified Operator	**Telephone:**	
Last Name:	Stear				

No Data Indicator (NODI)

Form NODI: --

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample								=	7.87	=	7.76	19 - mg/L	0	02/DA - 2 Days Every Week	GR - GRAB
					Permit Req.								>=	6.25 MN WK AV	>=	5.0 DAILY MN	19 - mg/L		02/DA - 2 Days Every Week	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	7.26			=	7.79	12 - SU	0	02/DA - 2 Days Every Week	GR - GRAB
					Permit Req.						>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU		02/DA - 2 Days Every Week	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	26.5	=	48.22	26 - lb/d			=	7.5	=	14.0	19 - mg/L		02/DA - 2 Days Every Week	CP - COMPOS
					Permit Req.	<=	125.0 MO AVG	<=	250.0 DAILY MX	26 - lb/d			<=	12.0 MO AVG	<=	24.0 DAILY MX	19 - mg/L		02/DA - 2 Days Every Week	CP - COMPOS
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	=	0.265	=	0.372	26 - lb/d			=	0.0768	=	0.108	19 - mg/L	0	02/DA - 2 Days Every Week	CP - COMPOS
					Permit Req.	<=	16.0 MO AVG	<=	31.0 DAILY MX	26 - lb/d			<=	1.5 MO AVG	<=	3.0 DAILY MX	19 - mg/L		02/DA - 2 Days Every Week	CP - COMPOS
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.413	=	0.573	03 - MGD								0	99/99 - Continuous	
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD									99/99 - Continuous	
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample										=	0.0	19 - mg/L	0	01/30 - Monthly	GR - GRAB
					Permit Req.										<=	0.05 DAILY MX	19 - mg/L		01/30 - Monthly	GR - GRAB
					Value NODI															
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample										T					
					Permit Req.											Req Mon DAILY MX	13 - #/100mL		01/30 - Monthly	GR - GRAB
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	<	10.33	<	10.33	26 - lb/d			<	3.0	<	3.0	19 - mg/L	0	02/DA - 2 Days Every Week	CP - COMPOS
					Permit Req.	<=	104.0 MO AVG	<=	209.0 DAILY MX	26 - lb/d			<=	10.0 MO AVG	<=	20.0 DAILY MX	19 - mg/L		02/DA - 2 Days Every Week	CP - COMPOS
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

POPLAR GROVE, VILLAGE OF

User:	ebumgarner
Name:	Elaine Bumgarner
E-Mail:	ebumgarner@testinc.com
Date/Time:	2020-08-24 08:28 (Time Zone: -05:00)

DMR Copy of Record

Permit

Permit #:	**IL0071447**	**Permittee:**	POPLAR GROVE, VILLAGE OF	**Facility:**	POPLAR GROVE SOUTH STP, VILLAGE OF
Major:	Yes	**Permittee Address:**	200 S HILL ST POPLAR GROVE, IL 61065	**Facility Location:**	12211 STATE ROUTE 76 POPLAR GROVE, IL 61065
Permitted Feature:	INF Influent Structure	**Discharge:**	**INF-L** INFLUENT MONITORING		

Report Dates & Status

Monitoring Period:	**From 07/01/20 to 07/31/20**	**DMR Due Date:**	**08/25/20**	**Status:**	**NetDMR Validated**

Considerations for Form Completion

BOW ID: W0070150006

Principal Executive Officer

First Name:	Ion	**Title:**	Certified Operator	**Telephone:**	
Last Name:	Stear				

No Data Indicator (NODI)

Form NODI: --

Parameter Code	Parameter Name	Monitoring Location	Season #	Param. NODI		Quantity or Loading Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Quality or Concentration Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units	# of Ex.	Frequency of Analysis	Sample Type
00310	**BOD, 5-day, 20 deg. C**	G - Raw Sewage Influent	0	--	Sample								<	75.0			19 - mg/L		03/DW - 3 Days Every Week	CP - COMPOS
					Permit Req.									Req Mon MO AVG			19 - mg/L	0	03/DW - 3 Days Every Week	CP - COMPOS
					Value NODI															
00530	**Solids, total suspended**	G - Raw Sewage Influent	0	--	Sample								=	101.8			19 - mg/L		03/DW - 3 Days Every Week	CP - COMPOS
					Permit Req.									Req Mon MO AVG			19 - mg/L	0	03/DW - 3 Days Every Week	CP - COMPOS
					Value NODI															
00665	**Phosphorus, total [as P]**	1 - Effluent Gross	0	--	Sample								=	4.33	=	5.76	19 - mg/L		03/DW - 3 Days Every Week	CP - COMPOS
					Permit Req.									Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L	0	03/DW - 3 Days Every Week	CP - COMPOS
					Value NODI															
50050	**Flow, in conduit or thru treatment plant**	G - Raw Sewage Influent	0	--	Sample	=	0.163	=	0.219	03 - MGD									99/99 - Continuous	
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD								0	99/99 - Continuous	
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

POPLAR GROVE, VILLAGE OF

User:	ebumgarner
Name:	Elaine Bumgarner
E-Mail:	ebumgarner@testinc.com
Date/Time:	2020-08-24 08:30 (Time Zone: -05:00)

Report Last Signed By

User:	IONSTEAR
Name:	Ion Stear
E-Mail:	istear@testinc.com
Date/Time:	2020-08-24 08:42 (Time Zone: -05:00)

DMR Copy of Record

Permit

Permit #:	**IL0071447**	**Permittee:**	POPLAR GROVE, VILLAGE OF	**Facility:**	POPLAR GROVE SOUTH STP, VILLAGE OF
Major:	Yes	**Permittee Address:**	200 S HILL ST POPLAR GROVE, IL 61065	**Facility Location:**	12211 STATE ROUTE 76 POPLAR GROVE, IL 61065
Permitted Feature:	001 External Outfall	**Discharge:**	**001-0** **STP OUTFALL**		

Report Dates & Status

Monitoring Period:	**From 07/01/20 to 07/31/20**	**DMR Due Date:**	**08/25/20**	**Status:**	**NetDMR Validated**

Considerations for Form Completion

BOW ID: W0070150006; DMF LOAD LIMITS DISPLAYED.

Principal Executive Officer

First Name:	Ion	**Title:**	Certified Operator	**Telephone:**	
Last Name:	Stear				

No Data Indicator (NODI)

Form NODI: --

Parameter Code	Parameter Name	Monitoring Location	Season #	Param. NODI		Quantity or Loading Qualifier 1	Quantity or Loading Value 1	Quantity or Loading Qualifier 2	Quantity or Loading Value 2	Quantity or Loading Units	Quality or Concentration Qualifier 1	Quality or Concentration Value 1	Quality or Concentration Qualifier 2	Quality or Concentration Value 2	Quality or Concentration Qualifier 3	Quality or Concentration Value 3	Quality or Concentration Units	# of Ex.	Frequency of Analysis	Sample Type
00300	**Oxygen, dissolved [DO]**	1 - Effluent Gross	0	--	Sample								=	6.35	=	6.0	19 - mg/L		03/DW - 3 Days Every Week	GR - GRAB
					Permit Req.								>=	6.25 MN WK AV	>=	5.0 DAILY MN	19 - mg/L	0	03/DW - 3 Days Every Week	GR - GRAB
					Value NODI															
00400	**pH**	1 - Effluent Gross	0	--	Sample						=	7.13			=	7.64	12 - SU		03/DW - 3 Days Every Week	GR - GRAB
					Permit Req.						>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU	0	03/DW - 3 Days Every Week	GR - GRAB
					Value NODI															
00530	**Solids, total suspended**	1 - Effluent Gross	0	--	Sample	=	13.43	=	20.9	26 - lb/d			=	5.77	=	9.0	19 - mg/L		03/DW - 3 Days Every Week	CP - COMPOS
					Permit Req.	<=	250.0 MO AVG	<=	500.0 DAILY MX	26 - lb/d			<=	12.0 MO AVG	<=	24.0 DAILY MX	19 - mg/L		03/DW - 3 Days Every Week	CP - COMPOS
					Value NODI															
00600	**Nitrogen, total [as N]**	1 - Effluent Gross	0	--	Sample								=	12.4	=	12.4	19 - mg/L		01/30 - Monthly	CP - COMPOS
					Permit Req.									Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L	0	01/30 - Monthly	CP - COMPOS
					Value NODI															
00610	**Nitrogen, ammonia total [as N]**	1 - Effluent Gross	1	--	Sample	=	0.156	=	0.209	26 - lb/d			=	0.067	=	0.09	19 - mg/L		03/DW - 3 Days Every Week	CP - COMPOS
					Permit Req.	<=	31.0 MO AVG	<=	113.0 DAILY MX	26 - lb/d			<=	1.5 MO AVG	<=	5.4 DAILY MX	19 - mg/L	0	03/DW - 3 Days Every Week	CP - COMPOS
					Value NODI															
00610	**Nitrogen, ammonia total [as N]**	8 - Other Treatment, Process Complete	1	--	Sample			=	0.193	26 - lb/d					=	0.083	19 - mg/L		03/DW - 3 Days Every Week	CP - COMPOS
					Permit Req.			<=	79.0 WKLY AVG	26 - lb/d					<=	3.8 WKLY AVG	19 - mg/L	0	03/DW - 3 Days Every Week	CP - COMPOS
					Value NODI															
00665	**Phosphorus, total [as P]**	1 - Effluent Gross	0	--	Sample	=	0.854			26 - lb/d			=	0.367			19 - mg/L		03/DW - 3 Days Every Week	CP - COMPOS
					Permit Req.	<=	21.0 MO AVG			26 - lb/d			<=	1.0 MO AVG			19 - mg/L	0	03/DW - 3 Days Every Week	CP - COMPOS
					Value NODI															
50050	**Flow, in conduit or thru treatment plant**	1 - Effluent Gross	0	--	Sample	=	0.279	=	0.42	03 - MGD									99/99 - Continuous	
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD								0	99/99 - Continuous	
					Value NODI															
50060	**Chlorine, total residual**	1 - Effluent Gross	0	--	Sample										=	0.0	19 - mg/L		CL/OC - Chlorination/Occurances	GR - GRAB
					Permit Req.										<=	0.05 DAILY MX	19 - mg/L	0	CL/OC - Chlorination/Occurances	GR - GRAB
					Value NODI															
74055	**Coliform, fecal general**	1 - Effluent Gross	0	--	Sample										=	80.0	13 - #/100mL		03/DW - 3 Days Every Week	GR - GRAB
					Permit Req.										<=	400.0 DAILY MX	13 - #/100mL	0	03/DW - 3 Days Every Week	GR - GRAB
					Value NODI															
80082	**BOD, carbonaceous [5 day, 20 C]**	1 - Effluent Gross	0	--	Sample	<	6.98	<	6.98	26 - lb/d			<	3.0	<	3.0	19 - mg/L		03/DW - 3 Days Every Week	CP - COMPOS
					Permit Req.	<=	209.0 MO AVG	<=	417.0 DAILY MX	26 - lb/d			<=	10.0 MO AVG	<=	20.0 DAILY MX	19 - mg/L	0	03/DW - 3 Days Every Week	CP - COMPOS
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

POPLAR GROVE, VILLAGE OF

User:	ebumgamer
Name:	Elaine Bumgamer
E-Mail:	ebumgamer@testinc.com
Date/Time:	2020-08-24 08:31 (Time Zone: -05:00)

Report Last Signed By

User:	IONSTEAR
Name:	Ion Stear
E-Mail:	istear@testinc.com
Date/Time:	2020-08-24 08:42 (Time Zone: -05:00)

DMR Copy of Record

Permit

Permit #:	**IL0071447**	**Permittee:**	POPLAR GROVE, VILLAGE OF	**Facility:**	POPLAR GROVE SOUTH STP, VILLAGE OF
Major:	Yes	**Permittee Address:**	200 S HILL ST POPLAR GROVE, IL 61065	**Facility Location:**	12211 STATE ROUTE 76 POPLAR GROVE, IL 61065
Permitted Feature:	001 External Outfall	**Discharge:**	**001-S** SEMI ANNUAL SAMPLING @ 001		

Report Dates & Status

Monitoring Period:	**From 02/01/20 to 07/31/20**	**DMR Due Date:**	**08/25/20**	**Status:**	**NetDMR Validated**

Considerations for Form Completion

Principal Executive Officer

First Name:	Ion	**Title:**	Certified Operator	**Telephone:**	
Last Name:	Stear				

No Data Indicator (NODI)

Form NODI: –

Parameter Code	Parameter Name	Monitoring Location	Season #	Param. NODI		Quantity or Loading Qualifier 1	Quantity or Loading Value 1	Quantity or Loading Qualifier 2	Quantity or Loading Value 2	Quantity or Loading Units	Quality or Concentration Qualifier 1	Quality or Concentration Value 1	Quality or Concentration Qualifier 2	Quality or Concentration Value 2	Quality or Concentration Qualifier 3	Quality or Concentration Value 3	Quality or Concentration Units	# of Ex.	Frequency of Analysis	Sample Type
00556	**Oil & Grease**	1 - Effluent Gross	0	–	Sample						<	1.04					19 - mg/L		09/99 - See Permit	GR - GRAB
					Permit Req.							Req Mon DAILY MX					19 - mg/L	0	09/99 - See Permit	GR - GRAB
					Value NODI															
00720	**Cyanide, total [as CN]**	1 - Effluent Gross	0	–	Sample						=	0.0					28 - ug/L		09/99 - See Permit	GR - GRAB
					Permit Req.							Req Mon DAILY MX					28 - ug/L	0	09/99 - See Permit	GR - GRAB
					Value NODI															
00722	**Cyanide, free [amen. to chlorination]**	1 - Effluent Gross	0	–	Sample						=	0.0					28 - ug/L		09/99 - See Permit	GR - GRAB
					Permit Req.							Req Mon DAILY MX					28 - ug/L	0	09/99 - See Permit	GR - GRAB
					Value NODI															
00951	**Fluoride, total [as F]**	1 - Effluent Gross	0	–	Sample						=	0.245					19 - mg/L		09/99 - See Permit	24 - COMP24
					Permit Req.							Req Mon DAILY MX					19 - mg/L	0	09/99 - See Permit	24 - COMP24
					Value NODI															
01002	**Arsenic, total [as As]**	1 - Effluent Gross	0	–	Sample						<	0.0049					19 - mg/L		09/99 - See Permit	24 - COMP24
					Permit Req.							Req Mon DAILY MX					19 - mg/L	0	09/99 - See Permit	24 - COMP24
					Value NODI															
01007	**Barium, total [as Ba]**	1 - Effluent Gross	0	–	Sample						=	0.0418					19 - mg/L		09/99 - See Permit	24 - COMP24
					Permit Req.							Req Mon DAILY MX					19 - mg/L	0	09/99 - See Permit	24 - COMP24
					Value NODI															
01027	**Cadmium, total [as Cd]**	1 - Effluent Gross	0	–	Sample						<	0.005					19 - mg/L		09/99 - See Permit	24 - COMP24
					Permit Req.							Req Mon DAILY MX					19 - mg/L	0	09/99 - See Permit	24 - COMP24
					Value NODI															
01032	**Chromium, hexavalent [as Cr]**	1 - Effluent Gross	0	–	Sample						<	0.005					19 - mg/L		09/99 - See Permit	GR - GRAB
					Permit Req.							Req Mon DAILY MX					19 - mg/L	0	09/99 - See Permit	GR - GRAB
					Value NODI															
01034	**Chromium, total [as Cr]**	1 - Effluent Gross	0	–	Sample						<	0.0076					19 - mg/L		09/99 - See Permit	24 - COMP24
					Permit Req.							Req Mon DAILY MX					19 - mg/L	0	09/99 - See Permit	24 - COMP24
					Value NODI															
01042	**Copper, total [as Cu]**	1 - Effluent Gross	0	–	Sample						<	0.0049					19 - mg/L		09/99 - See Permit	24 - COMP24
					Permit Req.							Req Mon DAILY MX					19 - mg/L	0	09/99 - See Permit	24 - COMP24
					Value NODI															
01045	**Iron, total [as Fe]**	1 - Effluent Gross	0	–	Sample						=	0.0183					19 - mg/L		09/99 - See Permit	24 - COMP24
					Permit Req.							Req Mon DAILY MX					19 - mg/L	0	09/99 - See Permit	24 - COMP24
					Value NODI															
01046	**Iron, dissolved [as Fe]**	1 - Effluent Gross	0	–	Sample						=	0.0118					19 - mg/L		09/99 - See Permit	24 - COMP24
					Permit Req.							Req Mon DAILY MX					19 - mg/L	0	09/99 - See Permit	24 - COMP24
					Value NODI															
01051	**Lead, total [as Pb]**	1 - Effluent Gross	0	–	Sample						<	0.0091					19 - mg/L		09/99 - See Permit	24 - COMP24
					Permit Req.							Req Mon DAILY MX					19 - mg/L	0	09/99 - See Permit	24 - COMP24
					Value NODI															

01055	**Manganese, total [as Mn]**	1 - Effluent Gross	0	--	Sample			=	0.00897	19 - mg/L		09/99 - See Permit	24 - COMP24
					Permit Req.				Req Mon DAILY MX	19 - mg/L	0	09/99 - See Permit	24 - COMP24
					Value NODI								
01067	**Nickel, total [as Ni]**	1 - Effluent Gross	0	--	Sample			<	0.00487	19 - mg/L		09/99 - See Permit	24 - COMP24
					Permit Req.				Req Mon DAILY MX	19 - mg/L	0	09/99 - See Permit	24 - COMP24
					Value NODI								
01077	**Silver, total [as Ag]**	1 - Effluent Gross	0	--	Sample			<	0.0084	19 - mg/L		09/99 - See Permit	24 - COMP24
					Permit Req.				Req Mon DAILY MX	19 - mg/L	0	09/99 - See Permit	24 - COMP24
					Value NODI								
01092	**Zinc, total [as Zn]**	1 - Effluent Gross	0	--	Sample			=	0.0365	19 - mg/L		09/99 - See Permit	24 - COMP24
					Permit Req.				Req Mon DAILY MX	19 - mg/L	0	09/99 - See Permit	24 - COMP24
					Value NODI								
01147	**Selenium, total [as Se]**	1 - Effluent Gross	0	--	Sample			<	0.0108	19 - mg/L		09/99 - See Permit	24 - COMP24
					Permit Req.				Req Mon DAILY MX	19 - mg/L	0	09/99 - See Permit	24 - COMP24
					Value NODI								
32730	**Phenolics, total recoverable**	1 - Effluent Gross	0	--	Sample			=	0.0	19 - mg/L		09/99 - See Permit	GR - GRAB
					Permit Req.				Req Mon DAILY MX	19 - mg/L	0	09/99 - See Permit	GR - GRAB
					Value NODI								
71900	**Mercury, total [as Hg]**	1 - Effluent Gross	0	--	Sample			=	0.0	3M - ng/L		09/99 - See Permit	GR - GRAB
					Permit Req.				Req Mon DAILY MX	3M - ng/L	0	09/99 - See Permit	GR - GRAB
					Value NODI								

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

POPLAR GROVE, VILLAGE OF

User:	ebumgarner
Name:	Elaine Bumgarner
E-Mail:	ebumgarner@testinc.com
Date/Time:	2020-08-18 16:11 (Time Zone: -05:00)

Report Last Signed By

User:	IONSTEAR
Name:	Ion Stear
E-Mail:	istear@testinc.com
Date/Time:	2020-08-24 08:42 (Time Zone: -05:00)