

Inspection Checklist

Date:08/12/2026

Location:604 S Virginia

Inspector:

Bradley Shaffer

	Pass	Fail	Violation/Deficiency	Location of violation
Roof properly maintained	X			
Improper Walls, partitions or other vertical supports		X	Evidence of damage to wall supports	
Fireplaces or chimneys properly maintained	N/A			
Unsecure building: vacant and open.		X	Damaged Windows and door open	
Lack of required rails, stairs, steps and/or balconies		X	Porch damaged	
Lack of or improper exterior wall coverings		X	Exterior wall coverings damaged in some areas	
Hazardous wiring		X	Unable to verify	
Hazardous plumbing		X	Unable to verify	
Hazardous mechanical equipment			Unable to verify	
Sanitation:	X			
Lack of or improper connection to required sewage disposal			Unable to verify	
Lack of or improper garbage and rubbish storage		X	No rubbish storage	
Standing or stagnant water		N/A		
Improper Drainage	X			
Improper Occupancy	X			
Inadequate exits	X			
Improper Fireplace or Chimney	X			

Improper Ceiling or Ceiling supports		X	Roof Damage leaves evidence of damage to ceilings	
Improper Flooring or floor supports		X	Unable to verify	
Improper Foundation		X	Evidence of foundation damage	
Vermin/Insects		X	Possible damage from insects present	
Dampness of habitable space		X	Unable to verify	
Lack of electrical lighting	X			
Hot and Cold Water	X			
Lack of or Improper Kitchen	X			
Lack of or Improper bathroom	X			
Dead trees, tree limbs, holes, excavations or other conditions reasonably capable of causing injury to a person.		X	Trip hazards present	

This inspection was completed in accordance with Sec. 12-287 of the City of Port Lavaca Code of Ordinances.

State Law reference— Authority to condemn dangerous buildings, V.T.C.A., Local Government Code § 342.012(b).