

Port Lavaca Port Commission Monthly Building Inspection

Month: **SEPTEMBER 2024** Location: **NLB**

10 SEPTEMBER 2024

1. Building Maintenance:

Condition: **Satisfactory** Unsatisfactory Not Applicable

Comments: **18 September 2024 Barefoot Construction replaced bad condensing unit fan motor suite 5.**

2. Decking:

Condition: **Satisfactory** Unsatisfactory Not Applicable

Comments:

3. Flooring:

Condition: **Satisfactory** Unsatisfactory Not Applicable

Comments:

4. Windows:

Condition: **Satisfactory** Unsatisfactory Not Applicable

Comments:

5. Water Lines, Valves, Etc.

Condition: **Satisfactory** Unsatisfactory Not Applicable

Comments:

6. Electrical & Lights

Condition: **Satisfactory** Unsatisfactory Not Applicable

Comments:

7. HVAC

Condition: **Satisfactory** Unsatisfactory Not Applicable

Comments:

8. Roof:

Condition: **Satisfactory** Unsatisfactory Not Applicable

Comments:

9. Parking:

Condition: **Satisfactory** Unsatisfactory Not Applicable

Comments:

10. Fire Extinguishers:

Condition: **Satisfactory** Unsatisfactory Not Applicable

Comments:

11. Hand Railing:

Condition: **Satisfactory** Unsatisfactory Not Applicable

Comments:

12. Stairs & Steps

Condition: **Satisfactory** Unsatisfactory Not Applicable

Comments:

Harbor Master: _____