

Port Lavaca Port Commission

Monthly Inspection

Month: 18 JULY 2023 Location: NLM / Smith Harbor

1. Gangway

Condition: Satisfactory Unsatisfactory Not Applicable

Comments:

2. Decking

Condition: Satisfactory Unsatisfactory Not Applicable

Comments:

3. Main Frame & Floats

Condition: Satisfactory Unsatisfactory Not Applicable

Comments:

4. Dock Boxes

Condition: Satisfactory Unsatisfactory Not Applicable

Comments: Dock A there are six dock boxes with broken hinges and Three boxes missing.

5. Water Lines, Valves, Etc.

Condition: Satisfactory Unsatisfactory Not Applicable

Comments:

6. Electrical & Lights

Condition: Satisfactory Unsatisfactory Not Applicable

Comments: 23 June 23 called out Hayes Electric to check power on B Dock found one dead leg called AEP they came out and repaired.

7. Pilings, Guides & Rollers

Condition: Satisfactory Unsatisfactory Not Applicable

Comments:

8. Rub Rails & Fenders

Condition: Satisfactory Unsatisfactory Not Applicable

Comments: Dock A there are two 6' sections of rub rail damaged.

9. Cleats & Kevels

Condition: Satisfactory Unsatisfactory Not Applicable

Comments: Dock A 15 broken cleats, Dock B 2 broken cleats.

10. Gates & Locks

Condition: Satisfactory Unsatisfactory Not Applicable

Comments:

11. Dredging

Condition: Satisfactory Unsatisfactory Not Applicable

Comments:

12. Cement Cap

Condition: Satisfactory Unsatisfactory Not Applicable

Comments:

13. Bulkhead

Condition: Satisfactory Unsatisfactory Not Applicable

Comments:

Harbor Master: _____