

Port Lavaca Port Commission Monthly Building Inspection

Month: 17 JANUARY 2023 Location: NLB

1. Doors:

Condition: Satisfactory Unsatisfactory Not Applicable

Comments:

2. Decking:

Condition: Satisfactory Unsatisfactory Not Applicable

Comments: SOME DECK BOARD NEED REPLACING.

3. Flooring:

Condition: Satisfactory Unsatisfactory Not Applicable

Comments:

4. Windows:

Condition: Satisfactory Unsatisfactory Not Applicable

Comments:

5. Water Lines, Valves, Etc.

Condition: Satisfactory Unsatisfactory Not Applicable

Comments:

6. Electrical & Lights

Condition: Satisfactory Unsatisfactory Not Applicable
Comments:

7. HVAC

Condition: Satisfactory Unsatisfactory Not Applicable
Comments:

8. Roof:

Condition: Satisfactory Unsatisfactory Not Applicable
Comments: 28 JANUARY 2022 ROOF LEAK APPEARED OVER SUITE 2.

9. Parking:

Condition: Satisfactory Unsatisfactory Not Applicable
Comments:

10. Fire Extinguishers:

Condition: Satisfactory Unsatisfactory Not Applicable
Comments:

11. Hand Railing:

Condition: Satisfactory Unsatisfactory Not Applicable
Comments:

12. Stairs & Steps

Condition: Satisfactory Unsatisfactory Not Applicable
Comments:

Harbor Master: _____