

# Port Lavaca Port Commission

## Monthly Inspection

Month: 17 OCTOBER 2023    Location: City Harbor

### 1. Fueling Area

Condition: Satisfactory    Unsatisfactory    Not Applicable

Comments:

### 2. Decking

Condition: Satisfactory    Unsatisfactory    Not Applicable

Comments:

### 3. Main Frame & Floats

Condition: Satisfactory    Unsatisfactory    Not Applicable

Comments:

### 4. CLEAN UP

Condition: Satisfactory    Unsatisfactory    Not Applicable

Comments: 31 March 2023, Put disposable oil boom out at south end of harbor where the city storm drain spills in harbor, due to oil coming from drain. 20 SEPTEMBER 2023 AIMS COMPANIES ran CCTV up outfall found Sewer and grease running in to storm drain from sewer.

### 5. Water Lines, Valves, Etc.

Condition: Satisfactory    Unsatisfactory    Not Applicable

Comments: 9 OCTOBER 2023 Port Lavaca Plumbing replaced drain pipe Under sink in the bathroom at the Evelyns building.

### 6. Electrical & Lights

Condition: Satisfactory    Unsatisfactory    Not Applicable

Comments:

**7. Pilings, Guides & Rollers**

Condition: **Satisfactory**    Unsatisfactory    Not Applicable

Comments:

**8. Rub Rails & Fenders**

Condition: **Satisfactory**    Unsatisfactory    Not Applicable

Comments:

**9. Cleats & Kevels**

Condition: **Satisfactory**    Unsatisfactory    Not Applicable

Comments:

**10. Gates & Locks**

Condition: **Satisfactory**    Unsatisfactory    Not Applicable

Comments:

**11. Railing**

Condition: **Satisfactory**    Unsatisfactory    Not Applicable

Comments:

**12. Cement Slab**

Condition: **Satisfactory**    Unsatisfactory    Not Applicable

Comments:

**13. Bulkhead**

Condition: **Satisfactory**    Unsatisfactory    Not Applicable

Comments:

**Harbor Master:** \_\_\_\_\_