



# R E P U B L I C **BUILDS**

Public Works • Community Development

## Memo of Approval

To whom it concerns:

The City of Republic advertised for sealed bids for a new Dry- Prime Pump for the BUILDS Dept. This pump will be for emergency situations on our wastewater lift stations. The pump must have a least the following requirements to be considered.

### PUMP

1. 8" suction connection
2. 6" discharge connection
3. Discharge capacity of at least 2,500 gallons per minute
4. Solid handling of 1.5" or greater
5. Automatic Prime
6. Automatic Start
7. Dry weight of 6,300 lbs
8. Wet weight of 7,600 lbs
9. Dimensions (L) 147"x (W) 55"x (H) 84"
10. Trailer Mounted

### Engine

1. Diesel
2. 220 Hp or Greater @ 2000rpm
3. 180-gallon fuel capacity
4. Impeller Diameter = 15.7"

The City received (2) acceptable bids. The first was from Fluid Equipment for \$122,400.00 with a 20–30 weeks lead time. It also came with a Special Rate on rental of the same unit of 50% if needed before delivery. The pump offered is the same model pump we rent and have a set up already for. The second was from Independent Electric for \$120,000.00 with no lead time reported on bid. This pump is very similar and acceptable but will take a few modifications to set up.

Jason Davis  
Operations Manager, BUILDS Dept  
204 N Main, Republic Mo 65738  
(417) 732-3401 jasondavis@republicmo.com



R E P U B L I C  
**BUILDS**  
Public Works • Community Development

After deliberations we would like to accept the bid from Fluid Equipment for \$122,400.00 due to familiarity of the pump set up and also the 50% reduction in rental cost if a pump is needed during delivery lead time.

Thank you,

*Jason Davis*

Jason Davis

Operations Manager

Jason Davis  
Operations Manager, BUILDS Dept  
204 N Main, Republic Mo 65738  
(417) 732-3401 [jasondavis@republicmo.com](mailto:jasondavis@republicmo.com)